

IEEE Std C57.91-1995
(Revision of IEEE Std C57.91-1981,
IEEE Std C57.92-1981, and
IEEE Std C57.115-1991)

IEEE Guide for Loading Mineral-Oil-Immersed Transformers

Sponsor
**Transformers Committee
of the
IEEE Power Engineering Society**

Approved June 14, 1995
IEEE Standards Board

Abstract: General recommendations for loading 65 °C rise mineral-oil-immersed distribution and power transformers are covered.

Keywords: distribution transformer, loading, mineral-oil-immersed, power transformer

The Institute of Electrical and Electronics Engineers, Inc.

345 East 47th Street, New York, NY 10017-2394, USA

Copyright © 1996 by the Institute of Electrical and Electronics Engineers, Inc.

All rights reserved. Published 1996. Printed in the United States of America.

ISBN 1-55937-569-8

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

IEEE Standards documents are developed within the Technical Committees of the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Board. Members of the committees serve voluntarily and without compensation. They are not necessarily members of the Institute. The standards developed within IEEE represent a consensus of the broad expertise on the subject within the Institute as well as those activities outside of IEEE that have expressed an interest in participating in the development of the standard.

Use of an IEEE Standard is wholly voluntary. The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of all concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason IEEE and the members of its technical committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration.

Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE Standards Board
445 Hoes Lane
P.O. Box 1331
Piscataway, NJ 08855-1331
USA

NOTE — Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying all patents for which a license may be required by an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; (508) 750-8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Introduction

(This introduction is not part of IEEE Std C57.91-1995, IEEE Guide for Loading Mineral-Oil-Immersed Transformers.)

This guide is applicable to loading 65 °C mineral-oil-immersed distribution and power transformers. Guides for loading, IEEE Std C57.91-1981 (prior edition), IEEE Std C57.92-1981, and IEEE Std C57.115-1991 (redesignation of IEEE Std 756) are all combined in this document as the basic theory of transformer loading is the same, whether the subject is distribution transformers, power transformers 100 MVA and smaller, or transformers larger than 100 MVA. In recognition of different types of construction, special considerations, and the degree of conservatism involved in the loading of this equipment, specific clauses are devoted to power transformers and distribution transformers. In the previously referenced information, the guide for units larger than 100 MVA referenced the IEEE Std C57.92-1981 loading guide for units up to and including 100 MVA.

In the previous guides, different insulation aging curves were used for power transformers and distribution transformers. This was caused by the different evaluation procedures used. The distribution transformer curve was based on aging tests of actual transformers. The power transformer curve was based on aging insulation samples in test containers to achieve 50% retention of tensile strength. Investigation of cellulosic insulating materials removed from transformers that had long service life has led knowledgeable people to question the validity of the 50% criteria. One new criteria suggested is 25% retention. This revised guide will permit the user to select the criteria most acceptable to their need, based on percent strength retention, polymerization index, etc. An insulation aging factor may thus be applied.

A per unit life concept and aging acceleration factor were introduced in this loading guide. The equations given may be used to calculate percent loss of total insulation life, as has been the practice in earlier editions of the transformer loading guides. The relationship between insulation life and transformer life is a question that remains to be resolved. It is recognized that under the proper conditions, transformer life can well exceed the life of the insulation.

The assumed characteristics used in previous guides contained tables of loading capability based on assumed typical transformer characteristics. These assumed characteristics were recognized as not being those of actually built units, which may have a wide range of characteristics. In this guide these tables were removed since computer technology permits calculation of loading capability based on specific transformer characteristics.

Two methods of calculating temperatures are given in this guide. Clause 7 contains temperature equations similar to those used in previous editions of this guide. These equations use the winding hot spot rise over tank top oil and assume that the oil temperature in the cooling ducts is the same as the tank top oil during overloads. Recent research using imbedded thermocouples and fiber optic detectors indicates that the fluid flow occurring in the windings during transient heating and cooling is an extremely complicated phenomena to describe by simple equations. These recent investigations have shown that during overloads, the temperature of the oil in the winding cooling ducts rises rapidly and exceeds the top-oil temperature in the tank. An alternate set of equations based on this concept is given in annex G. The change of losses with temperature and liquid viscosity effects, and variable ambient temperature was incorporated into the equations. A computer program based on these equations is given for evaluation by the industry. Research in this field is ongoing at this time and may be incorporated into future revisions of this guide.

Changes in the guide, in addition to the consolidation, include information to more accurately load transformers operating down to a –30 °C ambient, information regarding loss of diversity due to cold load pick-up or unusually low ambient temperatures.

Transformers rated 55 °C rise were generally replaced as a standard offering by most manufacturers about 1966. Their replacements were originally rated 55/65 °C and in 1977 the single 65 °C rated transformers became the industry standard offering. The higher temperature ratings are based on thermally upgraded oil-paper-enamel insulation systems. Loading of 55 °C insulation system transformers is covered in annex D.

Suggestions for improvement gained in the use of this guide will be welcomed. They should be sent to the IEEE Standards Department.

The Accredited Standards Committee on Transformers, Regulators, and Reactors, C57, that reviewed and approved this document, had the following membership at the time of approval:

P. E. Orehek, *Chair*
vacant, *Vice Chair*
John A. Gauthier, *Secretary*

Electric Light and Power Group	E.A. Bertolini T. Diamantis E. Hanus M. C. Mingoia (<i>Alt.</i>) P. Orehek G. Paiva J. Sullivan
Institute of Electrical and Electronics Engineers	W. B. Binder J. D. Borst J. H. Harlow J. W. Matthews L. Savio H. D. Smith (<i>Alt.</i>) G. H. Vaillancourt
National Electrical Manufacturers Association	G. D. Coulter P. Dewever (<i>Alt.</i>) J. Douglas S. Endersbe A. Ghafourian P. Hopkinson K. R. Linsley R. L. Plaster (<i>Alt.</i>) H. Robin
Tennessee Valley Authority	F. Lewis
Underwriters Laboratories, Inc.	M. Schacker
US Department of Agriculture, REA.....	J. Bohlk
US Department of Energy, Western Area Power Administration	Kenneth C. Wolohon
US Department of Interior, Bureau of Reclamation	R. Chadwick
US Department of the Navy, Civil Engineering Corps.	H. P. Stickley

At the time it approved this standard, the IEEE/PES Transformers Committee had the following officers:

J. H. Harlow, *Chair*
W.B. Binder, *Vice Chair*
J. W. Matthews, *Secretary*
Georges Vaillancourt, *Standards Coordinator*

This guide was produced by the IEEE Working Group for Loading Mineral-Oil-Immersed Transformers, which had the following membership:

Linden W. Pierce, *Chair*^a

M. Altman	D. Gerlach	J. M. Pollitt
R. Anderson	D. Goodwin	A. Rizvi
R. J. Ardolino	R. L. Grubb	V. S. N. Sankar
J. Aubin	G. Hall	D. N. Sharma
D. E. Ayers	J. H. Harlow	T. Singh
R. Barker	G. Henry	M. Springrose
B. Beaster	P. J. Hopkinson	T. Stewart
W. B. Binder, Jr.	C. P. Kappeler	C. L. Stiegmeier
T. Bode	S. Lindgren	R. W. Stoner
C. Chatterji	D. Lowe	D. Takach ^b
O. O. Chew	J. W. Mathews	J. B. Templeton
D. Chu	J. W. McGill	T. P. Traub
O. Compton	C. J. McMillen	D. E. Truax
J. Cultrera	W. J. McNutt	W. B. Uhl
D. H. Douglas	R. E. Minkwitz, Sr.	R. A. Veitch
D. A. Duckett	C. R. Murray	L. B. Wagenaar
J. Dutton	E. T. Norton	F. N. Weffer
F. Elliott	D. Orten	R. J. Whearty
R. Ensign	B. K. Patel	C. W. Williams, Jr.
D. J. Fallon	P. Payne	H. J. Windisch
D. L. Galloway	D. D. Perco	W. E. Wren ^c
C. Garner	D. W. Platts	

^a1992-1995 Chair term

^b1990-1992 Chair term

^c1985-1990 Chair term

The following persons were on the balloting committee:

Edward J. Adolphson	Dan W. Crofts	Robert L. Grubb
D. J. Allan	John C. Crouse	F. J. Gryszkiewicz
Benjamin E. Allen	V. Dahinden	Geoff H. Hall
Raymond Allustiarti	John N. Davis	Kenneth S. Hanus
Michael S. Altman	R. C. Degeneff	Jim H. Harlow
J. C. Arnold	T. Diamantis	Frank W. Heinrichs
J. Aubin	David H. Douglas	William R. Henning
Thomas R. Balgie	R. F. Dudley	K. R. Highton
Roy A. Bancroft	John A. Ebert	Peter J. Hoefler
Ron L. Barker	K. Edwards	R. H. Hollister
David A. Barnard	Fred E. Elliott	Philip J. Hopkinson
D. L. Basel	D. J. Fallon	J. W. Howard
Wallace B. Binder	Jeffrey A. Fleeman	Edgar Howells
W. E. Boettger	Jerry M. Frank	J. Hunt
J. V. Bonucchi	Maurince Frydman	Y. Peter Iijima
John D. Borst	Dudley L. Galloway	Anthony J. Jonnatti
C. V. Brown	Dennis W. Gerlach	R. D. Jordan
M. Cambre	A. A. Ghafourian	E. Kallaur
D. J. Cash	Donald A. Gillies	C. P. Kappeler
J. L. Corkran	R. S. Girgis	J. J. Kelly

Sheldon P. Kennedy
 William N. Kennedy
 James P. Kinney
 Alexander D. Kline
 J. G. Lackey
 J. P. Lazar
 Frank A. Lewis
 Harold F. Light
 S. R. Lindgren
 Larry Lowdermilk
 Donald L. Lowe
 Richard I. Lowe
 David S. Lyon
 William A. Maguire
 K. T. Massouda
 John W. Matthews
 Jack W. McGill
 Charles J. McMillen
 W. J. McNutt
 Charles P. McShane
 Sam P. Mehta
 C. Kent Miller
 C. H. Millian
 Matthew C. Mingoia
 Russell E. Minkwitz
 Michael I. Mitelman
 Harold R. Moore
 W. E. Morehart

D. H. Mulkey
 C. R. Murray
 R. J. Musil
 William H. Mutschler
 C. G. Niemann
 E. T. Norton
 P. E. Orehek
 S. H. Osborn
 Gerald A. Paiva
 Bipin K. Patel
 Wesley F. Patterson, Jr
 J. M. Patton
 Paulette A. Payne
 Henry A. Pearce
 Dan D. Perco
 Mark D. Perkins
 V. Q. Pham
 Linden W. Pierce
 R. L. Plaster
 Donald W. Platts
 Charles T. Raymond
 Chris A. Robbins
 R. B. Robertson
 J. R. Rossetti
 Mahesh P. Sampat
 L. J. Savio
 William E. Saxon
 Robert W. Scheu

Devki N. Sharma
 V. Shenoy
 H. J. Sire
 Stephen D. Smith
 Leonard R. Smith
 Ronald J. Stahara
 W. W. Stein
 Ron Stoner
 John Sullivan
 David Sundin
 David S. Takach
 Louis A. Tauber
 James Templeton
 V. Thenappan
 Jerry C. Thompson
 R. W. Thompson
 James A. Thompson
 Thomas P. Traub
 David E. Truax
 W. Bruce Uhl
 Georges H. Vaillancourt
 Robert A. Veitch
 Loren B. Wagenaar
 Barry H. Ward
 R. J. Whearty
 D. W. Whitley
 A. L. Wilks
 Charles W. Williams

When the IEEE Standards Board approved this guide on June 14, 1995, it had the following membership:

E. G. “Al” Kiener, *Chair*
Donald C. Loughry, *Vice Chair*
Andrew G. Salem, *Secretary*

Gilles A. Baril
 Clyde R. Camp
 Joseph A. Cannatelli
 Stephen L. Diamond
 Harold E. Epstein
 Donald C. Fleckenstein
 Jay Forster*
 Donald N. Heirman
 Richard J. Holleman

Jim Isaak
 Ben C. Johnson
 Sonny Kasturi
 Lorraine C. Kevra
 Ivor N. Knight
 Joseph L. Koepfinger*
 D. N. “Jim” Logothetis
 L. Bruce McClung
 Marco W. Migliaro

Mary Lou Padgett
 John W. Pope
 Arthur K. Reilly
 Gary S. Robinson
 Ingo Rusch
 Chee Kiow Tan
 Leonard L. Tripp

*Member Emeritus

Also included are the following nonvoting IEEE Standards Board liaisons:

Satish K. Aggarwal

Richard B. Engelman
 Robert E. Hebner

Chester C. Taylor

Rochelle L. Stern
IEEE Standards Project Editor

CLAUSE	PAGE
1. Overview	1
1.1 Scope	1
1.2 Purpose.....	1
2. References	1
3. Definitions.....	2
4. Effect of loading beyond nameplate rating	3
4.1 General	3
4.2 Voltage and frequency considerations	3
4.3 Supplemental cooling of existing self-cooled transformers	4
4.4 Information for user calculations	4
5. Transformer insulation life	5
5.1 General	5
5.2 Aging equations	5
5.3 Percent loss of life.....	9
6. Ambient temperature and its influence on loading	11
6.1 General	11
6.2 Approximating ambient temperature for air-cooled transformers	11
6.3 Approximating ambient temperature for water-cooled transformers	12
6.4 Influence of ambient on loading for normal life expectancy	12
7. Calculation of temperatures	13
7.1 Load cycles	13
7.2 Calculation of temperatures	14
7.3 Computer calculation of loading capability	19
7.4 Bibliography for clause 7	19
8. Loading of distribution transformers	21
8.1 Distribution transformer life expectancy	21
8.2 Limitations	21
8.3 Types of loading.....	22
9. Loading of power transformers	25
9.1 Types of loading and their interrelationship	25
9.2 Limitations	26
9.3 Normal life expectancy loading	27
9.4 Planned loading beyond nameplate rating	29
9.5 Long-time emergency loading	29
9.6 Short-time emergency loading	29
9.7 Loading information for specifications	30
9.8 Operation with part or all of the cooling out of service	30

CLAUSE	PAGE
Annex A (Normative) Thermal evolution of gas from transformer insulation	31
Annex B (Normative) Effect of loading transformers above nameplate rating on bushings, tap changers, and auxiliary components	40
Annex C (Normative) Calculation methods for determining ratings and selecting transformer size	45
Annex D (Normative) Philosophy of guide applicable to transformers with 55 °C average winding rise (65 °C hottest-spot rise) insulation systems	53
Annex E (Normative) Unusual temperature and altitude conditions	55
Annex F (Normative) Cold-load pickup (CLPU)	57
Annex G (Normative) Alternate temperature calculation method	60
Annex H (Normative) Operation with part or all of the cooling out of service	85
Annex I (Informative) Transformer insulation life	89
Annex J (Informative) Hottest-spot temperature indicators and fiber optic detectors	99

IEEE Guide for Loading Mineral-Oil-Immersed Transformers

1. Overview

1.1 Scope

This guide covers general recommendations for loading 65 °C rise mineral-oil-immersed distribution and power transformers described in the standards listed in clause 2

Recommendations for 55 °C rise transformers are included in annex D because a substantial percentage of these transformers are still in service.

1.2 Purpose

Applications of loads in excess of nameplate rating involve some degree of risk. It is the purpose of this guide to identify these risks and to establish limitations and guidelines, the application of which will minimize the risks to an acceptable level. Risk areas are identified in clauses 4 and 9, and in the annexes as noted.

2. References

This guide should be used in conjunction with the following publications. When the following publications are superseded by an approved revision, the revision should apply.

ANSI C57.12.10-1988, American National Standard for Transformers 230 kV and Below, 833/958 through 8333/10 417 kVA Single-Phase, and 750/862 through 60 000/80 000/100 000 kVA Three-Phase, without Load Tap Changing; and 3750/4687 through 60 000/80 000/100 000 kVA with Load Tap Changing-Requirements.¹

ANSI C57.12.20-1988, Requirements for Overhead-Type Distribution Transformers, 500 kVA and Smaller: High Voltage, 34 500 Volts and Below; Low Voltage, 7970/13 800Y and Below.

¹ANSI publications are available from the Sales Department, American National Standards Institute, 11 West 42nd Street, 13th Floor, New York, NY 10036, USA.

ANSI C57.12.21-1980, Requirements for Pad-Mounted, Compartmental-Type, Self-Cooled, Single-Phase Distribution Transformers with High-Voltage Bushings (High-Voltage, 34 500 GrdY/19 920 Volts and Below; Low-Voltage, 240/120 Volts; 167 kVA and Smaller).

ANSI C57.12.22-1989, Pad-Mounted, Compartmental-Type, Self-Cooled, Three-Phase Distribution Transformers with High-Voltage Bushings, 2500 kVA and Smaller: High Voltage, 34 500 GrdY/19 920 Volts and Below; Low Voltage, 480 Volts and Below—Requirements.

ANSI C57.12.25-1990, Requirements for Pad-Mounted, Compartmental-Type, Self-Cooled, Single-Phase Distribution Transformers with Separable Insulated High-Voltage Connectors: High-Voltage, 34 500 GrdY/ 19 920 Volts and Below; Low Voltage 240/120 Volts; 167 kVA and Smaller.

IEEE Std C57.12.00-1993, IEEE Standard General Requirements for Liquid-Immersed Distribution, Power, and Regulating Transformers (ANSI).²

IEEE Std C57.12.26-1992, IEEE Standard for Pad-Mounted, Compartmental-Type, Self-Cooled, Three-Phase Distribution Transformers for Use with Separable Insulated High-Voltage Connectors (34 500 Grd Y/ 19 920 V and Below; 2500 kVA and Smaller) (ANSI).

IEEE Std C57.12.90-1993, IEEE Standard Test Code for Liquid-Immersed Distribution, Power, and Regulating Transformers, and IEEE Guide for Short-Circuit Testing of Distribution and Power Transformers (ANSI).

IEEE Std C57.100-1986, IEEE Standard Test Procedure for Thermal Evaluation of Oil-Immersed Distribution Transformers (ANSI).

3. Definitions

3.1 aging acceleration factor: For a given hottest-spot temperature, the rate at which transformer insulation aging is accelerated compared with the aging rate at a reference hottest-spot temperature. The reference hottest-spot temperature is 110 °C for 65 °C average winding rise and 95 °C for 55 °C average winding rise transformers (without thermally upgraded insulation). For hottest-spot temperatures in excess of the reference hottest-spot temperature the aging acceleration factor is greater than 1. For hottest-spot temperatures lower than the reference hottest-spot temperature, the aging acceleration factor is less than 1.

3.2 directed flow (oil-immersed forced-oil-cooled transformers): Indicates that the principal part of the pumped oil from heat exchangers or radiators is forced to flow through the windings.

3.3 non-directed flow (oil-immersed forced-oil-cooled transformers): Indicates that the pumped oil from heat exchangers or radiators flows freely inside the tank, and is not forced to flow through the windings.

3.4 percent loss of life: The equivalent aging in hours at the reference hottest-spot temperature over a time period (usually 24 h) times 100 divided by the total normal insulation life in hours at the reference hottest-spot temperature. The equivalent aging in hours at different hot-spot temperatures is obtained by multiplying the aging acceleration factors for the hottest-spot temperatures times the time periods of the various hottest-spot temperatures.

3.5 transformer insulation life: For a given temperature of the transformer insulation, the total time between the initial state for which the insulation is considered new and the final state for which dielectric stress, short circuit stress, or mechanical movement, which could occur in normal service, and would cause an electrical failure.

²IEEE publications are available from the Institute of Electrical and Electronics Engineers, 445 Hoes Lane, P.O. Box 1331, Piscataway, NJ 08855-1331, USA.

4. Effect of loading beyond nameplate rating

4.1 General

Applications of loads in excess of nameplate rating involve some degree of risk. While aging and long time mechanical deterioration of winding insulation have been the basis for the loading of transformers for many years, it is recognized that there are additional factors that may involve greater risk for transformers of higher megavoltampere and voltage ratings. The risk areas that should be considered when loading large transformers beyond nameplate rating are listed below. Further discussion regarding these risks is provided in clause 9 or in the annexes, as noted.

- a) Evolution of free gas from insulation of winding and lead conductors (insulated conductors) heated by load and eddy currents (circulating currents between or within insulated conductor strands) may jeopardize dielectric integrity. See annex A for further discussion.
- b) Evolution of free gas from insulation adjacent to metallic structural parts linked by electromagnetic flux produced by winding or lead currents may also reduce dielectric strength.
- c) Loss of life calculations may be made as described in clause 5. If a percent loss of total life calculation is made based on an arbitrary definition of a “normal life” in hours, one should recognize that the calculated results may not be as conservative for transformers rated above 100 MVA as they are for smaller units since the calculation does not consider mechanical wear effects that may increase with megavoltampere rating.
- d) Operation at high temperature will cause reduced mechanical strength of both conductor and structural insulation. These effects are of major concern during periods of transient overcurrent (through-fault) when mechanical forces reach their highest levels.
- e) Thermal expansion of conductors, insulation materials, or structural parts at high temperatures may result in permanent deformations that could contribute to mechanical or dielectric failures.
- f) Pressure build-up in bushings for currents above rating could result in leaking gaskets, loss of oil, and ultimate dielectric failure. See annex B for further discussion.
- g) Increased resistance in the contacts of tap changers can result from a build-up of oil decomposition products in a very localized high temperature region at the contact point when the tap changer is loaded beyond its rating. In the extreme, this could result in a thermal runaway condition with contact arcing and violent gas evolution. See annex B for further discussion.
- h) Auxiliary equipment internal to the transformer such as reactors and current transformers, may also be subject to some of the risk identified above. See annex B for further discussion.
- i) When the temperature of the top oil exceeds 105 °C (65 °C rise over 40 °C ambient according to IEEE Std C57.12.00-1993³), there is a possibility that oil expansion will be greater than the holding capacity of the tank and also result in a pressure that causes the pressure relief device to operate and expel the oil. The loss of oil may also create problems with the oil preservation system or expose electrical parts upon cooling.

4.2 Voltage and frequency considerations

Voltage and frequency influences should be recognized when determining limitations for loading a transformer beyond its nameplate rating. This is true even though in all probability there may be little control of these parameters during a loading beyond nameplate rating event. Subclause 4.1.6 in IEEE Std C57.12.00-1993 defines the capability of a transformer to operate above rated voltage and below rated frequency. The user of this guide should recognize that, during conditions of loading beyond nameplate, the voltage regulation through the transformer may increase significantly (depending on the transformer impedance) due to the increased kilovoltampere loading and possibly dropping power factor.

A conservative guideline to prevent excessive core heating due to increased excitation is to reduce the transformer output volts per hertz limit by 1% for every 1% increase in voltage regulation during the loading beyond nameplate

³Information on references can be found in clause 2.

event. For example, if the voltage regulation at rated conditions is 6% and increases to 9% at some load above nameplate, the output volts per hertz limit might be reduced from 105% to 102%.

4.3 Supplemental cooling of existing self-cooled transformers

The load that can be carried on existing self-cooled transformers can usually be increased by adding auxiliary cooling equipment such as fans, external forced-oil coolers, or water spray equipment. The amount of additional loading varies widely, depending upon the following:

- a) Design characteristics of the transformer
- b) Type of cooling equipment
- c) Permissible increase in voltage regulation
- d) Limitations in associated equipment

No general rules can be given for such supplemental cooling, and each transformer should be considered individually.

The use of water spray equipment for supplemental cooling is not recommended for use in normal loading beyond nameplate rating. Appropriate precautions should be made for application of water spray equipment for supplemental cooling during emergency overloads. The major problem is the build up of scale on the cooling equipment due to minerals in the water. Over the long term this buildup will hinder the cooling efficiency. The spray and steam generated can also cause phase-to-phase flashover between bushings.

4.4 Information for user calculations

If the user intends to perform calculations to determine the loading capability of a transformer using clause 7 or annex G, the user should request the following minimum information in the specification or final test report:

- a) Top-oil temperature rise over ambient temperature at rated load
- b) Bottom-oil temperature rise over ambient temperature at rated load
- c) Average conductor temperature rise over ambient temperature at rated load
- d) Winding hottest-spot temperature rise over ambient temperature at rated load
- e) Load loss at rated load
- f) No-load (core) loss
- g) Total loss at rated load
- h) Confirmation of oil flow design (that is, directed or non-directed)
- i) Weight of core and coil assembly
- j) Weight of tank and fittings

NOTE — For the purpose of transient thermal calculations, the weight of tank and fittings to be used is only those portions that are in contact with heated oil.

- k) Volume of oil in the tank and cooling equipment (excluding LTC compartments, oil expansion tanks, etc.)

For all of the information in a) through g), the conditions under which the measurements were made (load, ambient temperature, tap, etc.) should be stated. If test data from thermally similar units is supplied the data shown on the test report should be corrected (in accordance with IEEE recommended procedures when issued) by the manufacturer using the actual design characteristics (losses, cooling surface, etc.) of the transformer supplied.

More precise calculations of loading capability may be performed if desired using clause 7 or annex G if the following additional information is provided:

- l) Load loss at rated load at rated and tap extremes or all possible tap connection combinations
- m) Winding resistance at tap extremes or all possible tap combinations

More precise calculations of loading capability may be performed if desired using annex G if the following additional information is also provided:

- n) Total stray and eddy loss as a percent of total load loss and estimated stray and eddy loss
- o) Per unit eddy loss at hot spot location
- p) Per unit winding height to hot spot location

The temperature rise test is performed (and calculations of temperature rises made when a test is not performed) on the maximum loss tap position. This data results in conservative predictions of loading capability when the transformer is operated on other than the maximum loss tap. To achieve more accurate predictions of the capability of a transformer based on the actual loading cycle and tap connections, several adjustments may be made of the data presented in the test report before the data is used as input to loading calculations. These adjustments are provided in the following:

- q) Load cycle in kVA on the actual combination of tap connections.
- r) Use the measured or calculated load losses for that tap connection.
- s) Correct the temperature rise test data for the lower losses or different rated current.
- t) Determine if the hottest-spot winding gradient changes with changes in the tap connections.

Calculating the effect of load tap changer operation into the loading predictions is an extremely complicated and controversial subject and the effect may vary with manufacturer. For some designs the effect of load tap changer operation may have a negligible effect on temperature rises of the transformer windings.

5. Transformer insulation life

5.1 General

The subject of loss of transformer insulation life has had a rich but controversial history of development, with distribution and power transformers taking independent research paths (refer to I.1 in annex I). As a result of recent study and testing, the approach to determination of insulation loss of life in this guide has been significantly modified (refer to I.2 in annex I.) Aging or deterioration of insulation is a time function of temperature, moisture content, and oxygen content. With modern oil preservation systems, the moisture and oxygen contributions to insulation deterioration can be minimized, leaving insulation temperature as the controlling parameter. Since, in most apparatus, the temperature distribution is not uniform, that part that is operating at the highest temperature will ordinarily undergo the greatest deterioration. Therefore, in aging studies it is usual to consider the aging effects produced by the highest (hottest-spot) temperature. Because many factors influence the cumulative effect of temperature over time in causing deterioration of transformer insulation, it is not possible to predict with any great degree of accuracy the useful life of the insulation in a transformer, even under constant or closely controlled conditions, much less under widely varying service conditions. Wherever the word “life” is used in this guide, it means calculated insulation life, not actual transformer life.

5.2 Aging equations

Experimental evidence indicates that the relation of insulation deterioration to time and temperature follows an adaptation of the Arrhenius reaction rate theory that has the following form:

$$\text{Per unit life} = A \exp \left[\frac{B}{\Theta_H + 273} \right]$$

where

Θ_H is the winding hottest-spot temperature, °C

A is a constant
 B is a constant

The transformer per unit insulation life curve of figure 1 relates per unit transformer insulation life to winding hottest-spot temperature. This curve should be used for both distribution and power transformers because both are manufactured using the same cellulose conductor insulation. The use of this curve isolates temperature as the principal variable affecting thermal life. It also indicates the degree to which the rate of aging is accelerated beyond normal for temperature above a reference temperature of 110 °C and is reduced below normal for temperature below 110 °C (see discussion in I.2 of annex I). The equation for the curve is as follows:

$$\text{Per unit life} = 9.80 \times 10^{-18} \text{EXP}^{\left[\frac{1500}{\Theta_H + 273} \right]} \quad (1)$$

The per unit transformer insulation life curve (figure 1) can be used in the following two ways. It is the basis for calculation of an aging acceleration factor (F_{AA}) for a given load and temperature or for a varying load and temperature profile over a 24 h period. A curve of F_{AA} vs. hottest-spot temperature for a 65 °C rise insulation system is shown in figure 2 and values are tabulated in table 1. F_{AA} has a value greater than 1 for winding hottest-spot temperatures greater than the reference temperature 110 °C and less than 1 for temperatures below 110 °C. The equation for F_{AA} is as follows:

$$F_{AA} = \text{EXP}^{\left[\frac{1500}{383} - \frac{1500}{\Theta_H + 273} \right]} \quad (2)$$

Equation 2 may be used to calculate equivalent aging of the transformer. The equivalent life (in hours or days) at the reference temperature that will be consumed in a given time period for the given temperature cycle is the following:

$$F_{EQA} = \frac{\sum_{n=1}^N F_{AA,n} \Delta t_n}{\sum_{n=1}^N \Delta t_n} \quad (3)$$

where

F_{EQA} is equivalent aging factor for the total time period
 n is index of the time interval, t
 N is total number of time intervals
 $F_{AA,n}$ is aging acceleration factor for the temperature which exists during the time interval Δt_n .
 Δt_n is time interval, hours

See annex I for example calculations.




Figure 1—Transformer insulation life




Figure 2—Aging acceleration factor (relative to 110 °C)

Table 1—Aging acceleration factor

Temperature °C	Age factor	Temperature °C	Age factor	Temperature °C	Age factor
<37	0.000 0	65	0.005 4	94	0.181 3
37	0.000 1	66	0.006 2	95	0.202 6
38	0.000 1	67	0.007 1	96	0.226 3
39	0.000 1	68	0.008 0	97	0.252 6
40	0.000 2	69	0.009 1	98	0.281 7
41	0.000 2	70	0.010 4	99	0.314 1
42	0.000 2	71	0.011 8	100	0.349 9
43	0.000 2	72	0.013 4	101	0.389 7
44	0.000 3	73	0.015 2	102	0.433 7
45	0.000 3	74	0.017 2	103	0.482 3
46	0.000 4	75	0.019 5	104	0.536 2
47	0.000 4	76	0.022 0	105	0.595 7
48	0.000 5	77	0.024 9	106	0.661 4
49	0.000 6	78	0.028 1	107	0.734 0
50	0.000 7	79	0.031 8	108	0.814 2
51	0.000 8	80	0.0358	109	0.902 6
52	0.000 9	81	0.0404	110	1.000 0
53	0.001 1	82	0.0455	111	1.107 4
54	0.001 2	83	0.0513	112	1.225 6
55	0.001 4	84	0.0577	113	1.355 8
56	0.001 6	85	0.0649	114	1.499 0
57	0.001 9	86	0.0729	115	1.656 5
58	0.002 1	87	0.0819	116	1.829 6
59	0.002 4	88	0.0919	117	2.019 7
60	0.002 8	89	0.1031	118	2.228 5
61	0.003 2	90	0.1156	119	2.457 6
62	0.003 7	91	0.129 5	120	2.708 9
63	0.004 2	92	0.144 9	121	2.984 5
64	0.004 8	93	0.162 2	122	3.286 5

Table 1—Aging acceleration factor (Continued)

Temperature °C	Age factor	Temperature °C	Age factor	Temperature °C	Age factor
123	3.617 2	149	37.321 5	175	293.641 7
124	3.979 3	150	40.591 5	176	316.371 8
125	4.375 6	151	44.131 5	177	340.751 8
126	4.809 1	152	47.961 5	178	366.891 8
127	5.283 0	153	52.101 5	179	394.911 8
128	5.800 9	154	56.581 5	180	424.921 8
129	6.366 5	155	61.421 5	181	457.071 8
130	6.984 2	156	66.651 6	182	491.501 8
131	7.658 2	157	72.301 6	183	528.351 8
132	8.393 5	158	78.391 6	184	567.781 8
133	9.195 2	159	84.971 6	185	609.961 8
134	10.068 9	160	92.061 6	186	655.081 9
135	11.020 8	161	99.711 6	187	703.311 9
136	12.057 3	162	107.961 6	188	754.861 9
137	13.185 6	163	116.841 6	189	809.941 9
138	14.413 1	164	126.411 6	190	868.771 9
139	15.748 1	165	136.721 6	191	931.601 9
140	17.199 4	166	147.811 7	192	998.671 9
141	18.776 5	167	159.751 7	193	1070.251 9
142	20.489 5	168	172.581 7	194	1146.621 9
143	22.349 3	169	186.391 7	195	1228.081 9
144	24.367 9	170	201.231 7	196	1314.942 0
145	26.557 8	171	217.181 7	197	1407.542 0
146	28.931 5	172	234.3017	198	1506.222 0
147	31.511 5	173	252.7017	199	1611.352 0
148	34.301 5	174	272.4517	200	1723.342 0

5.3 Percent loss of life

The insulation per unit life curve (see figure 1) can also be used to calculate percent loss of total life, as has been the practice in earlier editions of the referenced transformer loading guides. To do so, it is necessary to arbitrarily define the normal insulation life at the reference temperature in hours or years. Benchmark values of normal insulation life for a well-dried, oxygen-free system can be selected from table 2. Then the hours of life lost in the total time period is determined by multiplying the equivalent aging determined in equation 4 by the time period (t) in hours. This gives equivalent hours of life at the reference temperature which are consumed in the time period. Percent loss of insulation

life in the time period is equivalent hours life consumed divided by the definition of total normal insulation life (hours) and multiplied by 100. Usually the total time period used is 24 h. The equation is given as follows:

$$\% \text{ Loss of life} = \frac{F_{EQA} \times t \times 100}{\text{Normal insulation life}} \quad (4)$$

Table 2—Normal insulation life of a well-dried, oxygen-free 65 °C average winding temperature rise insulation system at the reference temperature of 110 °C

Basis	Normal insulation life	
	Hours	Years
50% retained tensile strength of insulation (former IEEE Std C57.92-1981 criterion)	65 000	7.42
25% retained tensile strength of insulation	135 000	15.41
200 retained degree of polymerization in insulation	150 000	17.12
Interpretation of distribution Transformer functional life test data (former IEEE Std C57.91-1981 criterion)	180 000	20.55
NOTES: 1 — Tensile strength or degree of polymerization (D.P.) retention values were determined by sealed tube aging on well-dried insulation samples in oxygen-free oil. 2 — Refer to I.2 in annex I for discussion of the effect of higher values of water and oxygen and also for the discussion on the basis given above.		

Possible definitions of normal life at 110°C from table 2 are the following:

Normal life	
Hours	Days
180 000	7500
150 000	6250
135 000	5625
65 000	2708

The time duration for continuous operation at hottest-spot temperatures above rated that give different percent loss of life may be calculated using equation 4. Table 3 gives time durations for various loss of life based on a normal life of 180 000 h. Normal percent loss of life for operation at a rated hottest-spot temperature of 110°C for 24 h is 0.0133%.

Table 3—Time durations in hours for continuous operation above rated hottest-spot temperature for different loss of life values

Hot spot temp °C	F _{AA}	Percent loss of life*						
		0.0133 [†]	0.02	0.05	1	2	3	4
110	1.00	24	—	—	—	—	—	—
120	2.71	8.86	13.3	—	—	—	—	—
130	6.98	3.44	5.1	12.9	—	—	—	—
140	17.2	1.39	2.1	5.2	10.5	20.9	—	—
150	40.6	0.59	0.89	2.2	4.4	8.8	13.3	17.7
160	92.1	0.26	0.39	0.98	1.96	3.9	5.9	7.8
170	201.2	0.12	0.18	0.45	0.89	1.8	2.7	3.6
180	424.9	0.06	0.08	0.21	0.42	0.84	1.27	1.7
190	868.8	0.028	0.04	0.10	0.21	0.41	0.83	1.66
200	1723	0.014	0.02	0.05	0.10	0.21	0.31	0.42

*Based on a normal life of 180 000 h. Time durations not shown are in excess of 24 h.

[†]This column of time durations for 0.0133% loss of life gives the hours of continuous operation above the basis-of-rating hottest-spot temperature (110°C) for one equivalent day of operation at 110°C.

6. Ambient temperature and its influence on loading

6.1 General

Ambient temperature is an important factor in determining the load capability of a transformer since the temperature rises for any load must be added to the ambient to determine operating temperatures. Transformer ratings are based on a 24 h average ambient of 30°C. This is the standard ambient used in this guide. Whenever the actual ambient can be measured, such ambients should be averaged over 24 h, and then used in determining the transformer's temperature and loading capability. The ambient air temperature seen by a transformer is the air in contact with its radiators or heat exchangers. In some installations the transformer may be outdoors but surrounded by buildings or sound deadening walls. This may result in recirculation of air, and the ambient should be adjusted accordingly.

6.2 Approximating ambient temperature for air-cooled transformers

It is often necessary to predict the load that a transformer can safely carry at some future time in an unknown ambient. The probable ambient temperature for any month may be approximated from data in reports prepared by the national or local atmospheric authority for the sections of the country where the transformer is located.

- Average temperature.* Use average daily temperature for the month involved, averaged over several years.
- Maximum daily temperature.* Use average of the maximum daily temperatures for month involved averaged over several years.

These ambients should be used as follows:

- For loads with normal life expectancy, use a), the average temperature as the ambient for the month involved.
- For short-time loads with moderate sacrifice of life expectancy, use b), the maximum daily temperature for the month involved.

During any one day the 24 h average of temperature may exceed the value derived from a) or b) above. To be conservative it is recommended that these temperatures be increased by 5°C since aging at higher than average temperature is not fully compensated by decreased aging at lower than average temperature. With this margin the approximated 24 h average temperature will not be exceeded on more than a few days per month and, where it is exceeded, the additional loss of life will not be serious.

6.3 Approximating ambient temperature for water-cooled transformers

The ambient temperature to be used for water-cooled transformers is the cooling water temperature plus an added 5°C to allow for possible loss of cooling efficiency due to deposits on cooling coil surfaces of water-cooled transformers in service.

6.4 Influence of ambient on loading for normal life expectancy

Average ambient temperatures should cover 24 h time periods. The associated maximum temperatures should not be more than 10°C above the average temperatures for air-cooled, and 5°C for water-cooled transformers. Since ambient temperature is an important factor in determining the load capability of a transformer, it should be controlled for indoor installations by adequate ventilation and should always be considered in outdoor installations.

Table 4 gives the increase or decrease from rated kVA for other than average daily ambients of 30°C for air and 25°C for water. It is recommended that a 5°C margin be used when applying the factors from table 4. It should be pointed out that the increase or decrease obtained from table 4 is conservative, and therefore do not check exactly with calculations using the equations in clause 7. Table 4 is for quick approximations, only. Loading on the basis of ambient temperature with loads permitted in table 4 will give approximately the same life expectancy as if transformers were operated at nameplate rating and standard ambient temperatures over the same period. Table 4 covers a range in average ambient temperatures of –30°C to 50°C for cooling air. A check should be made with the manufacturer before loading on the basis of ambient air less than –30°C or greater than 50°C.

**Table 4—Loading on basis of temperatures
(average ambient other than 30°C and average winding rise less than limiting values)
(for quick approximation)
(ambient temperature range –30°C to 50°C)**

Type of cooling *	% of KVA rating	
	Decrease load for each°C higher temperature	Increase load for each°C lower temperature
Self-cooled—OA	1.5	1.0
Water-cooled—OW	1.5	1.0
Forced-air-cooled—OA/FA, OA/FA/FA	1.0	0.75
Forced-oil, -air, -water-cooled —FOA, FOW, and OA/FOA/FOA	1.0	0.75

*See 5.1 in IEEE Std C57.12.00-1995.

7. Calculation of temperatures

7.1 Load cycles

7.1.1 Load cycles, general

Transformers usually operate on a load cycle which repeats every 24 h. A typical normal load cycle such as shown in figure C.1 of annex C, consists of load fluctuations throughout the day. For normal loading or planned overloading above nameplate, a multi-step load cycle calculation method is usually used. The 24 h load profile is described by a series of constant loads of a short duration (usually 1/2 h or 1 h). The equivalent load during the short time steps may be determined by the method of 7.1.2 or by using the maximum peak load during the short-time period under consideration. This method is usually used in computer programs.

An equivalent two step overload cycle as shown in figure 3 may be used for determining emergency overload capability using the equations 5 through 22. The equivalent two-step load cycle consists of a prior load and a peak load. This figure is also used for the purpose of describing calculations to determine equivalent load cycles. There is usually one period in the daily load cycle when the load builds up to a considerably greater value than any reached at other times, such as shown by the solid line in the overload cycle in figure 3. Generally, the maximum value or peak load is not reached and passed suddenly, but builds up and falls off gradually. Calculations using the multi-step load cycle described in the above paragraph may also be performed for emergency overload cycles if desired.

7.1.2 Method of converting actual to equivalent load cycle

A transformer supplying a fluctuating load generates a fluctuating loss, the effect of which is about the same as that of an intermediate constant load for the same period of time. This is due to the heat storage characteristics of the materials in the transformer. A constant load that generates total losses the same as a fluctuating load is assumed an equivalent load from a temperature standpoint. Equivalent load for any part of a daily load cycle may be expressed by equation 5.

$$\left[\frac{L_1^2 t_1 + L_2^2 t_2 + L_3^2 t_3 + \dots + L_N^2 t_N}{t_1 + t_2 + t_3 + \dots + t_N} \right]^{0.5} \quad (5)$$

where

L_1, L_2, \dots is various load steps in %, per unit, or in actual kVA or current

N is the total number of loads considered

t_1, t_2, \dots is the respective durations of these loads, hours




Figure 3—Example of actual load cycle and equivalent load cycle

7.1.3 Equivalent peak load

Equivalent peak load for the usual load cycle is the rms load obtained by equation 5 for the limited period over which the major part of the actual irregular peak seems to exist. The estimated duration of the peak has considerable influence over the rms peak value. If the duration is over-estimated, the rms peak value may be considerably below the maximum peak demand. To guard against overheating due to high, brief overloads during the peak overload, the rms value for the peak load period should not be less than 90% of the integrated 1/2 h maximum demand.

7.1.4 Equivalent continuous prior load

The equivalent continuous prior load is the rms load obtained by equation 5 over a chosen period of the day. Experience indicates that quite satisfactory results are obtained by considering the 12 h periods preceding and following the peak and by selecting the larger of the two rms values so produced. Time intervals (t) of 1 h are suggested as a further simplification of the equation, which for a 12 h period becomes equation 6. The dashed line in figure 3 shows the equivalent load cycle constructed from the actual load cycle.

$$\text{Equivalent continuous 12 h prior load} = 0.29[L_1^2 + L_2^2 + \dots L_{12}^2]^{0.5} \quad (6)$$

7.2 Calculation of temperatures

7.2.1 General

The method given here for calculation of oil and winding temperatures for changes in load is simplified and requires no iterative procedures. The exponents m and n approximately account for changes in load loss and oil viscosity caused by changes in temperature. Values for the exponents used in these equations are shown in table 5. Exact values of the exponents for specific transformers may be determined by overload test procedures in IEEE PC57.119 (see [G6]).

An alternate method, which requires computer calculation procedures, is given in annex G. This method is more exact in accounting for changes in load loss and oil viscosity caused by changes in resistance and oil temperature, respectively. The effect of a variable ambient temperature is also considered. This method should produce a greater accuracy in loading capability if accurate methods of determining load, ambient temperature, tap position, and the cooling mode in operation are utilized.

7.2.2 List of symbols

Temperatures are indicated by Θ and temperature rises by $\Delta\Theta$. Winding hot-spot rises are over top oil unless otherwise specified. Top-oil rises are over ambient.

C	is the thermal capacity of the transformer, Watt-hours/ $^{\circ}\text{C}$
EXP	is 2.71828 (base of natural logarithm)
I_R	is rated current
K	is the ratio of load L to rated load, per unit
L	is the load under consideration, kilovoltamperes or amperes
m	is an empirically derived exponent used to calculate the variation of $\Delta\Theta_H$ with changes in load. The value of m has been selected for each mode of cooling to approximately account for effects of changes in resistance and oil viscosity with changes in load.
n	is an empirically derived exponent used to calculate the variation of $\Delta\Theta_{TO}$ with changes in load. The value of n has been selected for each mode of cooling to approximately account for effects of change in resistance with change in load.
$P_{T,R}$	is the total loss at rated load, watts
R	is the ratio of load loss at rated load to no-load loss on the tap position to be studied

t	is the duration of load, hours
Θ	is temperature, °C
Θ_A	is the average ambient temperature during the load cycle to be studied, °C
$\Theta_{A,R}$	is the average ambient temperature at rated load, °C
Θ_H	is the winding hottest-spot temperature, °C
$\Theta_{H,R}$	is the winding hottest-spot temperature at rated load on the tap position to be studied, °C
$\Theta_{H,U}$	is the ultimate winding hottest-spot temperature for load L, °C
Θ_{TO}	is the top-oil temperature, °C
$\Delta\Theta_H$	is the winding hottest-spot rise over top-oil temperature. °C
$\Delta\Theta_{H,i}$	is the initial winding hottest-spot rise over top-oil temperature for $t = 0$, °C
$\Delta\Theta_{H,R}$	is the winding hottest-spot rise over top-oil temperature at rated load on the tap position to be studied, °C.
$\Delta\Theta_{H,U}$	is the ultimate winding hottest-spot rise over top-oil temperature for load L, °C
$\Delta\Theta_{H/A,R}$	is the winding hot spot rise over ambient at rated load on the tap position to be studied, °C
$\Delta\Theta_{TO}$	is the top-oil rise over ambient temperature, °C
$\Delta\Theta_{TO,R}$	is the top-oil rise over ambient temperature at rated load on the tap position to be studied, °C
$\Delta\Theta_{TO,i}$	is the initial top-oil rise over ambient temperature for $t = 0$, °C
$\Delta\Theta_{TO,U}$	is the ultimate top-oil rise over ambient temperature for load L, °C
τ_{TO}	is the oil time constant of transformer for any load L and for any specific temperature differential between the ultimate top-oil rise and the initial top-oil rise
$\tau_{TO,R}$	is the time constant for rated load beginning with initial top-oil temperature rise of 0 °C, hours
τ_W	is the winding time constant at hot spot location, hours

Subscripts:

A	is ambient
R	is rated
U	is ultimate
i	initial
H	is winding hottest-spot
TO	is top oil
W	is winding
I	is over

Superscript: (') indicates adjustment of test report data to a different tap position.

7.2.3 Components of temperature

The hottest-spot temperature is assumed to consist of three components given by the following equation:

$$\Theta_H = \Theta_A + \Delta\Theta_{TO} + \Delta\Theta_H \quad (7)$$

The top-oil temperature is given by the following equation:

$$\Theta_{TO} = \Theta_A + \Delta\Theta_{TO} \quad (8)$$

The temperature calculations assume a constant ambient temperature. The effect of a variable ambient may be conservatively considered as follows:

- For ambient temperatures that increase during the load cycle, the instantaneous ambient should be used when considering load cycles.
- For decreasing ambient temperatures, the maximum ambient during a long prior cycle of about 12 h should be used.

7.2.4 Top-oil rise over ambient

The top-oil temperature rise at a time after a step load change is given by the following exponential expression containing an oil time constant:

$$\Delta\Theta_{TO} = (\Delta\Theta_{TO,U} - \Delta\Theta_{TO,i}) \left(1 - \exp^{-\frac{t}{\tau_{TO}}} \right) + \Delta\Theta_{TO,i} \quad (9)$$

For the two-step overload cycle with a constant equivalent prior load the initial top-oil rise is given by the following:

$$\Delta\Theta_{TO,i} = \Delta\Theta_{TO,R} \left[\frac{(K_i^2 R + 1)}{(R + 1)} \right]^n \quad (10)$$

For the multi-step load cycle analysis with a series of short-time intervals, equation 9 is used for each load step, and the top-oil rise calculated for the end of the previous load step is used as the initial top-oil rise for the next load step calculation.

The ultimate top-oil rise is given by the following equation:

$$\Delta\Theta_{TO,U} = \Delta\Theta_{TO,R} \left[\frac{(K_U^2 R + 1)}{(R + 1)} \right]^n \quad (11)$$

Equation 11 is used to calculate the ultimate oil rise for each load step. Except for very long duration constant loads, the ultimate top-oil rise calculated by equation 11 is never reached.

7.2.5 Oil time constant

The thermal capacity is given by the following equation for the OA and FA cooling modes:

$$\begin{aligned} C = & 0.06(\text{weight of core and coil assembly in pounds}) \\ & + 0.04(\text{weight of tank and fittings in pounds}) \\ & + 1.33(\text{gallons of oil}) \end{aligned} \quad (12A)$$

or

$$\begin{aligned} C = & 0.0272(\text{weight of core and coil assembly in kilograms}) \\ & + 0.01814(\text{weight of tank and fittings in kilograms}) \\ & + 5.034(\text{liters of oil}) \end{aligned} \quad (12B)$$

The derivation of the exponential heating equation is based on the average temperature rise of the lumped mass. In the case of the transformer this would be the average oil temperature. However, the top oil is the variable measured by temperature indicators or thermocouples during thermal tests. In equation 12A for the thermal capacity, two-thirds of the weight of the tank and 86% of the specific heat of the oil was used.

For forced-oil cooling modes either directed or non-directed the thermal capacity is given by the following:

$$\begin{aligned} C = & 0.06(\text{weight of core and coil assembly in pounds}) \\ & + 0.06(\text{weight of tank and fittings in pounds}) \\ & + 1.93(\text{gallons of oil}) \end{aligned} \quad (13A)$$

or

$$\begin{aligned} C = & 0.0272(\text{weight of core and coil assembly in pounds}) \\ & + 0.0272(\text{weight of tank and fittings in kilograms}) \\ & + 7.305(\text{liters of oil}) \end{aligned} \quad (13B)$$

For the calculation of the time constant, the weight of the tank and fittings to be used is only those portions that are in contact with heated oil. Some transformers, may have cabinetry and tank base construction with substantial weight that does not contribute to the thermal mass in determination of the oil rise time constant.

The top-oil time constant at rated kVA is given by the following:

$$\tau_{TO,R} = \frac{C\Delta\Theta_{TO,R}}{P_{T,R}} \quad (14)$$

The top-oil time constant is

$$\tau_{TO} = \tau_{TO,R} \frac{\left(\frac{\Delta\Theta_{TO,U}}{\Delta\Theta_{TO,R}}\right) - \left(\frac{\Delta\Theta_{TO,i}}{\Delta\Theta_{TO,R}}\right)}{\left(\frac{\Delta\Theta_{TO,U}}{\Delta\Theta_{TO,R}}\right)^{\frac{1}{n}} - \left(\frac{\Delta\Theta_{TO,i}}{\Delta\Theta_{TO,R}}\right)^{\frac{1}{n}}} \quad (15)$$

In the derivation of equation 9 it was assumed that the top-oil temperature rise $\Delta\Theta_{TO}$ is directly proportional to the heat loss q , or in equation form,

$$\Delta\Theta_{TO} = kq^n$$

where

$$n \quad \text{is } 1.0$$

If the exponent $n = 1.0$, the time constant given by equation 14 and the exponential equation 9 is correct for any load and any starting temperature. If n is less than 1, the equation is incorrect and the time constant must be modified as shown in equation 15 for different overload cycles. Equation 15 was developed to give a corrected time constant (for case of $n < 1$) to use in the exponential equation that gave the same rate of change of initial temperature rise and the same final temperature rise if the overload continued indefinitely; however, intermediate temperatures may vary somewhat from actual.

If n is equal to 1.0, 63% of the temperature change occurs in a length of time equal to the time constant regardless of the relationship of initial temperature rise and ultimate temperature rise. If n is not unity, the temperature change in a similar time interval will be different, depending on both initial temperature rise and ultimate temperature rise.

7.2.6 Winding hot-spot rise

Transient winding hottest-spot temperature rise over top-oil temperature is given by:

$$\Delta\Theta_H = (\Delta\Theta_{H,U} - \Delta\Theta_{H,i}) \left(1 - \exp^{-\frac{t}{\tau_w}}\right) + \Delta\Theta_{H,i} \quad (16)$$

The initial hot-spot rise over top oil is given by

$$\Delta\Theta_{H,i} = \Delta\Theta_{H,R} K_i^{2m} \quad (17)$$

The ultimate hot-spot rise over top oil is given by

$$\Delta\Theta_{H,U} = \Delta\Theta_{H,R} K_u^{2m} \quad (18)$$

The rated value of hot-spot rise over top oil is given by

$$\Delta\Theta_{H,R} = \Delta\Theta_{H/A,R} - \Delta\Theta_{TO,R} \quad (19)$$

The value of the winding hot-spot rise over ambient $\Delta\Theta_{H/A,R}$ is obtained in the following manner, in order of preference:

- a) By actual test using imbedded detectors
- b) Calculated value supplied by manufacturer on test report, or
- c) Assume $\Delta\Theta_{H/A,R} = 80^\circ\text{C}$ for 65°C average winding rise and 65°C for 55°C average winding rise

The value of the top-oil rise over ambient $\Delta\Theta_{TO,R}$ is determined by

- a) Actual test per IEEE Std C57.12.90-1993, or
- b) Calculated value supplied by the manufacturer on the test report

The winding time constant is the time it takes the winding temperature rise over oil temperature rise to reach 63.2% of the difference between final rise and initial rise during a load change. The winding time constant may be estimated from the resistance cooling curve during thermal tests or calculated by the manufacturer using the mass of the conductor materials. The winding time constant varies with the oil viscosity and the exponent m . For moderate overloads it is conservative to neglect the winding time constant and assume the winding hot-spot rise over top oil is given by equation 18.

7.2.7 Exponents for temperature rise equations

The suggested exponents for use in the temperature rise equations are given in table 5.

Table 5—Exponents used in temperature determination equations

Type of cooling	m	n
OA	0.8	0.8
FA	0.8	0.9
Non-directed FOA or FOW	0.8	0.9
Directed FOA or FOW	1.0	1.0

7.2.8 Adjustment of test data for different tap position

If it is desired to adjust the test report data for operation on a no-load tap position other than that reported on the test report, the following equations may be used. The prime symbol (') indicates values at the different tap position.

Top-oil rise over ambient:

$$\Delta\Theta'_{TO,R} = \Delta\Theta_{TO,R} \left[\frac{P'_{T,R}}{P_{T,R}} \right]^n \quad (20)$$

Hottest-spot rise over top oil:

$$\Delta\Theta'_{H,R} = \Delta\Theta_{H,R} \left[\frac{I'_R}{I_R} \right]^{2m} \quad (21)$$

Time constant at rated load:

$$\tau'_{TO,R} = \frac{C\Delta\Theta'_{TO,R}}{P'_{T,R}} \quad (22)$$

7.3 Computer calculation of loading capability

Due to the wide variations in transformer characteristics typical loading capability tables are not published in this guide. The equations given in clauses 5 and 7 may be used to develop a computer program that calculates the loading capability for a specific transformer design. A suggested flow chart is shown in figure 4. The program should compute and print the maximum peak load that can be impressed on a transformer and meet specified limitations. In addition, the computer program should calculate the top-oil and hottest-spot temperatures as a function of time for a repetitive 24 h load cycle. The total loss of insulation life for a 24 h load cycle should also be calculated.

Input to the program should consist of the following:

- a) Transformer characteristics (loss ratio, top-oil rise, bottom-oil rise, hottest-spot rise, total loss, gallons of oil, weight of tank and fittings (all at rated load))
- b) Ambient temperatures
- c) Initial continuous load
- d) Peak load durations and the specified daily percent loss of life
- e) Repetitive 24 h load cycle if desired

A systematic convergence process may be used to obtain the highest allowable peak load. An initial trial is made with an assumed peak load midway between the minimum continuous load and maximum permitted peak load (300% for distribution transformers, 200% for power transformers). Using this peak load, aging calculations are made at varying time intervals (depending on the time duration of the peak load) during the 24 h, to determine the total daily insulation aging imposed by the load cycle. A comparison is made between the calculated values and the limiting values, (top-oil temperature, hot-spot temperature, or specified percent loss of life). Depending on the results, the peak value is changed and the calculation repeated until the calculated value of the total percent loss of life above normal is within $\pm 4\%$ of the desired value. At this point, the peak load and corresponding values of peak hottest-spot temperature, peak top-oil temperature, total percent loss of life, and the specified percent loss of life are printed out.

7.4 Bibliography for clause 7

[B1] AIEE Transformer Subcommittee, "Guides for Operation of Transformers, Regulators, and Reactors," *AIEE Transactions*, vol. 64, pp. 797–805, disc. p. 957, Nov. 1945.

[B2] Cooney, W. H., "Predetermination of Self-Cooled Oil-Immersed Transformer Temperatures Before Conditions are Constant", *AIEE Transactions*, vol. 44, pp. 611–618, 1925.

[B3] Montsinger, V. M., "Loading Transformers by Temperature," *AIEE Transactions*, vol. 49, pp. 776–792, April 1930.

[B4] Montsinger, V. M. and Ketchum, P.M., "Emergency Overloading of Air Cooled Oil-Immersed Power Transformers," *AIEE Transactions*, vol. 61, pp. 906–916, 993–995, 1942.

[B5] Narbutovskih, P., "Simplified Graphical Method of Computing Thermal Transients," *AIEE Transactions*, vol. 66, pp. 78–83, 1947.

[B6] Vogel, F. J. and Narbutvskih, P., "Hot-Spot Winding Temperatures in Self-Cooled Oil-Insulated Transformers," *AIEE Transactions*, vol. 61, pp. 133–136, disc. pp. 418–422, March 1942.




Figure 4—Logic diagram for computer program

8. Loading of distribution transformers

8.1 Distribution transformer life expectancy

8.1.1 General

Distribution transformer life expectancy at any operating temperature is not accurately known. The information given regarding loss of insulation life at elevated temperatures is considered to be conservative and the best that can be produced from present knowledge of the subject. The effects of temperature on insulation life are being investigated continuously, and new data may affect future revisions of this guide. The word conservative as used above is used in the sense that the expected loss of insulation life for a single overload cycle will not be greater than the amount stated.

Because the cumulative effects of temperature and time in causing deterioration of transformer insulation are not thoroughly established, it is not possible to predict with any great degree of accuracy the length of life of a transformer even under constant or closely controlled conditions, much less under widely varying service conditions. Deterioration of insulation is generally characterized by a reduction in mechanical strength and in dielectric strength, but these characteristics may not necessarily be directly related. In some cases, insulation in a charred condition will have sufficient insulating qualities to withstand normal operating electrical and mechanical stresses. A transformer having insulation in this condition may continue in service for many months or even years, if undisturbed. On the other hand, any unusual movement of the conductors, such as may be caused by expansion of the conductors due to heating resulting from a heavy overload or to large electromagnetic forces resulting from short circuit, may disturb the mechanically weak insulation such that turn-to-turn or layer-to-layer failure will result.

The recommendations of this guide are based upon the life expectancy curve of figure 1, which relates to the insulation system, but does not account for such factors as deterioration of gaskets, rusting of tanks, etc., that are induced by exposure to the elements of the weather in normal operations.

8.1.2 Normal life expectancy

The basic loading of a distribution transformer for normal life expectancy is continuous loading at rated output when operated under usual service conditions as indicated in 4.1 of IEEE Std C57.12.00-1993. It is assumed that operation under these conditions is equivalent to operation in a constant 30°C ambient temperature. The hottest-spot conductor temperature is the principal factor in determining life due to loading. Direct temperature measurement of the hottest-spot may not be practical on commercial designs. The indicated hottest-spot temperatures have therefore been obtained from tests made in the laboratory and mathematical models. The hottest-spot temperature at rated load is the sum of the average winding temperature and a hottest-spot allowance, usually 15°C. Normal life expectancy will result from operating continuously with hottest-spot conductor temperature of 110°C or an equivalent daily transient cycle. For mineral oil-immersed transformers operating continuously under the foregoing conditions this temperature has been limited to a maximum of 110°C. Normal life expectancy of transformer insulation using different criteria is given in table 1. Distribution and power transformer model tests indicate that the normal life expectancy at a continuous hottest-spot temperature of 110°C is 20.55 years.

8.2 Limitations

8.2.1 General

When loading distribution transformers above nameplate rating, other limitations may be encountered. Among these limitations are oil expansion, pressure in sealed units, and the thermal capability of bushings; leads, tap changers, or associated equipment such as cables, reactors, circuit breakers, fuses, disconnecting switches, and current transformers. Any of these items may limit the loading to less than the capability of the winding insulation. Manufacturers should, therefore, be consulted before loading transformers above nameplate rating. Operation at hottest-spot temperatures above 140°C may cause gassing in the solid insulation and the oil. Gassing may produce a

potential risk to the dielectric strength integrity of the transformer and this risk should be considered when the guide is applied.

Distribution transformers are sometimes installed in subsurface manholes and vaults of minimum size with natural ventilation through roof gratings. This type of installation results in a higher ambient temperature than the outdoor air. The amount of increase depends on the design of the manholes and vaults, net opening area of the roof gratings, and the adjacent subsurface structures. Therefore, the increase in effective ambient temperature for expected transformer losses must be determined before loading limitations can be estimated.

The separate heating effects of loading a distribution transformer, and of solar radiation, may each result in an enclosure surface temperature high enough to present a hazard to personnel who might come in contact with the enclosure surface where unlimited access to the transformer exists (such as certain pad-mounted units).

8.2.2 Limitations for loading above nameplate rating

Suggested limits of temperature and load for loading above the nameplate rating are given in table 6.

Table 6—Suggested limits of temperature and load for loading above nameplate distribution transformers with 65°C rise

Top-oil temperature	120°C
Hottest-spot conductor temperature	200°C
Short-time loading (1/2 h or less)	300%

8.3 Types of loading

8.3.1 Loading for normal life expectancy under specific conditions

Distribution transformers may be operated above 110°C average continuous hottest-spot temperature for short periods provided they are operated for much longer periods at temperatures below 110°C. This is due to the fact that thermal aging is a cumulative process. This permits loads above the rating to be safely carried under specified conditions without encroaching upon the normal life expectancy of the transformer. When the ambient temperature is below the 30°C ambient used to establish the transformer's rating, or when the transformer's temperature rises at nameplate rated load, as determined by test, are less than the normal limiting values, some additional load beyond nameplate rating is possible within normal life expectations.

8.3.2 Loading by top-oil temperature

Top-oil temperature alone should not be used as a guide for loading transformers. The hottest-spot winding rise over top-oil temperature at full load should be determined from the factory tests corrected for the actual load carried by using equation 18. This hottest-spot rise over top-oil, subtracted from 110 °C, will give the maximum permissible top-oil temperature for normal life expectancy. It should be recognized that, due to the thermal lag in the oil temperature rise, time is required for a transformer to reach a stable temperature for any change in load. Therefore, higher peak loads may be carried for a short duration. If the transformer characteristics are not accurately known, maximum top-oil temperatures derived from figure 5 may be used as an approximate guide. Figure 5 is based on a difference between hottest-spot temperature and top-oil temperature of 25° at rated load.





Figure 5—Approximate continuous loading for normal life expectancy based on maximum top-oil temperature



Time (h)	0.05	0.10	0.25	%loss of life ^a 0.50	1.00	2.00	4.00
1/2	171	180	193	<u>204</u> ^b			
1	161	171	183	193	<u>204</u> ^b		
2	153	161	174	183	193	<u>204</u> ^b	
4	144	153	164	174	183	193	<u>204</u> ^b
8	136	144	155	164	174	183	193
16	128	136	147	155	164	174	183
24	124	131	142	150	159	168	178

^a Calculated for one occurrence on the assumption that the hottest-spot temperature remains constant for the specified time duration. For loss of life determinations in which the time-temperature response of the transformer is taken into account, refer to clauses 5 and 7.

^b Maximum permissible value is 200 °C; the underlined values permit interpolation.

Figure 6—Loss of life expectancy (based on a normal life of 180 000 h)

8.3.3 Continuous loading based on average winding test temperature rise

For each degree Celsius in excess of 5°C that the average winding test temperature rise is below 65 °C, the transformer load may be increased above rated kVA by 1.0%. The 5°C margin is taken to provide a tolerance in the measurement of temperature rise. The load value thus obtained is the kVA load, which the transformer can carry at 65°C rise. Since this may indicate a load capability beyond that contemplated by the designer, the limitations given in 8.2 should be checked before taking full advantage of this increase.

The above is not applicable to all distribution transformers. Some transformers are designed to have the difference between the hottest-spot and average winding temperatures greater than the 15°C allowance. This will result in an average winding temperature rise of less than 65 °C, while the hottest-spot winding rise may be at the 80°C limiting value. This condition may exist in transformers with large differences between top and bottom-oil temperatures. The manufacturer should be consulted for information on the hottest-spot allowance used for these designs.

8.3.4 Short-time loading with moderate sacrifice of life expectancy (operation above 110°C hottest-spot temperature)

When for any given period of time the aging effect of one overload cycle or the cumulative aging effect of a number of overload cycles is greater than the aging effect of continuous operation at rated load, the insulation deteriorates at a faster rate than normal. The rate of deterioration is a function of time and temperature and is commonly expressed as a percentage loss of life per incident. A chart and table showing relative loss of life for various combinations of time and temperature are given in figure 6 for 65°C rise transformers.

It should be clearly understood that, while the insulation aging rate information is considered to be conservative and helpful in estimating the relative loss of life due to loads above nameplate rating under various conditions, this information is not intended to furnish the sole basis for calculating the normal life expectancy of transformer insulation. The uncertainty of service conditions and the wide range in ratings covered should be considered in determining a loading schedule. Some of the variables are wide differences in ambient temperature between localities; differences in elevation; restricted air circulation caused by buildings, fire walls, etc.; previous emergency loading history that may not be known to the operator; and variations in design characteristics. As a guide, many users consider an average loss of life of 4% per day in any one emergency operation to be reasonable.

9. Loading of power transformers

9.1 Types of loading and their interrelationship

Power transformer life expectancy at various operating temperatures is not accurately known, but the information given regarding loss of insulation life at elevated temperature is the best that can be produced from present knowledge of the subject. Loads in excess of nameplate rating may subject insulation to temperatures higher than the basis of rating definition. To provide guidance on risk associated with higher operating temperature, four different loading conditions beyond nameplate have been defined. An increased risk is probable for each successive loading with its attendant increased temperature. For each higher temperature, a higher risk loading condition can be assumed to be additive to any lower risk condition accepted by the user except for the short-time emergency loading. The four types of loading are as follows:

Normal life expectancy

- a) Normal life expectancy loading

Sacrifice of life expectancy

- b) Planned loading beyond nameplate
- c) Long time emergency loading
- d) Short time emergency loading

Examples of loads that fall in these categories are illustrated in figure 7.

9.2 Limitations

9.2.1 Temperature and load limitations

Suggested limits of temperatures and loads for loading above nameplate rating are given in table 7. Suggested limits of temperature which give reasonable loss of life for the four types of loading are given in table 8.

Table 7—Suggested limits of temperature and load for loading above nameplate power transformers with 65°C rise

Top-oil temperature	110°C
Hottest-spot conductor temperature	180°C
Maximum loading	200%

Table 8—Suggested maximum temperature limits for the four types of loading

	Normal life expectancy loading	Planned loading beyond nameplate rating	Long-time emergency loading	Short-time emergency loading
Insulated conductor hottest-spot temperature, °C	120*	130	140	180 [†]
Other metallic hot-spot temperature (in contact and not in contact with insulation), °C	140	150	160	200
Top-oil temperature, °C	105	110	110	110

*100°C on a continuous 24 h basis

[†]Gassing may produce a potential risk to the dielectric strength of the transformer. This risk should be considered when this guide is applied refer to annex A.

Usually the limits of hot-spot temperature for other metallic parts not in contact with insulation are design limits and calculated by the manufacturer when an overload specification is submitted as part of the purchasing specifications.

9.2.2 Ancillary components

Tap changers bushings, leads, and other ancillary equipment may restrict loading to levels below those calculated by the equations in clause 7 or annex G. The user may wish to specify that ancillary equipment not restrict loading to levels below those permitted by the insulated conductor and other metallic part hot spots. Additional information on loading of ancillary components is given in annex B.

9.2.3 Risk considerations

Normal life expectancy loading is considered to be risk free; however, the remaining three types of loading have associated with them some indeterminate level of risk. Specifically, the level of risk is based on the quantity of free gas,

moisture content of oil and insulation, and voltage. The presence of free gas as discussed in annex A may cause dielectric failure during an overvoltage condition and possibly at rated power frequency voltage. The temperatures shown in table 8 for each type of loading are believed to result in an acceptable degree of risk for the special circumstances that require loading beyond nameplate rating. A scientific basis for the user's evaluation of the degree of risk is not available at this time. Current research in the area of model testing has not established sufficient quantitative data relationships between conductor temperature, length of time at that temperature, and reduction in winding dielectric strength. Additionally, there are other important factors that may affect any reduction, such as moisture content of the winding insulation and rate of rise of conductor temperature.

9.3 Normal life expectancy loading

9.3.1 General

The basic loading of a power transformer for normal life expectancy is continuous loading at rated output when operated under usual conditions as indicated in 4.1 of IEEE Std C57.12.00-1993. It is assumed that the operation under these conditions is equivalent to operation in an average ambient temperature of 30°C for cooling air or 25°C for cooling water. Normal life expectancy will result from operating with a continuous hottest-spot conductor temperature of 110°C (or equivalent variable temperature with 120°C maximum in any 24 h period). The 110°C hottest-spot temperature is based on the hottest-spot rise of 80°C plus the standard average ambient temperature of 30 °C.

Transformers may be operated above 110°C hottest-spot temperature for short periods providing they are operated for much longer periods at temperatures below 110 °C. This is due to the fact that thermal aging is a cumulative process and thus permits loads above the rating to be safely carried under many conditions without encroaching upon the normal life expectancy of the transformer. The equations given in clause 7 or annex G may be used to calculate the hottest-spot and top-oil temperatures as a function of load for normal life expectancy.

9.3.2 Influence of ambient on normal life expectancy loading





The influence of ambient on normal life expectancy loading is given in clause 6.

9.3.3 Normal life expectancy loading by top-oil temperature

Top-oil temperature alone should not be used as a guide for loading power transformers. The hottest-spot to top-oil gradient at full load should be determined from factory tests or, lacking data a value should be assumed. The full load hottest-spot to top-oil gradient should be corrected to that for actual load using equation 18. The gradient subtracted from 110°C will give the maximum permissible oil temperature for normal life expectancy. It should be recognized that, due to thermal lag in oil rise, time is required for a transformer to reach a stable temperature following any change in load.

9.3.4 Normal life expectancy loading by average winding test temperature rise

For each 1°C in excess of 5°C that the average winding test temperature is below 65 °C, the transformer load may be increased above rated load by the percentages given in table 4. A 5°C margin is used to provide a tolerance in the measurement of temperature rise. The load thus obtained is that which the transformer can carry at 65°C rise. Since this may increase the loading beyond that contemplated by the designer, the limitations given in tables 7 and 8 should be checked before taking full advantage of this increased load capability.

**a) Normal life expectancy loading****b) Planned loading beyond nameplate rating****c) Long-time emergency loading****d) Short-term emergency loading****Figure 7—Types of loading**

Some power transformers are designed to have the difference between the hottest-spot and average conductor temperature greater than 15°C. This will result in an average winding temperature rise less than 65°C, but the hottest-spot winding temperature rise may be the limiting value of 80°C. Such transformers should not be loaded above their rating by using table 2. The manufacturer should be consulted for information on the hottest-spot allowances used for these designs. This condition may exist in transformers with large differences (greater than 30°C) between top and bottom oil temperatures and may be checked approximately by measuring the top and bottom radiator temperatures. Whenever possible, data on hottest-spot and oil temperatures obtained from factory temperature tests should be used in calculating transformer load capability or when calculating temperatures for loads above rating.

9.4 Planned loading beyond nameplate rating

Planned loading beyond nameplate rating results in either the conductor hottest-spot or top-oil temperature exceeding those suggested in table 8 for normal life expectancy loading, and is accepted by the user as a normal, planned repetitive load. Usually planned loading beyond nameplate rating is restricted to transformers that do not carry a continuous steady load. Suggested conductor hottest-spot temperatures are presented in table 8. Planned loading beyond nameplate rating defines a condition wherein a transformer is so loaded that its hottest-spot temperature is in the temperature range of 120°C–130°C. The length of time for a transformer to operate in the 120 °C–130 °C range should be determined by loss of insulation life calculations, taking into account the specific load cycle. The characteristics of this type of loading are no system outages, regular and comparatively frequent occurrences and life expectancy is less than for loading within the nameplate rating.

9.5 Long-time emergency loading

Long-time emergency loading results from the prolonged outage of some system element and causes either the conductor hottest-spot or the top-oil temperature to exceed those suggested for planned loading beyond nameplate rating. This is not a normal operating condition, but may persist for some time. It is expected that such occurrences will be rare. Long-time emergency loading may be applied to transformers carrying continuous steady loads, but loss of insulation life must be determined to be acceptable. Suggested conductor hottest-spot temperatures are presented in table 8. Top-oil temperature should not exceed 110°C at any time.

Long-time emergency loading defines a condition wherein a power transformer is so loaded that its hottest-spot temperature is in the temperature range of 120°C–140°C. The characteristics of this type of loading are one long-time outage of a transmission system element, two or three occurrences over the normal life-time of the transformer each occurrence may last several months, and the risk is greater than planned loading beyond nameplate rating. Figure 7c) illustrates an example of a long-time emergency loading profile. The hottest-spot temperature for this example exceeds 120 °C. Calculations should be made to determine if the loss of insulation life is acceptable for the specific load cycle.

9.6 Short-time emergency loading

Short-time emergency loading is an unusually heavy loading brought about by the occurrence of one or more unlikely events that seriously disturb normal system loading and cause either the conductor hottest-spot or top-oil temperature to exceed the temperature limits suggested for planned loading beyond name-plate rating. Acceptance of these conditions for a short time may be preferable to other alternatives. Suggested conductor hottest-spot temperatures are presented in table 8. Top-oil temperature should not exceed 110°C at any time. This type of loading, with its greater risk, is expected to occur rarely.

Short-time emergency loading defines a loading condition wherein a transformer is so loaded that its hottest-spot temperature is as high as 180 °C for a short time. The characteristics of this type of loading are a series of unlikely conditions on the transmission system (second or third contingency), one or two occurrences over the normal lifetime of the transformer, and the risk is greater than for long-time emergency loading. Calculations should be made to determine if the loss of insulation life during the short-time emergency is acceptable for the specific load cycle. Figure 7d) illustrates an example of a short-time emergency loading profile. This figure presents a temperature curve that had

leveled off for the day until about 4 p.m. when a system condition occurs which loads the transformer so that its hottest-spot temperature rises rapidly to 163 °C in 1 h.

9.7 Loading information for specifications

If the maximum load capacity that a transformer user plans to utilize on a planned or emergency basis is included in the specifications at the time of purchase, the following information should be given:

- a) Load
 - 1) Two step load cycle approach
 - Prior steady-state load, percent of maximum nameplate rating
 - Maximum load, percent of maximum nameplate rating
 - Duration
 - 2) Load cycle over a 24 h period
- b) Ambient temperature, °C
 - 1) Constant for load cycle approach [see item a)1)]
 - 2) Variable over the load cycle for load cycle approach [see item a)2)]
- c) Type of loading, planned or emergency, long-time or short-time
- d) Limiting top-oil temperature
- e) Limiting hottest-spot temperature
- f) Statement that ancillary components not limit the loading capability

More than one set of loading conditions may be defined. The load cycle with limiting top-oil and hottest-spot temperatures determine loss of life, which may be calculated.

9.8 Operation with part or all of the cooling out of service

When auxiliary equipment, such as pumps or fans, or both, is used to increase the cooling efficiency, the transformer may be required to operate for some time without this equipment functioning. The permissible loading under such conditions is given in annex H.

Annex A Thermal evolution of gas from transformer insulation

(Normative)

A.1 General

In order for a bubble to form and grow within a liquid, the gas within the bubble must develop an internal pressure sufficient to overcome the forces constraining it, namely, the interfacial tension force of the liquid, the gravitational force resulting from the column of liquid above the bubble, and the force from whatever atmospheric pressure is acting on the surface of the liquid. Considering the formation of a bubble within the mineral oil of a transformer, only the last two forces merit practical consideration. The source of the gas pressure within the liquid, which tends to form a potential bubble, is the summation of partial pressures exerted by various individual gases dissolved in the liquid. If there is a gas space over the free surface of the liquid, the partial pressures of the dissolved gases within the liquid is in balance with the partial pressures of the same gases in the gas space under equilibrium conditions.

The principal gases found dissolved within the mineral oil of a transformer are the following:

- Nitrogen: From the external atmosphere or from a gas blanket over the free surface of the oil
- Oxygen: From the external atmosphere
- Water: From moisture absorbed in cellulose insulation or from thermal decomposition of the cellulose
- Carbon dioxide: From thermal decomposition of cellulose insulation
- Carbon monoxide: From thermal decomposition of cellulose insulation

Other gases may be present in very small amounts as a result of oil or insulation decomposition by overheated metal, partial discharges, or arcing and sparking, but these normally make an insignificant contribution to the summation of gas partial pressures within the oil.

References [A5] and [A18]⁴ describe a mathematical modelling technique by which it is possible to make a quantitative analysis of the tendency for bubble formation in an operating transformer. The mathematical model is oriented around a physical model of the hottest-spot conductor within the transformer. That physical model is shown in figure A.1. The analysis centers around the gas pressure generated in the “local oil,” which impregnates the innermost wrap of paper insulation at the conductor surface. Because the local oil is in intimate contact with the conductor, it is realistic to assume that the oil temperature closely tracks the conductor temperature. Also, as a result of the additional external wraps of paper, it is realistic to assume that the local oil and the paper wrap that it impregnates constitute a small isolated system whose total gas content must remain essentially constant during a thermal transient lasting for no more than a few hours (except for the possible formation of additional thermal decomposition gases from the heated cellulose). One final assumption is that the paper insulation of the inner wrap serves as an infinite water reservoir for the local oil, since the moisture holding capability of the cellulose is at least two orders of magnitude greater than the impregnating oil. The consequence of this last assumption is that the partial pressure of water in the local oil is always determined by the moisture content of the inner paper wrap.

Water vapor pressure equilibrium data for paper insulation and mineral oil are available in the published literature, although the paper from which the data was derived was not thermally upgraded, and the full range of operating temperatures into the overload region was not explored. The characteristic used in 18 is reproduced in figure A.2, showing extrapolation of the data to 180 °C. This graph makes it possible to relate the partial pressure of water vapor in the local oil to the moisture content of the inner wrap of conductor insulation.

⁴The numbers in brackets correspond to bibliographic items.




Figure A.1—Insulated winding conductor subsystem within a transformer

Other gases of interest will have concentrations in the bulk oil during normal operating conditions, which will come into equilibrium with the concentrations in the local oil over a period of time. During the thermal excursion of an overload event, these concentrations cannot change appreciably, but the resultant partial pressures generated by the gases will change with temperature. The fashion in which the gas concentration in the oil and its partial pressure is related is described by Henry's Law, which can be written mathematically as follows:

$$c_i = k_i \times p_i \quad (\text{A-1})$$

where

- c_i is the concentration of a single gas, i (in ppm by volume)
- P_i is the partial pressure of gas i (in atmospheres)
- k_i is the Henry's Law constant for gas i

Henry's Law constants are a function of temperature, as shown in figure A.3 from 5.

The fashion in which the model may be applied can be illustrated by a simple example. Assume a transformer with a gas blanket oil preservation system that limits the maximum gas pressure to 1.5 atmospheres. The transformer is operating at full load with a hottest-spot conductor temperature of 100 °C under steady-state conditions. The inner wrap of insulation on the hottest-spot conductor is assumed to have a moisture content of 0.5% by weight and the location of the hottest-spot is assumed near the oil surface, so that the pressure from a static head of oil over the bubble formation site may be neglected. Under these conditions, the partial pressure of water vapor in the local oil is 15 mm Hg (from figure A.2, 0.5% moisture and 100 °C). The summation of the partial pressures of the component gases should balance the gas blanket maximum pressure of 1140 mm Hg (1.5 atmospheres) so that the partial pressure of nitrogen is 1125 mm Hg. Next, assume that an overload occurs so that the hottest-spot temperature rises, ultimately reaching a value of 150 °C. At 150 °C, considerably more moisture moves from the paper into the local oil so that the partial pressure of water vapor becomes 180 mm Hg (from figure A.2, 0.5% moisture and 150 °C). The concentration of nitrogen in the local oil cannot change because gas would have to diffuse through the overwraps of conductor insulation, but the partial pressure will change. Calculation of the concentration of nitrogen from 1125 mm Hg at 100 °C using figure A.3 enables translation to a partial pressure of 1036 mm Hg at 150 °C.




Figure A.2—Equilibrium chart relating water vapor pressure over oil to water concentration in kraft paper vs. temperature

The new summation of partial pressures of gases at 150 °C becomes $180 + 1036 = 1216$ mm Hg, which exceeds the constraining pressure of 1140 mm Hg from the gas blanket. This is a favorable condition for the formation of free gas bubbles in the local oil at the conductor surface. In figure A.4, the results of calculation of summations of partial pressures at 10 °C increments of temperature are shown, indicating that bubbles may be formed at temperatures of

140 °C and above. This example calculation is closely related to physical experiments in which free gas bubbles were observed at temperatures of 140 °C and above.





Figure A.3—Henry's Law constants (ppm vol/atm) for common gases in mineral oil

More recent experimental results 24 indicate the concentration of nitrogen in the local oil has significantly less effect on the formation of bubbles than indicated by Henry's Law described here.

At temperatures of 150 °C and above, it is also necessary to consider the additional quantity of gas that will be formed from the thermal decomposition of cellulose. References 18 and 5 provide information on the rates of formation of these gases and a means of including them in the calculations.


The mathematical model may be exercised for a variety of possible operating conditions in transformers to derive some general understanding of the interaction of the various parameters. Figures A.5 and A.6 were extracted from reference 5, and indicate the role played by the type of oil preservation system, the average moisture content of the transformer insulation, and the time at the overload. For these studies, the fashion in which moisture partitions between hot and cool insulation in an operating transformer was also considered.

This model was developed to explain the data for the oil conservation systems used in the tests in 5. The validity of the model needs to be verified for all oil conservation systems. More work on this subject is required to produce and verify a suitable model for all conservator systems. This work is part of an ongoing research.




NOTE—More recent [A24] experimental results indicate the concentration of nitrogen in the local oil has significantly less effect on the formation of bubbles than indicated by Henry's Law.)

Figure A.4—The summation of partial pressures of nitrogen and water vapor exerted in local oil as the conductor temperature is raised above an initial 100 °C equilibrium condition. Nitrogen blanket oil preservation system and 0.5% moisture in the insulation.



- A = Open conservator, 72 in oil head
- B = 1.2 atm nitrogen blanket, 48 in oil head
- C = 1.5 atm nitrogen blanket, 48 in oil head
- D = Membrane conservator, 72 in oil head, 50 000 ppm nitrogen
- E = Membrane conservator, 72 in oil head, 0 ppm nitrogen

Figure A.5—Time to reach conditions suitable for bubble formation for a range of overloads following stabilization at 0.75 p.u. load



NOTE—1.5 atm nitrogen blanket, 0.75 p.u. initial stabilized load

Figure A.6—Time to reach conditions suitable for bubble formation for a range of moisture contents and overloads

A.2 Bibliography for annex A

- [A1] Baldwin, D. R., Sherman, E. J., and Ringlee, R. J., "Features of the Atmosol Oil Preservation System," *AIEE Transactions*, vol. 77, Part III, pp. 969–973, Dec. 1958.
- [A2] Chadwick, A. T., Ryder, D. H., and Brierly, A. E., "Oil Preservation Systems," *AIEE Transactions*, vol. 79, part III, pp. 92–99, April 1960.
- [A3] Degnan, W. J., Doucett, G. G. Jr., and Ringlee, R. J., "An Improved Method of Oil Preservation and Its Effect on Gas Evolution," *AIEE Transactions*, vol. 77, part III, pp. 657–666, Oct. 1958.
- [A4] Electric Power Research Institute, "Proceedings Second Workshop on Bubble Evolution in Transformers," Report EL-5807, Dec. 1987.
- [A5] Fessler, W. A., Rouse, T. O., McNutt, W. J. and Compton, O. R., "A Refined Mathematical Model for Prediction of Bubble Evolution in Transformers," *IEEE Transactions on Power Delivery*, vol. 4, Nov. 1, pp. 391–404, Jan. 1989.
- [A6] Franklin, E. G., "Sealed Transformers," *IEE Proceedings*, vol. 102, part A, no. 3, pp. 265–278, June 1955.
- [A7] General Electric Company, "Basic Transformer Life Characteristics: Overload Characteristics and Life Test Evaluation," *Electric Power Research Institute Report*, EL-2443, vol. 1, June 1982.
- [A8] General Electric Company, *Electric Power Research Institute Final Report*, no. EL-5384.
- [A9] General Electric Company, "Surge Characteristics and Protection of Distribution Transformers," *Electric Power Research Institute Report*, EL-3385, Jan. 1984.
- [A10] Harrold, R. T., "The Behavior of Electrically Stressed Gas Bubbles Trapped Within Naphthenic and Paraffinic Mineral Oils," IEEE Paper A79 433-4 presented at the 1979 IEEE PES Summer Power Meeting, Vancouver, July 15-20, 1989.
- [A11] Heinrichs, F. W., Truax, D. E., and Phillips, J. D., "The Effect of Gassing During Overloads on the Impulse Strength of Transformer Insulation," IEEE Paper A79 434-2 presented at the 1979 IEEE PES Summer Power Meeting, Vancouver, July 15-20, 1979.
- [A12] Heinrichs, F. W., "Bubble Formation in Power Transformer Windings at Overload Temperatures," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-98, no. 5, pp. 1576–1582, Sept./Oct. 1979.
- [A13] Kaufman, R. B., Shimanski, E. J., and MacFadyen, K. W., "Gas and Moisture Equilibria in Transformer Oil," *AIEE Transactions*, vol. 74, pt. I, pp. 312–318, July 1955.
- [A14] Kaufman, R. B., Pierce, J. L., and Uhlig, E. R., "The Effect of Transformer Oil Preservation Methods on the Dielectric Strength of Oil," *AIEE Transactions*, vol. 76, part III, pp 1315-1321, Feb. 1958.
- [A15] Kaufman, G. H., "Impulse Strength of Distribution Transformers Under Load," *ERDA Report*, CONS-2157-1, Sept. 1976.
- [A16] Kaufman, G. H., "Impulse Testing of Distribution Transformers Under Load," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-96, no. 5, pp. 1583–1595, Sept./Oct. 1977.
- [A17] Kaufman, G. H. and McMillen, C. W., "Gas Bubble Studies and Impulse Tests on Distribution Transformers During Loading Above Nameplate Rating," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-102 no. 8, pp. 2531–2542, Aug. 1983.

- [A18] McNutt, W. J., Rouse, T. O., and Kaufman, G. H., "Mathematical Modelling of Bubble Evolution in Transformers," *IEEE Transaction on Power Apparatus an Systems*, vol. PAS-104, pp. 477–487, Feb. 1985.
- [A19] McNutt, W. J., Kaufman, G. H., Vitols, A. P., and McDonald, J. D., "Short Time Failure Modes Considerations Associated with Power Transformer Overloading," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-99, no. 3, pp. 1186–1197, May/June 1980.
- [A20] McNutt, W. J., and Kaufman, G. H., "Evaluation of a Functional Life Test Model for Power Transformers," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-102, no. 5, May 1983, pp. 1151–1162.
- [A21] McNutt, W. J., "Risk Assessment for Loading Transformers Beyond Nameplate Ratings," *Transactions of American Power Conference*, vol. 47, pp. 710–715, 1985.
- [A22] Meador, J. R., and Dillow, N. E., "Transformer Oil Preservation," *AIEE Transactions*, vol. 76, part III, pp. 1208–1211, December 1957.
- [A23] Westinghouse Electric Corporation, "Basic Research on Transformer Life Characteristics," *Electric Power Research Institute Report*, EL-2622, Sept. 1982.
- [A24] Westinghouse Electric Corporation, *Electric Power Research Institute Project RP 1289-4*, Final Report No. EL 7291.

Annex B Effect of loading transformers above nameplate rating on bushings, tap changers, and auxiliary components

(Normative)

B.1 Bushings

B.1.1 General

The following discussion applies to oil-impregnated, paper-insulated, capacitance-graded bushings only. For other bushing types, consult with the manufacturer for loading guidelines. Bushings are normally designed with a hottest-spot total temperature limit of 105 °C at rated bushing current with a transformer top-oil temperature of 95 °C averaged over a 24 h time period. Operating a transformer beyond nameplate current can result in bushing temperatures above this limit which cause bushing loss-of-life depending on the actual time-temperature profile the bushing sees.

A number of factors that reduce the severity of bushing overloads compared to transformer winding insulation overloads include the following:

- a) Transformer top-oil temperature may be well below 95 °C at rated transformer output.
- b) Bushings are sealed units preserving insulation and thermal integrity.
- c) Bushing insulation is usually drier than transformer insulation.
- d) Bushing insulation is not significantly stressed by fault-current forces.
- e) The use of bushings with higher current ratings than the connected transformer windings.

Possible bushing overload effects include the following:

- Internal pressure build-ups
- Aging of gasket materials
- Unusual increases in power factor from thermal deterioration
- Gassing caused by hottest-spots in excess of 140 °C
- Thermal runaway from increased dielectric losses at high temperatures
- Heating in metallic flanges due to stray magnetic flux

The following overload limits are established for coordination of bushings with transformers:

Ambient air	40 °C maximum
Transformer top-oil temperature	110 °C maximum
Maximum current	2 times rated bushing current
Bushing insulation hottest-spot temperature	150 °C maximum

Methods for calculating bushing lead steady-state and transient hottest-spot temperatures are included in [BB3].

The insulation used in condenser bushings is not thermally upgraded. The relation of insulation deterioration to changes in time and temperature is assumed to follow an adaptation of the Arrhenius reaction rate theory, which states that the logarithm of insulation life is a function of the reciprocal of absolute temperature.

$$\text{Log}_{10}(\text{LIFE}) = \left[\frac{6972.15}{\Theta_H + 273} - 14.133 \right] \quad (\text{B-1})$$

where

LIFE is the life of bushing insulation, hours
 Θ_{HS} is the bushing insulation hottest-spot temperature, °C

The above equation indicates that bushings operated at rated current and rated insulation hot-spot temperature have a predicted life less than that of the transformer insulation. In most cases, bushings are applied at less than rated top-oil temperature and in many cases the transformer rated current is less than the bushing rated current. This results in bushing life equivalent to the transformer insulation life. Considerations may also be given to using a per unit life concept and the insulation aging equation 3 for 55 °C rise transformers.

B.1.2 Draw leads in bushings

Some bushings are designed for a solid or hollow copper rod inside the bushing to give the full bushing rating. Some bushings are also designed to substitute a draw lead cable for the conductor inside the bushings. When a bushing is operated in the draw lead mode, the thermal performance is determined by the size of the lead supplied as part of the transformer, and the nameplate rating of the bushing may not apply. The draw leads may limit transformer loading to less than the capability of the transformer winding insulation or the capability of the bushing.

B.2 Tap-changers

B.2.1 Tap-changers for de-energized operation (TCDO)

ANSI standards do not specify the temperature rise of the contacts for TCDO's. However, TCDO and LTC tap-changers have similar requirements concerning temperature rise of contacts. The rise will also depend on the design of contacts and the "condition" of the contacts when the loading occurs. Although tap-changer contacts may have certain overload capabilities when new, these capabilities may decrease due to a thin film build-up on the contacts that occurs during normal service. Once a contact reaches a critical temperature, a thermal runaway condition can occur. The contacts overheat and a deposit builds up around the contacts, increasing contact resistance until it finally reaches a temperature that will generate gas. As a minimum, this will produce a gas alarm. As a maximum, the gas may trigger a dielectric failure of the transformer.

The thin film build-up described above can be effectively controlled if the TCDO is operated a minimum of once a year. This can be done during an outage for maintenance or whenever the transformer is de-energized to change taps. Whenever this opportunity occurs, the TCDO should be operated across its full range approximately 10 times to ensure that all the contacts have been wiped clean. With clean contacts, the problem of thermal runaway and deposit buildup during overload conditions can be minimized,

If, in the transformer owner's experience, the de-energized tap-changer has been operated periodically without problems, the above paragraph is recommended to ensure that the contacts will remain in the best possible condition. However, if, in the owner's experience, the de-energized tap changer has not proven to be completely reliable (as a result of misalignment of the contacts or failure of the mechanized mechanism), he may not wish to operate it under any circumstances.

The decision to follow the recommendation of the above paragraph should be tempered by the actual experience with each transformer.

B.2.2 Load tap-changers

References [BB4] and [BB1] provide the basis for the rating of a load tap-changer. Most North American transformer manufacturers have complied with the requirements of [BB1] prior to the approval of [BB4]. The manufacturer should be consulted if it is necessary to assure that a specific LTC has been designed to these standards.

According to both standards, the basis for the current rating of an LTC includes the following:

- a) Temperature rise limit of 20 °C for any current carrying contact in oil when operating at 1.2 times the maximum rated current of the LTC.
- b) Capable of 40 breaking operations at twice maximum rated current and KVA. Oscillograms taken for each operation shall indicate that in no case is the arcing time such as to endanger the operation of the apparatus.

Standards allow tap-changer contacts to work in 100 °C oil with a temperature rise of 20 °C at 1.2 times the nameplate rating. Also, experience has shown that carbon starts to develop on contacts in oil at elevated temperatures (in the order of 120 °C). How serious this growth of carbon becomes depends on the wiping action of the switch contacts, the frequency that switch operation takes place, and how long the high temperature persists. Another important factor is whether the LTC is located in the main tank or in a separate compartment. Usually arcing contacts of the LTC are located in a separate compartment and the oil temperature is less than 100 °C.

Contact temperature rise over oil can be estimated using the following equation:

$$\Delta\Theta_c = \Delta\Theta_{c,R} \times K^n \quad (\text{B-2})$$

where

- $\Delta\Theta_c$ is the contact temperature rise over oil at per unit load “K”, °C
- $\Delta\Theta_{c,R}$ is the contact temperature rise over oil at rated current, °C
- K is the load through the LTC in per unit of LTC current rating
- n is the exponent of contact temperature rise and may vary over a range of 1.6-1.85. If an exact exponent, based on test results, is not known, a value of 1.8 may be used.

Total contact temperature can then be determined as follows:

$$\Theta_c = \Theta_A + \Delta\Theta_{TO, LTC} + \Delta\Theta_c \quad (\text{B-3})$$

where

- Θ_c is the total contact temperature, °C
- Θ_A is the ambient temperature, °C
- $\Delta\Theta_{TO, LTC}$ is the oil temperature rise over ambient in LTC compartment at per unit load K, °C
- $\Delta\Theta_c$ is the contact temperature rise over oil, °C

The top-oil temperature in the LTC compartment may not be readily available unless the LTC is located in the main tank of the transformer. If the LTC is located in a separate tank, the LTC oil may be in the order of 5-15 °C cooler than the top-oil temperature in the main tank at rated load. As a rule of thumb, it can usually be assumed that the temperature rise of the oil in a separate tank is 80% of the oil temperature rise in the main tank.

The following is an example using the above equations for the case where the LTC is located in a separate compartment. This calculation shows that the LTC could carry an emergency load of as high as 1.32 pu at an ambient of 30 °C before a contact temperature of 120 °C is reached. This assumes that, per the standards, the temperature rise

of the contacts is 20 °C at 1.2 times the maximum rated load and that the oil temperature rise in the separate compartment is 66 °C at 1.32 pu load.

$$\Delta\Theta_{c,R} = \frac{\Delta\Theta_c}{K^N} = \frac{20}{(1.2)^{1.8}} = 14.4^\circ\text{C}$$

where

Θ_A	is ambient	= 30 °C
$\Delta\Theta_{TO, LTC}$	is the oil rise in LTC compartment (80% of top-oil rise of 82 °C at 1.32 pu load)	= 66 °C
$\Delta\Theta_c$	is the maximum contact temperature rise = 14.4 x (1.32) ^{1.8}	= <u>24 °C</u>
Total		120 °C

Some LTC manufacturers have advised caution about using the above approach. One caution is that the cooling ability of the contact geometry and contact mass are also important to consider. In addition, it is not physically possible to actually measure the temperature at the contact point. What is actually measured is a point close to the contact point. The temperature of the actual contact point will be considerably higher. A well designed transformer will have an LTC capable of carrying the same load as the core and coils. That is, the hottest-spot temperature in the transformer will be the limitation to loading, not the LTC contact temperature. If this is the case, calculations as shown above would not be necessary. However, such calculations may be useful if the LTC limits the output of the transformer.

LTCs designed in accordance with IEC standards must be capable of 40 breaking operations at twice maximum rated current and KVA. The user would be wise, however, to exercise caution before operating an LTC in this fashion. It should be realized that a factory test is made under ideal conditions (new oil, new contacts, recently adjusted, etc.). Most LTC manufacturers would agree to a few operations per year at twice rated current and KVA. As the number of operations at twice rated current increases, not only would there be additional contact deterioration, but the likelihood of failure of the LTC would also increase. The wear of contacts and contamination of oil increases rapidly with current. Higher overloads on an LTC will necessitate more frequent maintenance.

B.3 Bushing-type current transformers

B.3.1 General

In their normal location, bushing-type current transformers have the transformer top-oil as their ambient, which is limited to 105 °C total temperature at rated output for 65 °C rise transformers. Loading the power transformer beyond nameplate results in an increase in top-oil temperature and secondary current in the current transformer with an associated temperature rise.

A factor in reducing the severity of the current transformer overload is that the top-oil temperature at rated transformer output may be well below 105 °C. In cases where consideration of the loading and top-oil temperature rise of the power transformer and the current in the current transformer indicates the possibility of excessive operating temperatures in the current transformer, the manufacturer should be consulted on the current transformer capability before loading beyond nameplates. The capability of bushing current transformers under operating conditions cannot necessarily be derived from the rating factor.

It may also be possible to select higher current transformer ratios to reduce secondary currents and thus increase the capability of the current transformer.

B.4 Insulated lead conductors

Within the transformer, connections to tap-changer and line terminals and other internal connections are made with insulated leads and cables. The method of calculating the hottest-spot temperature for these leads is different from that employed for the windings. However, the same hottest-spot limits apply equally for both windings and leads since similar insulating materials are normally used. Generally, the loading of the transformer will not be limited by the lead temperature rise. Recommendations of the manufacturer should be sought if proposed loading cycles are in excess of original specifications for the transformer.

B.5 Bibliography for annex B

[BB1] IEEE Std IEC 214 (1989) On-load tap-changers.

[BB2] IEEE Std C57.13-1993, IEEE Standard Requirements for Instrument Transformers (ANSI).

[BB3] IEEE Std C57.19.100-1995, IEEE Guide for Application of Power Apparatus Bushings (ANSI).

[BB4] IEEE Std C57.131-1995, IEEE Standard Requirements for Load Tap Changers (ANSI).

Annex C Calculation methods for determining ratings and selecting transformer size

(Normative)

C.1 General

A transformer application problem usually needs to answer the question, “Is an available transformer suitable for a given load cycle?” Calculations required to answer this question can be made by hand, or a computer program can be written to automate the calculation. This annex will illustrate calculation procedures used for the determination of loading limits and the selection of a transformer rating. It should be noted that the purpose of the illustration is to show one way to approach the problem. As in most engineering problems, different approaches are possible and judgment must be used in interpreting the results. The principles outlined in the following examples can be applied to all sizes and ratings of transformers. The calculation methods of annex I may be used to determine if the loss of insulation life for these examples is acceptable.

C.2 Calculation determining loading beyond nameplate rating of an existing transformer

For this example, a 65 °C rise triple rated, OA/FOA/FOA directed forced-oil cooled transformer rated 112000/149333/186666 kVA will be used. A load profile is given (see table C.1, normal load in per unit) for a day starting at 6:00 a.m. The hottest-spot winding temperature profile will be determined by calculation. Some simplifying assumptions will be made to make the calculation easier. The first assumption is that maximum cooling will be used throughout the day, even though at the lowest part of the load cycle, the loading will be less than the intermediate rating. The assumption may be optimistic; on the other hand, when loading beyond nameplate rating is planned, it is reasonable to assume that every measure is taken to assist the transformer, including the use of maximum cooling throughout the day.

For the directed forced oil cooling, the n exponent is 1 and no correction of the time constant is required. That is,

$$\tau_{TO} = \tau_{TO, R}$$

For cooling modes with $n < 1$ the time constant should be corrected and this refinement is easily accomplished with a computer program.

The third assumption is that the load is kept constant during the following hour. For the rising part of the load curve this assumption will give loads that are too low, but on the falling part of the load curve loading values that will be too high. It is possible to refine the load representation when there is need.

The last assumption is that the ambient temperature is constant during the day.

Table C.1 —Load cycles and temperature rises for 187 MVA transformer

Normal load						PLBN				LTE				STE			
Hour	Load pu	$\Delta\Theta_{to}$	$\Delta\Theta_{to}$	$\Delta\Theta_H$	Θ_H	Load pu	$\Delta\Theta_{to}$	$\Delta\Theta_H$	Θ_H	Load pu	$\Delta\Theta_{to}$	$\Delta\Theta_H$	Θ_H	Load pu	$\Delta\Theta_{to}$	$\Delta\Theta_H$	Θ_H
6	0.52	18.14	19.20	7.73	56.9	0.66	26.86	12.46	69.3	0.66	26.86	12.46	69.3	0.66	26.86	12.46	69.3
7	0.55	17.14	17.94	8.65	56.6	0.69	24.91	13.62	68.5	0.69	24.91	13.62	68.5	0.69	24.91	13.62	68.5
8	0.61	16.63	17.23	10.63	57.9	0.77	23.75	16.96	70.7	0.77	23.75	16.96	70.7	0.77	23.75	16.96	70.7
9	0.70	16.76	17.21	14.01	61.2	0.88	23.74	22.15	75.9	0.88	23.74	22.15	75.9	0.88	23.74	22.15	75.9
10	0.79	17.74	18.07	17.85	65.9	1.00	25.08	28.60	83.7	1.00	25.08	28.60	83.7	1.00	25.08	28.60	83.7
11	0.85	19.47	19.71	20.66	70.4	1.07	27.76	32.74	90.5	1.07	17.76	32.74	90.5	1.07	27.76	32.74	90.5
12	0.90	21.49	21.67	23.17	74.8	1.13	30.85	36.52	97.4	1.13	30.85	36.52	97.4	1.13	30.85	36.52	97.4
13	0.93	23.66	23.79	24.74	78.5	1.17	34.14	39.15	103.3	1.29	34.14	39.15	103.3	1.92	34.14	39.15	103.3
												47.59	111.7		*	a	a
14	0.96	25.69	25.79	26.36	82.2	1.21	37.29	41.87	109.2	1.33	39.48	50.59	120.1	1.33	46.76	50.59	127.4
15	0.98	27.64	27.71	27.47	85.2	1.23	40.36	43.27	113.6	1.36	44.27	52.90	127.2	1.36	49.73	52.90	132.6
16	0.99	29.39	29.44	28.03	87.5	1.25	43.03	44.69	117.7	1.38	48.46	54.47	132.9	1.38	52.55	54.47	137.0
17	1.00	30.84	30.88	28.60	89.5	1.26	45.40	45.41	120.8	1.39	52.01	55.26	137.3	1.39	55.07	55.26	140.3
18	1.00	32.08	32.11	28.60	90.7	1.26	47.36	45.41	122.8	1.39	54.87	55.26	140.1	1.39	57.17	55.26	142.4
19	0.98	33.01	33.03	27.47	90.5	1.23	48.83	43.27	122.1	1.23	57.02	55.26	142.3	1.23	58.74	55.26	144.0
												43.27	130.3			43.27	132.0

*See C.5 for temperature rises at 13:30 h.

Table C.1—Load cycles and temperature rises for 187 MVA transformer (Continued)

Normal load						PLBN				LTE				STE			
Hour	Load pu	$\Delta\Theta_{to}$	$\Delta\Theta_{to}$	$\Delta\Theta_H$	Θ_H	Load pu	$\Delta\Theta_{to}$	$\Delta\Theta_H$	Θ_H	Load pu	$\Delta\Theta_{to}$	$\Delta\Theta_H$	Θ_H	Load pu	$\Delta\Theta_{to}$	$\Delta\Theta_H$	Θ_H
20	0.97	33.41	33.43	26.91	90.3	1.22	49.38	42.57	122.0	1.22	55.52	42.57	128.1	1.22	56.81	42.57	129.4
21	0.94	33.57	33.58	25.27	88.9	1.18	49.61	39.82	119.4	1.18	54.21	39.82	134.0	1.18	55.18	39.82	125.0
22	0.90	33.26	33.27	23.17	86.4	1.13	49.07	36.52	115.6	1.13	52.52	36.52	119.0	1.13	53.25	36.52	119.8
23	0.86	32.49	32.49	21.15	83.6	1.08	47.81	33.36	111.2	1.08	50.39	33.36	113.8	1.08	50.94	33.36	114.3
24	0.81	31.39	31.39	18.76	80.2	1.02	46.04	29.76	105.8	1.02	47.98	29.76	107.7	1.02	48.39	29.76	108.2
1	0.68	29.94	29.94	13.22	73.2	0.86	43.78	21.15	94.9	0.86	45.23	21.15	96.4	0.86	45.54	21.15	96.7
2	0.61	27.42	27.42	10.64	68.1	0.77	39.85	16.96	86.8	0.77	40.94	16.96	87.9	0.77	41.17	16.96	88.1
3	0.58	24.86	24.86	9.62	64.5	0.73	35.82	15.24	81.1	0.73	36.63	15.24	81.9	0.73	36.81	15.24	82.1
4	0.55	22.67	22.67	8.65	61.3	0.69	32.35	13.62	76.0	0.69	32.96	13.62	76.6	0.69	33.09	13.62	76.7
5	0.53	20.78	20.78	8.03	58.8	0.67	29.33	12.84	72.2	0.67	29.78	12.84	72.6	0.67	29.88	12.84	72.7
6	0.52	19.20	19.20	7.73	56.9	0.66	26.86	12.46	69.3	0.66	27.20	12.46	69.7	0.66	27.27	12.46	69.7

*See C.5 for temperature rises at 13:30 h.

The transformer characteristics at 187 MVA are

Top-oil rise over ambient at rated load

$$\Delta\Theta_{TO, R} = 36.0\text{ }^{\circ}\text{C}$$

Hottest-spot conductor rise over top-oil temperature, at rated load

$$\Delta\Theta_{HS, R} = 28.6\text{ }^{\circ}\text{C}$$

Ratio of load loss at rated load to no-load loss

$$R = 4.87$$

Oil thermal time constant for rated load

$$\tau_{TO, R} = 3.5\text{ h}$$

Exponent of loss function vs. top-oil rise

$$n = 1.0$$

Exponent of load squared vs. winding gradient

$$m = 1.0$$

The ultimate top-oil rise over ambient for load K will be, according to equation 11.

$$\Delta\Theta_{TO,U} = \Delta\Theta_{TO,U} \left[\frac{(K^2 U^R + 1)}{R + 1} \right]^n \quad (C-1)$$

$$\Delta\Theta_{TO,U} = 36.0 \left[\frac{[K^2(4.87) + 1]}{(4.87 + 1)} \right]^n$$

$$\Delta\Theta_{TO,U} = 29.87K^2 + 6.13$$

After 1 h the top-oil temperature rise will be (see equation 9),

$$\Delta\Theta_{TO} = (\Delta\Theta_{TO,U} - \Delta\Theta_i) \left(1 - \exp^{-\frac{t}{\tau_{TO}}} \right) + \Delta\Theta_{TO,i}$$

or rewritten

$$\Delta\Theta_{TO} = \Delta\Theta_{TO,U} \left(1 - \exp^{-\frac{t}{\tau_{TO}}} \right) + \Delta\Theta_{TO,i} \exp^{-\frac{t}{\tau_{TO}}}$$

When we substitute $\tau_{TO} = \tau_{TO,R} = 3.5$, and the $\Delta\Theta_{TO,U}$ value of equation C-1, we obtain for $t = 1$ h

$$\Delta\Theta_{TO} = (29.87K + 6.13) \left(1 - \exp^{-\frac{1}{3.5}} \right) + \Delta\Theta_{TO,i} \exp^{-\frac{1}{3.5}}$$

or

$$\Delta\Theta_{TO} = 7.42K^2 + 1.53 + 0.75\Delta\Theta_{TO,i} \quad (C-2)$$

and for $t = 0.5$ h

$$\Delta\Theta_{TO} = 3.98K + 0.82 + 0.87\Delta\Theta_{TO,i} \quad (C-3)$$

The winding hot-spot rise over top oil will be according to equation 16

$$\Delta\Theta_H = \Delta\Theta_{H,R} K^{2m} = 28.6K^2 \quad (C-4)$$

One quantity, the initial top-oil rise, is still missing and we will have to estimate it. If we assume the load cycle for normal load found in table C.1, we may establish the rms value of the load curve, as an example, for the 6 h load preceding 6:00 a.m.

$$K = \sqrt{\frac{[(0.81)^2 + (0.68)^2 + (0.61)^2 + (0.58)^2 + (0.55)^2 + (0.53)^2]}{6}} = 0.634$$

Using C.1, a load of this magnitude yields an ultimate top-oil rise of

$$\Delta\Theta_{TO,U} = 29.87K^2 + 6.13 = 29.87(0.634)^2 + 6.13 = 18.14 \text{ } ^\circ\text{C}$$

Using $\Delta\Theta_{TO,i} = 18.14 \text{ } ^\circ\text{C}$ at 6:00 a.m., and $K = 0.52$, we can determine $\Delta\Theta_{TO}$ at 7:00 a.m. as follows:

$$\Delta\Theta_{TO} = 7.42K^2 + 1.53 + 0.75\Delta\Theta_{TO,i} = 17.14^\circ\text{C}$$

To determine the top-oil temperature rise at 8:00 a.m. set, $\Delta\Theta_{TO,i} = \Delta\Theta_{TO}$, calculated at 7:00 a.m. Repeated application of equation C-2 will produce a top-oil temperature rise profile; however, a slight discrepancy occurs 24 h later at 6:00 a.m. When one continues to apply equation C-2, convergency to true values is soon obtained, as shown in normal load, $\Delta\Theta_{TO}$ columns of table C.1. The first column represents the first iteration, and the second column represents the results after an additional iteration.

The winding hot-spot rise over top oil, $\Delta\Theta_H$, is considered to be instantaneous. Only where current discontinuities occur will some consideration be given to the winding time-constant.

For example, at 6:00 a.m.:

$$\Delta\Theta_H = (28.6)(0.52)^2 = 7.73^\circ\text{C}$$

The equation, $\Theta_H = \Delta\Theta_{TO} + \Delta\Theta_H + \Theta_A$, will be used to establish the hottest-spot winding temperature Θ_H , using for ambient temperature $\Theta_A = 30.0^\circ\text{C}$.

A complete daily normal load cycle is shown in table C.1 and plotted in figure C.1.

C.3 Planned loading beyond nameplate (PLBN)

The constant on PLBN loading is hottest-spot winding temperatures in the 120-130 °C range; therefore, $\Delta\Theta_{TO} + \Delta\Theta_H = 120^\circ\text{C} - \Theta_A = 90^\circ\text{C}$. The three highest temperatures for the normal loading cycle are just over 90.3 °C; therefore, $\Delta\Theta_{TO} + \Delta\Theta_H = 60.3^\circ\text{C}$.

To estimate what load multiplier K should be to produce $\Delta\Theta_{TO} + \Delta\Theta_H = 90^\circ\text{C}$, we proceed as follows:

$$\left[\frac{(K^2R + 1)}{(R + 1)} \right]^n = \frac{90}{60.3}$$

and solving for K gives

$$K = 1.26$$




Figure C.1—Load cycles for normal loading and planned loading beyond nameplate

The top-oil rise is not quite proportional to the square of the load current (no-load losses are constant) but the winding gradient is proportional to the square of the load current. The multiplier may have to be corrected if it is unsatisfactory. Again we have to estimate an initial top-oil temperature. Following the same procedures as for the normal load, we obtain a temperature profile, based on the load cycle shown in figure C.1. The hottest-spot temperature is in the 120-130 °C range for close to 4 h.

C.4 Long-time emergency loading (LTE)

A user has to consider carefully the emergency loading conditions that may occur on his system. A maximum period of 6 h is used in our example. Assume that the long time emergency begins at 13:00 h, and was preceded by a PLBN loading. Suppose a load multiplier of value K_2 is applied.

At 13:00 h:

$\Delta\theta_{TO}$, $i = 33.90$ °C, which is equal to $\Delta\theta_{TO}$ in the PLBN loading. Apply equation C-2 to find

At 14:00 h:

$$\Delta\theta_{TO} = (7.42 \times 0.93 K_2^2) + 1.53 + (0.75 \times 34.14) = 6.42 K_2^2 + 27.14$$

$$\Delta\theta_H = (28.6 \times 0.96 K_2^2) = 26.36 K_2^2$$

At 15:00 h:

$$\Delta\Theta_{TO} = (7.42 \times 0.96K_2^2) + 153 + (0.75)(6.42K_2^2 + 27.14) = 11.66K_2^2 + 21.89$$

$$\Delta\Theta_H = 27.47K_2^2$$

Repeated application of equation C-2 finally gives at 19:00 h an equation for $\Delta\Theta_{TO}$ and $\Delta\Theta_H$ in terms of K_2 as follows:

$$\Delta\Theta_{TO} + \Delta\Theta_H = 51.25K_2^2 + 11.11$$

The LTE constraint is 140°C, thus,

$$51.25K_2^2 + 11.11 + 30.0 = 140.0$$

and

$$K_2 = 1.39$$

Table C.1 shows the top-oil rise and the winding gradient. At 13:00 h and at 19:00 h, there is a discontinuity in current. The winding time-constant usually is in the order of 3–5 min. After 20 min, ΔT_{HS} will be according to the new load. Figure C.2 shows the hottest-spot temperature profile. The 140°C temperature limitation has been met. The hottest-spot temperature is in the 130–140°C range less than 6 h and in the 120–130°C range longer than 4 h, so a value of 1.39 applied to the per unit load from 13:00–19:00 hours seems to be in order.

C.5 Short-time emergency (STE) loading

In our example an STE loading is assumed to occur at 13:00 h, following a PLBN loading. After 1/2 h, the load is reduced to the LTE loading which will persist for 5.5 h. We will use an interval load value K_3 . The STE constraint is a maximum hottest-spot temperature of 180°C.

At 13:00 h:

$$\Delta\Theta_{TO,i} = 34.14^\circ\text{C}$$

Apply equation C-3 (for $t = 0.5$ h) to obtain at 13:30 h

$$\Delta\Theta_{TO} = 3.98K_3^2 + 0.82 + (0.87)(34.14)$$

$$\Delta\Theta_H = 28.6K_3^2$$

$$\Theta_H = \Delta\Theta_{TO} + \Delta\Theta_H + \Theta_A = 32.58K_3^2 + 30.52 + 30.0 = 180.0$$

$$K_3 = 1.92$$

At 13:30 h: $\Delta\Theta_{TO} = 45.19$, $\Delta\Theta_H = 105.43$, $\Theta_H = 180.6$, load = 1.29 per unit.

At 14:00 h: $\Delta\Theta_{TO} = (3.98)(1.29)^2 + 0.82 + (0.87)(45.19) = 46.76$

Figure C.2 shows the temperature excursion to be within the limits for the STE loading. The hottest-spot temperature will be somewhat longer in the 130–140°C range limit.




Figure C.2—Hottest-spot temperature profile for long time and short time emergency loadings

Annex D Philosophy of guide applicable to transformers with 55 °C average winding rise (65 °C hottest-spot rise) insulation systems

(Normative)

D.1 General

Loading of transformers above nameplate is a controversial subject. Agreement on the loading limits can be agreed upon with the manufacturer if they have been clearly specified prior to the design of the transformer. However, since there has been new knowledge gained in recent years concerning stray flux fields and their effects of metallic temperatures, it is desirable to confirm greater than nameplate load capabilities with the manufacturers of transformers on critical systems.

Some users have considerable experience in loading power transformers above nameplate using computer programs in conjunction with IEEE Std C57.92-1981 and NEMA TR98-1978. Since this approach deals with loss of life due to the effects of thermal aging of the windings, it should always be accompanied with due consideration given to the load capabilities of all other components in the transformer. These components include bushings, tap-changers and terminal boards, current transformers, and leads. Relay settings should also be checked so that load is not dumped. Consideration should also be given to oil expansion and its effect on possible mechanical relief device operation, subsequent possible operation of the fault-pressure relay, and oil clogging of breathing devices. Forced-oil cooler fouling should also be a consideration when determining load capability. This fouling is particularly found in areas having salt spray environments or dust and chemical contaminants present. These computer programs should be modified to reflect this new loading guide where its use may lead to more conservative loading. The loss of a single transformer of over 100 MVA rating rarely causes power interruption of customers. However, loss of one transformer due to its failure or due to the failure of some other part in the electrical circuit can result in increased loading of the back-up transformers. Most utilities do not design for second contingencies without loss of load. The adverse consequences are therefore rather great if the increased loading of the backup transformer results in a failure.

Common sense and good planning is required to keep the economic gains in balance with the risks of failure. Because excessive transformer temperatures weaken the insulation structures physically, and because many of the older transformers have low impedances, short-circuit failures should also be considered. The types of transformer construction are a factor in making this assessment. Most utilities load these transformers conservatively. Gas evolution in power transformers is not a new insulation contaminant. There are at least eight causes of gas within the transformer that have been documented. The risk of having a failure due to free gas in the insulating structure should take into consideration the insulation margins used and the construction of the insulation structures. The risk of failure increases considerably when the insulation levels are reduced three full steps from a typically accepted level such as use of 650 kV BIL on 230 kV transformers. The risk decreases when no insulation collars are used in highly stressed parts of these transformers with reduced BIL. Knowledgeable transformer engineers have paid close attention to gas evolution when specifying and designing these transformers.

The loading of transformers without thermally upgraded insulation (from an insulation aging point of view) can be considered to be similar to transformers with thermally upgraded insulation. The calculation of temperatures included in clause 7 and annex G may be applied equally well for transformers without thermally upgraded insulation. Equation 3 in clause 5 gives the equation for the aging acceleration factor used to calculate equivalent aging and loss of life for transformers with 55 °C rise insulation systems. The normal loss of life ratings are loadings that result in a daily loss of life equal to that of a continuous winding hottest-spot temperature of 95 °C for 55 °C rise transformers.

The factor that determines the greatest risk associated with loading transformers above nameplate rating is the evolution of free gas from the insulation of winding and lead conductors. This gas will result from two major sources:

- a) *Vaporization of water contained in the insulation.* This process is discussed in annex A of this guide.
- b) *Thermal decomposition of cellulose.* Data on the constituent gases and their proportions released by thermal decomposition of both thermally up-graded and non-upgraded cellulose insulation may be found in many of the references in the Bibliographies for annex A and annex I.

D.2 Aging equations

For older transformers with 55 °C average winding rise insulation systems with a rated hottest-spot rise over ambient of 65 °C and a 30 °C ambient, the reference temperature is 95 °C. The equations for per unit life and the aging acceleration factor are as follows:

$$\text{Per unit life} = 2.00 \times 10^{-8} \text{EXP}^{\frac{15\,000}{\Theta_H + 273}} \quad (\text{D-1})$$

$$F_{AA} = \text{EXP}^{\left[\frac{15\,000}{368} - \frac{15\,000}{\Theta_H + 273} \right]} \quad (\text{D-2})$$

Annex E Unusual temperature and altitude conditions

(Normative)

E.1 Unusual temperatures and altitude

Transformers may be applied at higher ambient temperatures or at higher altitudes than specified in IEEE Std C57.12.00-1993, but performance may be affected, and special consideration should be given to these applications.

E.2 Effect of altitude on temperature rise

The effect of the decreased air density due to high altitude is to increase the temperature rise of transformers since they are dependent upon air for the dissipation of heat losses.

E.3 Operation at rated kVA

Transformers may be operated at rated kVA at altitudes greater than 3300 ft (1000 m) without exceeding temperature limits, provided the average temperature of the cooling air does not exceed the values of table E.1 for the respective altitudes.

- a) See 4.3.2 and table 1 in IEEE Std C57.12.00-1993 for corrections of transformer insulation capability at altitudes above 3300 ft (1000 m).
- b) Operation in low ambient temperature with the top liquid at a temperature lower than -20°C may reduce dielectric strength between internal energized components below design levels.

E.4 Operation at less than rated kVA

Transformers may be operated at altitudes greater than 3300 ft (1000 m) without exceeding temperature limits, provided the load to be carried is reduced below rating by the percentages given in table E.2 for each 330 ft (100 m) and that the altitude is above 3300 ft (1000 m).

Table E.1—Maximum allowable average temperature* of cooling air for carrying rated kVA

Method of cooling apparatus	1000 m (3300 ft)	2000 m (6600 ft)	3000 m (9000 ft)	4000 m (13200 ft)
	$^{\circ}\text{C}$			
Liquid-immersed self-cooled	30	28	25	23
Liquid-immersed forced-air-cooled	30	26	23	20
Liquid-immersed forced-oil-cooled with oil-to-air cooler	30	26	23	20

*It is recommended that the average temperature of the cooling air be calculated by averaging 24 consecutive hourly readings. When the outdoor air is the cooling medium, the average of the maximum and minimum daily temperatures may be used. The value obtained in this manner is usually slightly higher by not more than 0.3°C than the true daily average

Table E.2—Rated kVA correction factors for altitudes greater than 3300 ft (1000 m)

Types of cooling	Derating factor% per 330 ft (100 m)
Liquid-immersed air-cooled	0.4
Liquid-immersed water-cooled	0.0
Liquid-immersed forced-air-cooled	0.5
Liquid-immersed forced-liquid-cooled with liquid-to-air cooler	0.5
Liquid-immersed forced-liquid-cooled with liquid-to-water-cooler	0.0

E.5 Bibliography for annex E

[E1] Bellaschi, P. L. and McAuley, P. H., “Temperature, Pressure and Humidity Reference Values,” *AIEE Transactions*, vol. 59, pp. 669–675. Discussion pp. 1227, 1940.

[E2] Blanchard, C. B. and Anderson, C. T., “A Laboratory Investigation of Temperature Rise as a Function of Atmospheric Conditions,” *AIEE Transactions*, vol. 32, pp. 289–299, Feb. 1913.

[E3] Doherty, R. E. and Carter, E. S., “Effect of Altitude on Temperature Rise,” *AIEE Transactions*, vol. 43, pp. 824–839, Discussion pp. 839–843, 1924.

[E4] Frank, J. E and Dwyer, W. O., “The Temperature Rise of Stationary Induction Apparatus as Influenced by the Effects of Temperature, Barometric Pressure, and Humidity of the Cooling Medium,” *AIEE Transactions*, vol. 32, pp. 235–258, Feb. 1913.

[E5] Montsinger, V., “Effect of Altitude on Temperature Rise of Aircraft Transformers,” *AIEE Transactions*, vol. 64, pp. 251–252, 1945.

[E6] Montsinger, V., “Effect of Altitude on Barometric Pressure and Air Density,” from Thermal Characteristics of Transformers, Part I, *General Electric Review*, April 1946, pp. 41–42 and “Effect of Altitude on Temperature Rise of Transformers” from Part II, *General Electric Review*, pp. 37–38, May 1946.

[E7] Montsinger, V. M., “Effect of Barometric Pressure on Temperature Rise of Self-Cooled Stationary Induction Apparatus,” *AIEE Transactions*, vol. 35, part I, pp. 599–633, 1916.

[E8] Montsinger, V. M. and Cooney, W. H., “Temperature Rise of Stationary Electrical Apparatus as Influenced by Radiation, Convection, and Altitude,” *AIEE Transactions*, vol. 43, pp. 814–823, 1924.

[E9] Nelson, John P., “High-Altitude Considerations for Electrical Power Systems and Components,” *IEEE Transactions of Industry Applications*, vol. IA-20, no. 2, pp. 407–412, Mar./April 1984.

[E10] Skinner, C. E. and Chubb, L. W., “Effect of Air Temperature, Barometric Pressure, and Humidity on the Temperature Rise of Electric Apparatus,” *AIEE Transactions*, vol. 32, pp. 279–288, Feb. 1913.

[E11] Tenney, H. W., “Variations of Atmospheric Temperature with Altitude in the United States,” *AIEE Transactions*, vol. 60, pp. 230–232, Discussion pp. 727, 1941.

Annex F Cold-load pickup (CLPU)

(Normative)

F.1 General

Cold-load pickup (CLPU) is the loading imposed on power and distribution transformers upon re-energization following a system outage. When an outage occurs, temperature in residential and office buildings starts to decay towards the outdoor ambient temperature. The amount of this decay and heat loss depends upon the temperature differential, the building insulation level, etc. Diversity among all the electric space heating furnaces and other appliances is rapidly lost. When the power is restored, all connected electric space heating furnaces, heaters, and other appliances will demand power simultaneously until the normal temperature conditions are attained and the diversity is regained. The time required to regain the diversity depends on the heating capacity of the furnaces and the duration of the preceding outage.

Obviously, the total loading imposed on the transformer after power restoration will be substantially higher than its normal peak load. Cold-load pickup consists of the following two components of the restoration load:

- a) Inrush current associated with transformers, motor starting, etc. Although the magnitudes are quite large (in the order of 6 to 25 times the normal current), the duration is quite short, lasting a few cycles.
- b) Load due to loss of diversity among thermostatically controlled cycling appliances. This load may persist for tens of minutes.

F.2 Duration of loads

Duration of this excessive load depends upon several variables, some of which are

- Time of and the day the outage begins
- Day of the week outage ends
- Duration of outage
- Temperature conditions and wind
- Number of customers affected by the outage
- Building size and insulation levels
- Type of load

This loading condition will persist until all the thermostatically controlled appliances are satisfied and the diversity has been restored. Typically, the maximum length of time during an outage until all diversity will be lost is around 20 min. The longer the outage lasts, the longer the load will remain undiversified after re-energization.

F.3 CLPU ratio

The ratio of the post-interruption load to pre-interruption load varies with the length and time of day of the interruption and the ambient temperature during interruption.

As an example, CLPU ratios that may be expected in a utility are as follows:

Load type	CLPU ratio
Major industrial	Less than 1.0
Residential plus 50% industrial	1–1.5
Urban residential plus less than 20% penetration of electric heat	1.5–2.0
Combination urban and rural	2.0–2.5
Rural	2.5–3.0

Different users will have different CLPU ratios depending upon their own customers and operating practices. Each user should look at the ratios for his or her system.

Studies F2 have shown that CLPU with high penetration of electric heating can become a limiting factor for substation transformers and for the protective equipment on the feeder. Electric heat penetration of 50–70% could lead to a CLPU ratio in the range of 3–4, or even higher.

Air conditioning could become a limiting factor if the penetration of air conditioning loads exceeds electric resistance space heating by a factor of 3 or more.

Depending upon normal loading of the transformer, it is possible to reach short-term emergency loading limits of the substation transformer. In some cases, it is possible for CLPU to exceed the thermal limits of a transformer resulting in associated loss of transformer insulation life.

During these types of loads, the auxiliary cooling equipment should be in operation. Since the duration of these loads is short or does not occur often, it is recommended that CLPU be considered as short-time emergency loading of the transformer.

F.4 Other considerations

Although CLPU has not been recognized as a serious problem in the past, changing patterns of oil and gas price and availability in several parts of the country have resulted in a continuing changeover from oil-based heating system to electric space heating system, making CLPU a more serious problem. In the substations where the transformers may be approaching their nameplate loading, it is worthwhile investigating the type of loads served to determine if a CLPU problem exists.

Depending upon circumstances, it may be necessary to restore the load in stages.

The effect of CLPU should be considered in the setting of relays, recloser trip settings, and fuse sizes to prevent nuisance tripping.

When planning capacity additions, utilities normally select the transformer capabilities to accommodate the anticipated load growth. It is recommended that effects of CLPU should also be considered during this planning. Application of loads in excess of nameplate when ambient temperatures are less than 0 °C requires consideration of transformer design, cooling control, and prior loading. Viscosity of the insulation fluid will influence velocity and distribution, and may detrimentally affect heat transfer. For power transformers with external cooling accessories, the method of control should be reviewed to ensure oil flow is induced before loading exceeds the respective ratings. If prior loading cannot be controlled by demand or rate of increase, the windings may experience localized hot spots and accelerated aging of conductor insulation during cold weather ambients.

F.5 Bibliography for annex F

[F1] Aubin and T. Langhame, "Effect of Oil Viscosity on Transformer Loading Capability at Low Ambient Temperatures," IEEE Transactions on Power Delivery, vol. 7 no. 2, pp. 516–524, April 1992.

[F2] "Effects of Cold Load Pickup at the Distribution Substation Transformer," Canadian Electrical Association (CEA), Report 131D 247, Nov. 1988.

[F3] Wilde, R.L. "Effects of Cold Load Pickup at the Distribution Substation Transformer," IEEE Transactions on Power Apparatus and Systems, vol. PAS-104, no. 3, Mar. 1985.

[F4] Wilde, R. L. "Effects of Cold Load Pickup on Distribution Transformers," IEEE Transactions on Power Apparatus and Systems, vol. PAS-100, no. 5 May 1981.

Annex G Alternate temperature calculation method

(Normative)

G.1 General

The transformer loading equations in clause 7 use the top-oil temperature rise over ambient to determine the winding hottest-spot temperature during an overload. When the equations were first proposed in 1945, there were few experimental investigations of the winding hottest-spot temperature during transient loading conditions. Recent investigations ([G4], [G7]) have shown that during overloads, the temperature of the oil in the winding cooling ducts rises rapidly at a time constant equal to the winding. During this transient condition, the oil temperature adjacent to the hot spot location is higher than the top oil temperature in the tank. For the OA and FA cooling modes this phenomena results in winding hottest-spot temperatures greater than predicted by the equations of clause 7. Accurate predictions of the winding hottest-spot temperature requires the use of the temperature of the oil entering and exiting the winding cooling ducts. The equations in clause 7 also assume a constant ambient air temperature during a load cycle. The equations presented in this annex consider type of liquid, cooling mode, winding duct oil temperature rise, resistance and viscosity changes, and ambient temperature and load changes during a load cycle. The derivation of the equations is given in [G8]. A PC Basic computer program is presented to perform the calculations in a step-by-step procedure.

Although the equations more exactly describe the heat transfer and fluid flow phenomena occurring in a liquid-immersed transformer during transient loading, they may not be equally valid for all distribution and power transformers covered by this guide and for all loading conditions. Recent research using imbedded thermocouples and fiber optic detectors indicate that the fluid flow occurring in the winding during transient heating and cooling is an extremely complicated phenomena to describe by simple equations. Research in this field is ongoing at this time and may be incorporated into future revisions of this guide.

G.2 List of symbols

Temperatures are indicated by Θ , and temperature rises or temperature differences are indicated by $\Delta\Theta$.

Equation	Program	Description
—	A	Aging acceleration factor
—	AEQ	Equivalent aging acceleration factor over a complete load cycle
—	ASUM	Equivalent insulation aging over load cycle, h
—	AMB()	Ambient point on input of load cycle curve, °C
D	B	Constant in viscosity equation
G	C	Constant in viscosity equation

Equation	Program	Description
C_{PCORE}	—	Specific heat of core, W-min/lb °C
C_{POIL}	CPF	Specific heat of fluid, W-min/lb °C
—	CPST	Specific heat of steel, W-min/lb °C
C_{PTANK}	—	Specific heat of tank, W-min/lb °C
C_{PW}	C_{PW}	Specific heat of winding material, W-min/lb °C
E_{HS}	PUELHS	Eddy loss at winding hot spot location, per unit of I^2R loss
—	GFLUID	Fluid volume, gallons
H_{HS}	HHS	Per unit of winding height to hot spot location
—	JJ	Number of points on load cycle
I_R	—	Rated current
K_{HS}	TKHS	Temperature correction for losses at hot spot location
—	KK	Number of times results are printed
K_W	TKW	Temperature correction for losses of winding
—	LCAS	Loading case 1 or 2, see input data description in G.5
K	PL	Per unit load
—	PUL()	Per unit load point on load cycle curve
—	MA	Cooling code, 1=OA, 2=FA, 3=non-directed FOA, 4=directed FOA
—	MC	Conductor code, 1=aluminum, 2=copper
—	MCORE	Core overexcitation occurs during load cycle, 0=no, 1=yes
—	MF	Fluid code, 1=oil, 2=silicone, 3=hthc
—	MPR1	Print temperature table, 0=no, 1=yes
—	MPR	Print temperature table, 0=no, 1=yes
M_{CC}	WCC	Core and coil (untanking) weight, lb
M_{CORE}	WCORE	Mass of core, lb
M_{OIL}	WFL	Mass of fluid, lb
M_{TANK}	WTANK	Mass of tank, lb
M_W	WWIND	Mass of windings, lb
$M_W C_{PW}$	XMCP	Winding mass times specific heat, W-min/°C

Equation	Program	Description
ΣMCp	SUMMCP	Total mass times specific heat of fluid, tank, and core, W-min/°C
$P_{C,R}$	PC	Core (no-load) loss, W
$P_{C,OE}$	PCOE	Core loss when overexcitation occurs, W
P_E	PE	Eddy loss of windings, W
P_{EHS}	PEHS	Eddy loss at rated winding hot-spot temperature, W
P_S	PS	Stray losses, W
P_T	PT	Total losses, W
P_W	PW	Winding I^2R loss, W
P_{WHS}	PWHS	Winding I^2R loss at rated hot-spot temperature, W
Q_C	QC	Heat generated by core, W-min
$Q_{GEN,HS}$	QHSGEN	Heat generated at hot spot temperature, W-min
$Q_{GEN,W}$	QWGEN	Heat generated by windings, W-min
$Q_{LOST, HS}$	QLHS	Heat lost for hot-spot calculation, W-min
$Q_{LOST,O}$	QLOSTF	Heat lost by fluid to ambient, W-min
$Q_{LOST, W}$	QWLOST	Heat lost by winding, W-min
Q_S	QS	Heat generated by stray losses, W-min
—	RHOF	Fluid density, lb/in ³
—	SL	Slope of line between two load points of load cycle curve
—	SLAMB	Slope of line between two ambient temperature points of load cycle curve
Δt	DT	Time increment for calculation, min
—	DTP	Time increment for printing calculations, min
—	TIM()	Value of time point on load cycle
—	TIMHS	Time during load cycle when maximum hot spot occurs, h
—	TIMP()	Times when results are printed, min
—	TMP	Time to print a calculation, min
—	TIMCOR	Time when core overexcitation occurs, h
—	TIMTO	Time during load cycle when maximum top oil temperature occurs, h
—	TIMS	Elapsed time, min

Equation	Program	Description
	TIMSH	Elapsed time, h
x	X	Exponent for duct oil rise over bottom oil, 0.5 for OA, FA, and NDFOA, 1.0 for DFOA
y	YN	exponent of average fluid rise with heat loss, 0.8 for OA, 0.9 for FA and NDFOA, 1.0 for DFOA
z	Z	exponent for top to bottom fluid temperature difference, 0.5 for OA and FA, 1.0 for NDFOA and DFOA
Θ	T	Temperature to calculate viscosity, °C
Θ_A	TA	Ambient temperature, °C
$\Theta_{A,R}$	TAR	Rated ambient at kVA base for load cycle, °C
Θ_{BO}	TBO	Bottom fluid temperature, °C
$\Theta_{BO,R}$	TBOR	Bottom fluid temperature at rated load, °C
Θ_{DAO}	TDAO	Average temperature of fluid in cooling ducts, °C
$\Theta_{DAO,R}$	TDAOR	Average temperature of fluid in cooling ducts at rated load, °C
Θ_{TDO}	TTDO	Fluid temperature at top of duct, °C
$\Theta_{TDO,R}$	TTDOR	Fluid temperature at top of duct at rated load, °C
Θ_H	THS	Winding hottest-spot temperature, °C
—	THSMAX	Maximum hottest-spot temperature during load cycle, °C
—	THSR	Winding hottest-spot temperature at rated load, °C
Θ_K	TK	Temperature factor for resistance correction, °C
—	TKHS	Correction factor for correction of losses to hot-spot temperature
—	TKVA1	Temperature base for losses at base kVA input
—	TMU	Temperature in viscosity function, °C
Θ_{AO}	TFAVE	Average fluid temperature in tank and radiator, °C
—	TFAVER	Average fluid temperature in tank and radiator at rated load, °C
Θ_{TO}	TTO	Top fluid temperature in tank and radiator, °C
—	TTOMAX	Maximum top fluid temperature in tank during load cycle, °C
$\Theta_{TO,R}$	TTOR	Top fluid temperature in tank and radiator at rated load, °C
Θ_W	TW	Average winding temperature, °C
Θ_{WO}	TWO	Temperature of oil adjacent to winding hot spot, °C

Equation	Program	Description
$\Theta_{WO,R}$	TWOR	Temperature of oil adjacent to winding hot spot at rated load, °C
—	TWR	Rated Average winding temperature at rated load, °C
$\Theta_{W,R}$	TWRT	Average winding temperature at rated load tested, °C
$\Delta\Theta_{AO,R}$	—	Average oil rise over ambient at rated load, °C
$\Delta\Theta_{BO}$	—	Bottom fluid rise over ambient, °C
$\Delta\Theta_{BO,R}$	THEBOR	Bottom fluid rise over ambient at rated load, °C
$\Delta\Theta_{DO,R}$	THEDOR	Temperature rise of fluid at top of duct over ambient at rated load, °C
$\Delta\Theta_{DO/BO}$	DTDO	Temperature rise of fluid at top of duct over bottom fluid, °C
$\Delta\Theta_{H/A}$	THEHSA	Winding hottest-spot rise over ambient, °C
$\Delta\Theta_{H/WO}$	—	Winding hot-spot temperature rise over oil next to hot-spot location, °C
$\Delta\Theta_{T/B}$	DTTB	Temperature rise of fluid at top of radiator over bottom fluid, °C
$\Delta\Theta_{TO}$	—	Top fluid rise over ambient, °C
$\Delta\Theta_{TO,R}$	THETOR	Top fluid rise over ambient at rated load, °C
—	THKVA2	Rated ave. winding rise over ambient at kVA base of load cycle, °C
$\Delta\Theta_{W/A,R}$	THEWA	Tested or rated average winding rise over ambient, °C
$\Delta\Theta_{WO/BO}$	—	Temperature rise of oil at winding hot-spot location over bottom oil, °C
μ	FNV(B,C,T)	Viscosity, cP
μ_{HS}	VISHS	Viscosity of fluid for hot-spot calculation, cP
$\mu_{HS,R}$	VIHSR	Viscosity of fluid for hot-spot calculation at rated load, cP
μ_W	VIS	Viscosity of fluid for average winding temperature rise calc. cP
$\mu_{W,R}$	VISR	Viscosity of fluid for average winding temperature rise at rated load, cP
t_W	TAUW	Winding time constant, min
—	XKVA1	KVA base for losses in input data
—	XKVA2	KVA base for load cycle curve

Suffixes	Description
1	At the prior time
2	At the next instant of time
R	At rated load
/	over
Superscript	Description
(')	Indicates adjustment of test report data for a different tap position

Cooling modes	Description
OA	Natural convection flow of oil through windings and radiators. Natural convection flow of air over tank and radiators.
FA	Natural convection flow of oil through windings and radiators. Forced convection flow of air over radiators by fans.
DFOA	Forced oil flow through windings and radiators or heat exchanger by pumps. The oil is directed from the radiators or heat exchangers into the windings. The air is forced over the radiators or heat exchanger by fans.
NDFOA	Forced oil flow through the radiators by one or more pumps. The oil is forced to flow into the tank by the pumps, however the main forced oil flow in the tank bypasses the windings. The air is forced over the radiators or heat exchangers by fans.

G.3 Equations

G.3.1 Introduction

The winding hottest-spot and oil temperatures are obtained from equations for the conservation of energy during a small instant of time, Δt . The system of equations constitute a transient forward-marching finite difference calculation procedure. The equations were formulated so that temperatures obtained from the calculation at the prior time t_1 are used to compute the temperatures at the next instant of time $t_1 + \Delta t$ or t_2 . The time is incremented again by Δt , and the last calculated temperatures are used to calculate the temperatures for the next time step. At each time step, the losses were calculated for the load and corrected for the resistance change with temperature. Corrections for fluid viscosity changes with temperature were also incorporated into the equations. With this approach, the required accuracy is achieved by selecting a small value for the time increment Δt and the programming approach is very simple. No iteration is required.

The improved system of loading equations is based on the fluid flow conditions occurring in the transformer during transient conditions. The hottest-spot temperature is made up of the following components:

$$\Theta_H = \Theta_A + \Theta_{BO} + \Delta\Theta_{WO/BO} + \Delta\Theta_{H/WO} \quad (G-1)$$

The energy balance equation to determine the oil temperature was based on the average oil temperature in the tank and radiators. The temperatures of the top and bottom oil are determined from equations G-2 and G-3.

$$\Theta_{BO} = \Theta_{AO} - \frac{\Delta\Theta_{T/B}}{2} \quad (G-2)$$

$$\Theta_{BO} = \Theta_{AO} + \frac{\Delta\Theta_{T/B}}{2} \quad (G-3)$$

For overload conditions, the oil temperature rise at the hottest-spot location ΔT_{WO} is the temperature rise of the oil in the winding cooling ducts above the bottom oil temperature. When the load is reduced, the winding duct oil temperature falls, but a portion of the upper winding may still remain in the hotter top oil of the main tank. When the winding duct oil temperature is less than the top oil in the main tank, $\Delta\Theta_{WO/BO}$ is assumed to equal the tank top-oil rise over the bottom oil.

G.3.2 Average winding temperature

The heat generated by the windings during the time t_1 to t_2 is

$$Q_{GEN, W} = K^2 \left[P_W K_W + \frac{P_E}{K_W} \right] \Delta t \quad (G-4)$$

where

$$K_W = \frac{\Theta_{W,1} + \Theta_K}{\Theta_{W,R} + \Theta_K} \quad (G-5)$$

For the OA, FA, and NDFOA cooling modes, the heat lost by the windings is

$$Q_{LOST, W} = \left(\frac{\Theta_{W,1} - \Theta_{DAO,1}}{\Theta_{W,R} - \Theta_{DA(O,R)}} \right)^{5/4} \left(\frac{\mu_{W,R}}{\mu_{W,1}} \right)^{1/4} (P_W + P_E) \Delta t \quad (G-6A)$$

The viscosity μ is evaluated at a temperature equal to the average winding temperature plus the average oil duct temperature divided by two.

For the DFOA cooling mode, no viscosity correction is used since the fluid is pumped and the heat lost is

$$Q_{LOST, W} = \left(\frac{\Theta_{W,1} - \Theta_{DAO,1}}{\Theta_{W,R} - \Theta_{DA(O,R)}} \right) (P_W + P_E) \Delta t \quad (G-6B)$$

The mass and thermal capacitance of the windings may be estimated from the winding time constant. The winding time constant may be determined from the cooling curves obtained during factory heat run testing, or approximate values may be used. From the definition of a time constant for exponential heating or cooling the MCp term may be determined from the following equation:

$$M_W C_P W = \frac{(P_W + P_E) \tau_W}{\Theta_{W,R} - \Theta_{DAO,R}} \quad (G-7)$$

The average winding temperature at time $t = t_2$ is

$$\Theta_{W,2} = \frac{Q_{GEN, W} - Q_{LOST, W} + M_W C_P W \Theta_{W,1}}{M_W C_P W} \quad (G-8)$$

G.3.3 Winding duct oil temperature rise over bottom oil

$$\Delta\Theta_{DO/BO} = \Theta_{TDO} - \Theta_{BO} = \left[\frac{Q_{LOST,W}}{(P_W + P_E)\Delta t} \right]^x (\Theta_{TDO,R} - \Theta_{BO,R}) \quad (G-9)$$

$x = 0.5$ for OA, FA, and NDFOA; 1.0 for DFOA.

For the OA, FA, and DFOA cooling modes the duct top-oil temperature at rated load, $\Theta_{TDO,R}$ is assumed equal to the tank top oil temperature. For non-directed FOA, if the duct top-oil temperature at rated load $\Theta_{TDO,R}$ is not known, it can be assumed to be approximately equal to the average winding temperature at rated load (based on an analysis of the data reported in [G7]).

In [G7], it is shown that the hot spot may not be located at the top of the winding. The oil temperature at the hot-spot elevation is given by

$$\Delta\Theta_{WO/BO} = H_{HS}(\Theta_{TDO} - \Theta_{BO}) \quad (G-10)$$

$$\Theta_{WO} = \Theta_{BO} + \Delta\Theta_{WO/BO} \quad (G-11A)$$

When the winding duct-oil temperature is less than the top oil in the tank, the oil temperature adjacent to the hot spot is assumed equal to the top-oil temperature since the upper portion of the winding may be in contact with the hotter top oil. The equation is as follows:

$$^7 \Theta_{TDO} < \Theta_{TO} \text{ THEN } \Theta_{WO} = \Theta_T \quad (G-11B)$$

G.3.4 Winding hottest-spot temperature

To account for the additional heat generated at the hot-spot temperature, it is necessary to correct the winding losses from the average winding temperature to the hottest-spot temperature by means of the following equations:

$$P_{HS} = \left(\frac{\Theta_{H,R} + \Theta_K}{\Theta_{W,R} + \Theta_K} \right) P_W \quad (G-12)$$

$$P_{EHS} = E_{HS} P_{HS} \quad (G-13)$$

If E_{HS} is not known, it may be estimated; however, it should be equal to or greater than $P_{E,R}$ divided by $P_{W,R}$.

$$Q_{GEN,HS} = K^2 \left[P_{HS} K_{HS} + \frac{P_{EHS}}{K_{HS}} \right] \Delta t \quad (G-14)$$

where

$$K_{HS} = \frac{\Theta_{H,1} + \Theta_K}{\Theta_{H,R} + \Theta_K} \quad (G-15)$$

For the OA, FA, and NDFOA cooling modes, the heat lost at the hot spot location is given by

$$Q_{LOST,HS} = \left[\frac{\Theta_{H,1} - \Theta_{WO}}{\Theta_{H,R} - \Theta_{WO,R}} \right]^{5/4} \left[\frac{\mu_{HS,R}}{\mu_{HS,1}} \right]^{1/4} (P_{HS} + P_{EHS}) \Delta t \quad (G-16A)$$

For the DFOA cooling mode, no viscosity correction is used since the oil is pumped and the heat lost at the hot-spot location is given by

$$Q_{LOST, HS} = \left[\frac{\Theta_{H,1} - \Theta_{WO}}{\Theta_{HS,R} - \Theta_{WO,R}} \right] (P_{HS} + P_{EHS}) \Delta t \quad (\text{G-16B})$$

The winding hot-spot temperature at time t_2 is

$$\Theta_{H,2} = \frac{Q_{GEN, HS} - Q_{LOST, HS} + M_W C_{PW} \Theta_{H,1}}{M_W C_{PW}} \quad (\text{G-17})$$

G.3.5 Average oil temperature

The heat lost by the windings to the duct oil and the heat generated by the core and stray losses is absorbed by the bulk oil in the main tank and radiators and is lost to the ambient air. The heat generated by the core varies slightly with temperature; however, it is assumed constant for the analysis. Overexcitation during the load cycle increases core loss however. The heat generated by the core is given by equations G-18A, G-18B, and G-19 as follows:

For normal excitation:

$$Q_C = P_{C,R} \Delta t \quad (\text{G-18A})$$

For overexcitation:

$$Q_C = P_{C,OE} \Delta t \quad (\text{G-18B})$$

The heat generated by the stray loss is given by:

$$Q_S = \left[\frac{K^2 P_S}{K_W} \right] \Delta t \quad (\text{G-19})$$

The temperature correction, K_W for stray loss is given by equation G-5 and assumes that the temperature of the structural parts is the same as the average winding temperature.

The heat lost by the oil is given by equations G-20 and G-21 as follows:

$$P_T = P_W + P_E + P_S + P_C \quad (\text{G-20})$$

$$Q_{LOST, O} = \left[\frac{\Theta_{AO,1} - \Theta_{A,1}}{\Theta_{AO,R} - \Theta_{A,R}} \right]^{1/y} P_T \Delta t \quad (\text{G-21})$$

To determine the core weight it is necessary to subtract the weight of the windings used in equation 6 from the total core and coil weight given on the outline drawing supplied by the manufacturer.

$$M_W = \frac{M_W C_{PW}}{C_{PW}} \quad (\text{G-22})$$

$$M_{CORE} = M_{CC} - M_W \quad (\text{G-23})$$

$$\sum MCp = M_{TANK}Cp_{TANK} + M_{CORE}Cp_{CORE} + M_{OIL}Cp_{OIL} \quad (G-24)$$

The average oil temperature at time t_2 is given by

$$\Theta_{AO,2} = \frac{Q_{LOST,W} + Q_S + Q_C - Q_{LOST,O} + (\sum MCp)\Theta_{AO,1}}{\sum MCp} \quad (G-25)$$

The heat lost by the winding to oil is given by equation G.6.

G.3.6 Top and bottom oil temperatures

The top and bottom oil temperatures are determined by an equation similar to the equation for duct oil rise.

$$T/B = (\Theta_{TO} - \Theta_{BO}) = \left[\frac{Q_{LOST,O}}{P_T \Delta t} \right]^z (\Theta_{TO,R} - \Theta_{BO}) \quad (G-26)$$

$z = 0.5$ for OA and FA; 1.0 for NDFOA and DFOA

The heat lost by the oil, $Q_{LOST,O}$ is given by equation G-21. The top and bottom oil temperatures then are determined as follows from equations G-2 and G-3:

$$\Theta_{BO} = \Theta_{AO} - \frac{\Delta \Theta_{T/B}}{2}$$

$$\Theta_{BO} = \Theta_{AO} + \frac{\Delta \Theta_{T/B}}{2}$$

G.3.7 Stability requirements

For the OA, FA, and NDFOA cooling modes the system of equations is stable if the following criteria are met:

$$\frac{\tau_W}{\Delta t} > \left(\frac{\Theta_{W,1} - \Theta_{DAO,1}}{\Theta_{W,R} - \Theta_{DAO,R}} \right)^{1/4} \left(\frac{\mu_{W,R}}{\mu_{W,1}} \right)^{1/4} \quad (G-27A)$$

$$\frac{\tau_W}{\Delta t} > \left[\frac{\Theta_{H,1} - \Theta_{WO}}{\Theta_{H,R} - \Theta_{WO,R}} \right]^{1/4} \left[\frac{\mu_{HS,R}}{\mu_{HS,1}} \right]^{1/4} \quad (G-27B)$$

and for DFOA

$$\frac{\tau}{\Delta t} > 1 \quad (G-27C)$$

For the computer program, a time increment of $\Delta t = 0.5$ min is used, and the following criteria used for stability and accuracy for all four cooling modes:

$$\frac{\tau}{\Delta t} > 9 \quad (G-27D)$$

If required, the value of Δt is reduced to meet the stability requirement.

G.3.8 Fluid viscosity and specific heats of materials

Fluid viscosity is highly temperature dependant. The fluid viscosity at any temperature is given by an equation of the form

$$\mu = D \exp^{G/(\Theta + 273)} \quad (\text{G-28})$$

The temperatures used to calculate the viscosity are given in table G.1. Values of the constants D and G for three transformer fluids were derived from property data given in [G1], [G2], and [G3]. The values of these constants are given in table G.2. Specific heats of materials vary only slightly with temperature so that a constant value may be used. Specific heats are given in table G.2.

Table G.1 —Temperatures for calculating viscosity

Equation number	Viscosity term	Temperature for calculation
8	$\mu_{W,R}$	$(\Theta_{W,R} + \Theta_{DAO,R})/2$
8	$\mu_{W,1}$	$(\Theta_{W,1} + \Theta_{DAO,1})/2$
19	$\mu_{HS,R}$	$(\Theta_{H,R} + \Theta_{WO,R})/2$
19	$\mu_{HS,1}$	$(\Theta_{H,1} + \Theta_{WO,1})/2$

G.3.9 Summary of exponents

Values of the exponents used in the temperature calculations are summarized in table G.3.

The computer program allows changing the y exponent for cases for which test data is available.

Table G.2 —Specific heat and constants for viscosity calculation

Material	Cp*	D	G
Oil	13.92	.0013573	2797.3
Silicone	11.49	.12127	1782.3
HTHC	14.55	.00007343	4434.7
Tank(steel)		3.51	
Core(steel)		3.51	
Copper		2.91	
Aluminum		6.80	

*W-min./lb °C

Table G.3 —Summary of exponents

Exponent	Used for	Cooling mode			
		OA	FA	NDFOA	DFOA
x	Duct oil rise	0.5	0.5	0.5	1.0
y	Average oil rise	0.8	0.9	0.9	1.0
z	Top to bottom oil rise in radiator	0.5	0.5	1.0	1.0

G.3.10 Adjustment of rated test data for a different tap position

If it is desired to adjust the test data for operation on a no-load tap position other than that reported on the test report, equations G-29 through G-31 may be used as follows:

G.3.10.1 Top- and bottom-oil rise over ambient

$$\Delta\Theta_{AO,R} = \frac{\Delta\Theta_{TO,R} + \Delta\Theta_{BO,R}}{2} \quad (\text{G-29})$$

$$\Delta\Theta_{TO,R} = \Delta\Theta_{AO,R} \left[\frac{P'_{T,R}}{P_{T,R}} \right]^y + \left[\frac{\Delta\Theta_{TO,R} - \Delta\Theta_{BO,R}}{2} \right] \left[\frac{P'_{T,R}}{P_{T,R}} \right]^z \quad (\text{G-30})$$

$$\Delta\Theta_{BO,R} = \Delta\Theta_{AO,R} \left[\frac{P'_{T,R}}{P_{T,R}} \right]^y + \left[\frac{\Delta\Theta_{TO,R} - \Delta\Theta_{BO,R}}{2} \right] \left[\frac{P'_{T,R}}{P_{T,R}} \right]^z \quad (\text{G-31})$$

G.3.10.2 Average winding rise over ambient

For OA, FA, and DFOA:

$$\Delta\Theta_{DO/BO,R} = \Delta\Theta_{TO,R} - \Delta\Theta_{BO,R} \quad (\text{G-32A})$$

For NDFOA:

$$\Delta\Theta_{DO/BO,R} = \Delta\Theta_{W/A,R} - \Delta\Theta_{BO,R} \quad (\text{G-32B})$$

then

$$\Delta\Theta_{DO/BO,R} = \Delta\Theta_{DO/BO,R} \left[\frac{I'_R}{I_R} \right]^{2x} \quad (\text{G-33})$$

For OA,FA, and NDFOA:

$$\Delta\Theta'_{W/A,R} = \left[\Delta\Theta_{W/A,R} - \Delta\Theta_{BO,R} - \frac{\Delta\Theta_{DO/BO,R}}{2} \right] \left[\frac{I'_R}{I_R} \right]^{1.6} + \Delta\Theta'_{BO,R} + \frac{\Delta\Theta'_{DO/BO,R}}{2} \quad (\text{G-34A})$$

For DFOA:

$$\Delta\Theta'_{W/A,R} = \left[\Delta\Theta_{W/A,R} - \Delta\Theta_{BO,R} - \frac{\Delta\Theta_{DO/BO,R}}{2} \right] \left[\frac{I'_R}{I_R} \right]^{2.0} + \Delta\Theta'_{BO,R} + \frac{\Delta\Theta'_{DO/BO,R}}{2} \quad (\text{G-34B})$$

G.3.10.3 Hottest-spot rise over ambient

For OA, FA, and NDFOA:

$$\Delta\Theta_{H/A,R} = [\Delta\Theta_{H/A,R} - \Delta\Theta_{BO,R} - \Delta\Theta_{DO/BO,R}] \left[\frac{I'_R}{I_R} \right]^{1.6} + \Delta\Theta'_{BO,R} + \Delta\Theta'_{DO/BO,R} \quad (\text{G-35A})$$

For DFOA:

$$\Delta\Theta_{H/A,R} = [\Delta\Theta_{H/A,R} - \Delta\Theta_{BO,R} - \Delta\Theta_{DO/BO,R}] \left[\frac{I'_R}{I_R} \right]^{2.0} + \Delta\Theta'_{BO,R} + \Delta\Theta'_{DO/BO,R} \quad (\text{G-35B})$$

G.3.11 Load cycles and ambient temperatures

Values for the per unit load and ambient temperature are obtained from a plot or table. In the computer program, the load cycle is described by the end points of straight lines where the load or ambient temperature plot changes slope. Figure G.1 and the input data file is an example of this concept. This method more accurately describes the variation of load than the step load change or rms method of clause 7. Values may be input for any number of load points.

G.4 Discussion

The equations require the use of the bottom oil rise over ambient at rated conditions. Reference [G5] requires that this measurement be made during thermal testing; however, the measurement is not normally reported on the transformer test report. For existing units, the data may be obtained from the manufacturer. Specifications for new transformers should require that both the top and bottom oil temperature rises be stated on the test report.

The exponents in the equations were derived from fluid flow and heat transfer principles. The value of the y exponent depends upon the relative contribution of radiation, natural convection, and forced air heat losses and some variation between units. The computer program allows changing the value of the y exponent. Data for the y exponent may be obtained from overload heat run in accordance with [G6]. It is recommended that no changes be made in the other exponents.

The equations consider a variable ambient during the load cycle. Loading capability as a function of ambient may be determined with the equations. The equation formulation assumes that the temperature of the top oil in the tank and radiators are equal. During cold start-up at temperatures below about -20 °C, the oil in the main tank may become considerable hotter than the oil in the radiator. This depends upon the tank and radiator configuration. This condition is not considered in the equations.

Overexcitation of the core is considered in the program to allow predictions of oil and winding temperatures. Overexcitation may increase core loss several times above rated. Overexcitation above 110% of rated may result in core saturation and excessive local overheating. This is not considered. The loading equations also separate eddy and stray losses from losses due to winding resistance. This will permit a future consideration of oil and winding heating effects due to increased stray and eddy losses when harmonic currents are present. Local overheating due to stray losses in the structural parts or the tank may also occur, and this local overheating is not considered in the loading equations. Other clauses of the guide should be consulted for other loading limitations.

Thermal testing in accordance with the [G5] is performed by the short-circuit method, which gives zero core loss. The effect of core loss on the oil temperature is determined by holding above rated current. The computer program listed later was developed for loading of in-service transformers with core loss present. To compare the program predictions with the results of overload thermal tests, zero core loss should be used as input and the per unit loads based on the currents should be held during the various tests.

G.5 Disclaimer statement

This computer program is an essential part of IEEE Std C57.91-1995. This computer program may be copied, sold, or included with software that is sold as long as annex G of IEEE Std C57.91-1995 is cited as the source. This computer program may be used to implement this standard and may be distributed in source code or compiled form in any manner. This file may be copied for individual use by users who have purchased this standard.

The IEEE disclaims any responsibility or liability for damages resulting from misinterpretation or misuse of said information by the user.

Use of the information contained in this computer program is at your own risk. The program is provided on an “as is” basis. No warranty is made, either expressed or implied, and no warranty of merchantability and fitness for use for a particular purpose is provided. The user of this program indemnifies and holds IEEE harmless from any direct,

indirect, incidental, special, exemplary, or consequential damages (including, but not limited to, procurement of substitute goods or services; loss of use, data, or profits; or business interruption) however caused and on any theory of liability, whether in contract, strict liability, or tort (including negligence or otherwise) arising in any way out of the use of this program.

G.6 Computer program

Input data for computer program

Line numbers are used for convenience. They must be used, but have no significance. Reference to instruction numbers refer to the following instructions for data input and default values for unknown data.

	1,
kVA base for losses	____,
Temperature base for losses at this kVA, °C	____,
I_2R losses, P_W , watts (see instruction 1)	____,
Winding eddy losses, P_E , watts (see instruction 1)	____,
Stray losses, P_S , watts (see instruction 1)	____,
Core loss, $P_{C,R}$, watts	____,
	2,
One per unit kVA base for load cycle	____,
Data at this kVA (temperatures and temperature rises in °C):	____,
Rated average winding rise over ambient	____,
Tested or rated average winding rise over ambient, $\Delta\Theta_{W/A,R}$	____,
Tested or rated hot-spot rise over ambient, $\Delta\Theta_{H/A,R}$	____,
Tested or rated top-oil rise over ambient, $\Delta\Theta_{TO,R}$	____,
Tested or rated bottom oil rise over ambient, $\Delta\Theta_{BO,R}$	____,
Rated ambient temperature, $\Theta_{A,R}$	____,
	3,
Winding conductor, 1 = aluminum, 2 = copper	____,
Per unit eddy loss at winding hot-spot, EHS (see instruction 2)	____,
Winding time constant, τ_W , minutes (See instruction 3)	____,
Per unit winding height to hot spot, H_{HS} (see instruction 4)	____,
	4,
Weight of core and coils, M_{CC} , lb	____,
Weight of tank and fittings, M_{TANK} , lb	____,
Type fluid, 1 =oil, 2=silicone, 3=HTHC	____,
Gallons of fluid	____,

(See instruction 5)	5,
Over excitation occurs, 0 = no, 1 = yes	____,
Time when over excitation occurs, h	____,
Core loss during overexcitation, $P_{C,OE}$, W	____,
	6,
Loading case, 1 or 2	____
For case 1 the loading cycle (usually 24 h)	
is assumed to repeat and the initial temperatures are not known.	
For case 2, the initial temperatures (see instruction 6) are input at line 7.	
NOTE — Line 7 data Must be input for case 2 and must not be input for case 1.	
	7,
(See instruction 6)	____
Initial winding hottest-spot temperature, Θ_{HS} , °C	____,
initial average winding temperature, Θ_W , °C	____,
Initial top-oil temperature, Θ_{TO} , °C	____,
Initial top-duct-oil temperature, Θ_{TDO} , °C	____,
Initial bottom-oil temperature, Θ_{BO} , °C	____,
	9,
Type cooling for load cycle, 1 = OA, 2 = FA, 3 = non-directed FOA, 4 = directed FOA	____,
Print temperature table, 0=no, 1=yes	____,
Time increment for printing, minutes	____,
Number of points on load cycle	____,

Data for load cycle, time in hours, ambient in °C (see instruction 7):

10,time(1),ambient(1),per unit load(1)
 11,time(2),ambient(2),per unit load(2)
 12,time(3),ambient(3),per unit load(3)

 xtime (last),ambient (last),per unit load (last)

The following are instructions for data input and default values for unknown data:

- a) Stray losses and winding eddy losses vary inversely with temperature. The total stray and eddy loss may be obtained by calculating total I^2R using the resistance data from the total load loss. The computer program calculates a ratio of instantaneous losses to rated losses to determine the various temperature components. Since stray and eddy losses vary inversely with temperature, it is conservative to assume zero winding eddy loss, that is, the ratio is higher when zero eddy losses are assumed. If resistance data is not available or if a calculation of I^2R is not made, it is conservative to input total load losses for I^2R loss and zero values for winding eddy loss and stray loss.
- b) If the per unit eddy loss at the winding hot-spot location is unknown, use zero. This gives conservative results for the reasons given in instruction 1.
- c) Typical values of the winding time constant are 3-7 min. Estimates may be obtained from resistance cooling curve data from thermal testing. Overloads greater than 1/2 h have a minor effect on the hot-test-spot temperature calculation. If the time constant is unknown, 5 min is suggested.
- d) If the location of the winding hottest spot is unknown, input 1.00 for per unit winding height to the hottest-spot location. Values less than 1.00 are used to compare predicted hot spot temperatures with tested values in test windings with imbedded thermocouples or transformers with fiber optic hotspot detectors.
- e) If overexcitation does not occur, input zero for time overexcitation and normal excitation core loss for core loss during overexcitation.
- f) Case 1 is used for repeating load cycles (usually 24 h) such as planned overloading. Case 2 is used for short-time loading or emergency load cycles that do not repeat and may last less than 24 h. For case 2, the initial temperatures are determined by running a case 1 analysis and using the final temperatures as initial temperatures in line 7 for a case 2 analysis. For convenience, the computer program output lists final temperatures in the same order needed for input in line 7.
- g) For repeating load cycles, data statements for O h and the last time input are equal unless a step load change occurs at zero time. Step changes in load are illustrated by the following example. Assume that the load increases from 0.7 to 1.5 at time 1 h with the ambient of some value, say 30 °C. Two sequential lines of data for the one hour point are required as follows:
xx,1.0,30.0,70
xx,1.0,30.0,1.5

Program example:

It is desired to evaluate the load capability of a transformer rated OA/FA/FA-T-60-28000/37333/46667/52267-138000-34500Y/19919 for a summer load cycle with a maximum ambient of 40 °C and a peak load of 1.1. The losses on the test report are given at 28 000 kVA and 75 °C as follows:

No load	36 986 W
load loss	72 768 W
Total loss	109 755 W

From the resistance data the I^2R losses are calculated to be 51 690 W. Thus, total stray and eddy loss is 72 768-51 690 or 21 078 W. The temperature rise data at 52 267 kVA and the weights and fluid quantity are given as follows:

Core and coil weight, lb	75 600
Tank and radiators, lb	31 400
Gallons of oil	4910

Temperature rises at 52 267 kVA, °C:

Average wdg. guar.	65
Average wdg. test	63
Hottest spot	80
Top oil	55
Bottom oil	25

Values for the per unit load and ambient are obtained from a plot of the load cycle. Values may be input for any number of load points. A plot of the load cycle is shown in figure G.1.




Figure G.1—Example load cycle

The input data file is shown below. The program output file is printed on the following pages.

Input data file:

```

1,28000,75.,51690,0,21078,36986
2,52267,65,63.0,80,55.0,25.0,30.0
3,2,0,5,1.00
4,75600,31400,1,4910
5,0,0,36986
6,1
9,2,1,60,12
10,0,30.0,.73
11,1,29.5,.64
12,6,28.2,.56
13,7,29.8,.62
14,10,35.9,.88
15,13,39.6,1.03
16,14,40,1.07
17,15,40,1.10
18,16,39.6,1.10
19,18,36.8,1.04
20,21,32.5,.88
21,24,30.0,.73

```

Output data file from program:

```

PROGRAM LOADT, VERSION 1.1, 9-15-1993
TRANSFORMER TEMPERATURE CALCULATION WITH VARIABLE LOAD AND AMBIENT
TEMPERATURE USING BOTTOM OIL RISE DUCT OIL RISE, RESISTANCE CHANGE WITH
TEMPERATURE CORRECTIONS FOR FLUID VISCOSITY FOR OA, FA, AND NON-DIRECTED
FOA COOLING MODES. NO VISCOSITY CORRECTION FOR DIRECTED FOA COOLING MODE.

```

```

INPUT DATA FILENAME IS LCYC
OUTPUT DATA FILENAME IS LCYCOUT

```

```

KVA BASE FOR LOSS INPUT DATA          = 28000
TEMPERATURE BASE FOR LOSS INPUT DATA   = 75 C
WINDING I SQUARE R                      = 51690 WATTS
WINDING EDDY LOSS                        = 0 WATTS
STRAY LOSSES                            = 21078 WATTS
CORE LOSS                               = 36986 WATTS
TOTAL LOSSES                             = 109754 WATTS

```

```

WINDING CONDUCTOR IS COPPER
PER UNIT EDDY LOSS AT HOT SPOT LOCATION = 0
WINDING TIME CONSTANT                   = 5 MINUTES
PER UNIT WINDING HEIGHT TO HOT SPOT     = 1

```

```

WEIGHT OF CORE & COILS                   = 75600 POUNDS
WEIGHT OF TANK AND FITTINGS              = 31400 POUNDS
GALLONS OF FLUID                         = 4910
COOLING FLUID IS TRANSFORMER OIL

```

```

ONE PER UNIT LOAD.  = 52267 KVA

```

FORCED AIR (FA) COOLING

EXPONENT OF LOSSES FOR AVERAGE FLUID RISE = 0.9

AT THIS KVA LOSSES AT 95 C ARE AS FOLLOWS:

WINDING I SQUARE R = 191752.2 WATTS

WINDING EDDY LOSS = 0 WATTS

STRAY LOSSES = 68988.03 WATTS

CORE LOSSES = 36986 WATTS

TOTAL LOSS = 297726.3 WATTS

AT THIS KVA INPUT DATA FOR TEMPERATURES AS FOLLOWS:

RATED AVERAGE WINDING RISE OVER AMBIENT = 65 °C

TESTED AVERAGE WINDING RISE OVER AMBIENT = 63 °C

HOTTEST SPOT RISE OVER AMBIENT = 80 °C

TOP FLUID RISE OVER AMBIENT = 55 °C

BOTTOM FLUID RISE OVER AMBIENT = 25 °C

RATED AMBIENT TEMPERATURE = 30 °C

CORE OVEREXCITATION DOES NOT OCCUR

(LOAD-TEMPERATURE TABLE ON PAGE TWO)

Load temperature table

Time Hours	PU Load	AMB Temp	HS Temp	TOPO Temp	TOPDO Temp	BOTO Temp
0.000	0.730	30.0	89.9	74.1	69.6	48.0
1.000	0.640	29.5	82.7	69.5	64.0	45.0
2.000	0.624	29.2	77.9	65.4	60.5	42.4
3.000	0.608	29.0	74.5	62.5	58.1	40.6
4.000	0.592	28.7	71.9	60.3	56.2	39.3
5.000	0.576	28.5	69.7	58.6	54.6	38.2
6.000	0.560	28.2	67.8	57.2	53.2	37.3
7.000	0.620	29.8	68.7	56.6	54.9	37.7
8.000	0.707	31.8	73.7	58.5	59.3	39.7
9.000	0.793	33.9	82.4	62.7	65.2	42.9
10.000	0.880	35.9	92.3	68.5	72.2	47.1
11.000	0.930	37.1	100.4	74.9	78.4	51.3
12.000	0.980	38.4	108.0	80.9	84.3	55.4
13.000	1.030	39.6	115.7	86.6	90.1	59.5
14.000	1.070	40.0	122.3	92.0	95.3	63.1
15.000	1.100	40.0	127.7	96.6	99.5	66.1
16.000	1.100	39.6	130.0	99.8	101.7	68.0
17.000	1.070	38.2	128.4	100.8	101.1	68.2
18.000	1.040	36.8	125.7	99.6	98.9	66.9
19.000	0.987	35.4	121.0	96.7	94.8	64.6
20.000	0.933	33.9	115.1	92.6	89.8	61.3
21.000	0.880	32.5	108.6	87.9	84.4	57.7
22.000	0.830	31.7	102.1	83.0	79.2	54.3
23.000	0.780	30.8	95.9	78.4	74.3	51.1
24.000	0.730	30.0	89.9	74.1	69.6	48.0

TEMPERATURES DURING LOAD CYCLE:

MAX. HOT SPOT TEMP. = 130.0855 AT 16.08333 HOURS

MAX. TOP FLUID TEMP. = 100.7999 AT 16.85 HOURS

FINAL HOT SPOT TEMP. = 89.9446
 FINAL AVE. WIND. TEMP. = 73.36386
 FINAL TOP OIL TEMP. = 74.08505
 FINAL DUCT OIL TEMP. = 69.60123
 FINAL BOT. OIL TEMP. = 48.01001

EQUIVALENT AGING = 36.22312 HOURS

LOAD CYCLE DURATION = 24 HOURS

EQUIVALENT AGING FACTOR = 1.509297 PER UNIT

Program listing:

```

10 REM PROGRAM LOADT,9-15-1993
20 DEFINT I-N:DIM TIM(100),PUL(100),AMB(100),TIMP(1500)
30 PRINT "ENTER INPUT DATA FILENAME"
40 INPUT F2$
50 PRINT "ENTER OUTPUT FILENAME"
60 INPUT F1$
70 OPEN F2$ FOR INPUT AS #2
80 OPEN F1$ FOR OUTPUT AS #1
90 INPUT #2, LN,XKVA1,TKVA1,PW, PE,PS,PC
100 INPUT #2, LN, XKVA2,THKVA2,THEWA,THEHSA,THETOR,THEBOR,TAR
110 INPUT #2, LN,MC,PUELHS,TAUW,HHS
120 INPUT #2, LN,WCC,WTANK,MF,GFLUID
130 INPUT #2, LN,MCORE,TIMCOR, PCOE
140 INPUT #2, LN, LCAS
150 ON LCAS GOTO 170,160
160 INPUT #2, LN, THS,TW,TTO,TTDO,TBO
170 INPUT #2, LN,MA,MPR1,DTP,JJ
180 FOR J=1 TO JJ
190 INPUT #2, LN,TIM(J),AMB(J),PUL(J)
200 TIM(J)=60!*TIM(J)
210 NEXT J
220 CLOSE #2
230 PT=PW+PE+PS+PC
240 PRINT #1, "PROGRAM LOADT, VERSION 1.1, 9-15-1993"
250 PRINT #1,"TRANSFORMER TEMPERATURE CALCULATION WITH VARIABLE"
260 PRINT #1,"LOAD AND AMBIENT TEMPERATURE USING BOTTOM OIL RISE"
270 PRINT #1,"DUCT OIL RISE, RESISTANCE CHANGE WITH TEMPERATURE"
280 PRINT #1,"CORRECTIONS FOR FLUID VISCOSITY FOR OA, FA, AND NON-"
290 PRINT #1,"DIRECTED FOA COOLING MODES. NO VISCOSITY CORRECTION"
300 PRINT #1,"FOR DIRECTED FOA COOLING MODE."
310 PRINT #1,
320 PRINT #1,"INPUT DATA FILENAME IS ";F2$
330 PRINT #1,"OUTPUT DATA FILENAME IS ";F1$
340 PRINT #1,
350 PRINT #1,"KVA BASE FOR LOSS INPUT DATA          = ";XKVA1
360 PRINT #1,"TEMPERATURE BASE FOR LOSS INPUT DATA = ";TKVA1;"C"
370 PRINT #1,"WINDING I SQUARE R                      = ";PW;"WATTS"
380 PRINT #1,"WINDING EDDY LOSS                          = ";PE;"WATTS"

```



```

390 PRINT #1,"STRAY LOSSES                      = ";PS;"WATTS"
400 PRINT #1,"CORE LOSS                        = ";PC;"WATTS"
410 PRINT #1,"TOTAL LOSSES                     = ";PT;"WATTS"
420 PRINT #1,
430 ON MC GOTO 440,460
440 PRINT #1,"WINDING CONDUCTOR IS ALUMINUM"
450 TK=225!:CPW=6.798:GOTO 480
460 PRINT #1,"WINDING CONDUCTOR IS COPPER"
470 TK=234.5:CPW=2.91
480 PRINT #1,"PER UNIT EDDY LOSS AT HOT SPOT LOCATION = ";PUELHS
490 PRINT #1,"WINDING TIME CONSTANT              = ";TAUW;"MINUTES"
500 PRINT #1,"PER UNIT WINDING HEIGHT TO HOT SPOT = ";HHS
510 PRINT #1,
520 PRINT #1,"WEIGHT OF CORE & COILS              = ";WCC;"POUNDS"
530 PRINT #1,"WEIGHT OF TANK AND FITTINGS          = ";WTANK;"POUNDS"
540 PRINT #1,"GALLONS OF FLUID                     = ";GFLUID
550 ON MF GOTO 560,580,600
560 CPF=13.92:RHOF=.031621:C=2797.3:B=.0013473
570 PRINT #1, "COOLING FLUID IS TRANSFORMER OIL":GOTO 620
580 CPF=11.49:RHOF=.0347:C=1782.3:B=.12127
590 PRINT #1, "COOLING FLUID IS SILICONE":GOTO 620
600 CPF=14.55:RHOF=.03178:C=4434.7:B=7.343E-05
610 PRINT #1, "COOLING FLUID IS HTHC"
620 PRINT #1,
630 PRINT #1,"ONE PER UNIT LOAD. = ";XKVA2;" KVA"
640 ON MA GOTO 650,680,710,740
650 X=.5:YN=.8:Z=.5:THEDOR=THETOR
660 PRINT "COOLING MODE IS OA"
670 PRINT #1, "COOLING MODE IS OA":GOTO 770
680 X=.5:YN=.9:Z=.5:THEDOR=THETOR
690 PRINT "COOLING MODE IS FA"
700 PRINT #1, "FORCED AIR (FA) COOLING":GOTO 770
710 X=.5:YN=.9:Z=1!:THEDOR=THEWA
720 PRINT "COOLING MODE IS NON-DIRECTED FOA"
730 PRINT #1, "NON-DIRECTED FORCED OIL (NDFOA) COOLING":GOTO 770
740 X=1!:YN=1!:Z=1!:THEDOR=THETOR
750 PRINT "COOLING MODE IS DIRECTED FOA"
760 PRINT #1, "DIRECTED FOA COOLING (DFOA)"
770 PRINT "NOMINAL VALUE OF Y EXPONENT IS";YN
780 PRINT "DO YOU WISH TO CHANGE? TYPE Y FOR YES AND N FOR NO"
790 INPUT F3$
800 IF F3$ = "Y" THEN GOTO 820
810 GOTO 840
820 PRINT "INPUT DESIRED VALUE OF Y EXPONENT"
830 INPUT YN
840 PRINT "PROGRAM IS RUNNING"
850 PRINT #1, "EXPONENT OF LOSSES FOR AVERAGE FLUID RISE = ";YN
860 TWR=TAR+THKVA2:TWRT=TAR+THEWA
870 THSR=TAR+THEHSA:TTOR=TAR+THETOR
880 TBOR=TAR+THEBOR:TTDOR=THEDOR+TAR
890 TWOR=(HHS*(TTDOR-TBOR))+TBOR
900 TDAOR=(TTDOR+TBOR)/2!:TFAVER=(TTOR+TBOR)/2!
910 XK2=(XKVA2/XKVA1)^2!:TK2=(TK+TWR)/(TK+TKVA1)
920 PW=XK2*PW*TK2:PE=XK2*PE/TK2:PS=XK2*PS/TK2

```

```

930 PT=PW+PE+PS+PC
940 IF (PE/PW)>PUELHS THEN PUELHS=PE/PW
950 TKHS=(THSR+TK)/(TWR+TK):PWHS=TKHS*PW
960 PEHS=PUELHS*PWHS
970 PRINT #1, "AT THIS KVA LOSSES AT";TWR;"C ARE AS FOLLOWS:"
980 PRINT #1, "WINDING I SQUARE R = ";PW;"WATTS"
990 PRINT #1, "WINDING EDDY LOSS = ";PE;"WATTS"
1000 PRINT #1, "STRAY LOSSES = ";PS;"WATTS"
1010 PRINT #1, "CORE LOSSES = ";PC;"WATTS"
1020 PRINT #1, "TOTAL LOSS = ";PT;"WATTS":PRINT #1,
1030 PRINT #1, "AT THIS KVA INPUT DATA FOR TEMPERATURES AS FOLLOWS:
1040 PRINT #1, "RATED AVERAGE WINDING RISE OVER AMBIENT = ";THKVA2;"C"
1050 PRINT #1, "TESTED AVERAGE WINDING RISE OVER AMBIENT = ";THEWA;"C"
1060 PRINT #1, "HOTTEST SPOT RISE OVER AMBIENT = ";THEHSA;"C"
1070 PRINT #1, "TOP FLUID RISE OVER AMBIENT = ";THETOR;"C"
1080 PRINT #1, "BOTTOM FLUID RISE OVER AMBIENT = ";THEBOR;"C"
1090 PRINT #1, "RATED AMBIENT TEMPERATURE = ";TAR;"C"
1100 IF MCORE<1 GOTO 1140
1110 PRINT #1, "CORE OVEREXCITATION OCCURS AT ";TIMCOR;"HOURS"
1120 PRINT #1, "CORE OVEREXCITATION LOSS IS ";PCOE;"WATTS"
1130 GOTO 1150
1140 PRINT #1, "CORE OVEREXCITATION DOES NOT OCCUR"
1150 IF MPR1<1 GOTO 1230
1160 PRINT #1,
1170 PRINT #1, " (LOAD-TEMPERATURE TABLE ON PAGE TWO)
1180 FOR I=1 TO 15
1190 PRINT #1,
1200 NEXT I
1210 PRINT #1, " LOAD TEMPERATURE TABLE"
1220 PRINT #1,
1230 TIMCOR=60*TIMCOR
1240 DT=.5
1250 IF (TAUW/DT)>9! THEN GOTO 1270
1260 DT=DT/2!:GOTO 1250
1270 XMCP=(PE+PW)*TAUW/(TWRT-TDAOR):WWIND=XMCP/CPW
1280 IF WWIND>WCC GOTO 2260
1290 WCORE=WCC-WWIND:CPST=3.51:WFL=GFLUID*231*RHOF
1300 SUMMCP=(WTANK*CPST)+(WCORE*CPST)+(WFL*CPF)
1310 DEF FNV(B,C,TMU)=B*EXP(C/(TMU+273!))
1320 T=(TWRT+TDAOR)/2!:VISR=FNV(B,C,T)
1330 T=(THSR+TWOR)/2!:VIHSR=FNV(B,C,T)
1340 TMP=0!:IF MPR1<1 THEN DTP=15
1350 KK=INT((TIM(JJ)/DTP)+.01)
1360 FOR K=1 TO KK
1370 TMP=TMP+DTP:TIMP(K)=TMP
1380 NEXT K
1390 PRINT #1,
1400 C$="###.### ##.### ##.# ###.# ###.# ###.# ###.#"
1410 IF MPR1<1 THEN GOTO 1450
1420 PRINT #1, " TIME PU AMB HS TOPO TOPDO BOTO"
1430 PRINT #1, " HOURS LOAD TEMP TEMP TEMP TEMP TEMP"
1440 PRINT #1,
1450 ON LCAS GOTO 1460,1480
1460 THS=THSR:TW=TWRT:TTO=TTOR:TTDO=TTDOR:TBO=TBOR

```

```

1470 MPR =0:JLAST=2:GOTO 1490
1480 MPR=MPR1:JLAST=1
1490 TFAVE=(TTO+TBO)/2!:TWO=TBO+(HHS*(TTDO-TBO)) 1500 FOR JJJ=1 TO JLAST
1510 IF JJJ=2 THEN MPR=MPR1
1520 THSMAX=THS:TIMHS=0:TTOMAX=TTO:TIMTO=0
1530 J=1:K=1:TIMS=0!:TIMSH=0!:ASUM=0!
1540 IF MPR<1 THEN GOTO 1560
1550 PRINT #1, USING C$;TIMSH, PUL(1),AMB(1),THS,TTO,TTDO,TBO
1560 TIMS=TIMS+DT
1570 IF TIMS>TIM(J+1) THEN J=J+1
1580 IF TIMS>TIM(JJ) THEN GOTO 2120
1590 TIMSH=TIMS/60!
1600 IF ABS(TIM(J+1)-TIM(J))<.01 THEN J=J+1
1610 SL=(PUL(J+1)-PUL(J))/(TIM(J+1)-TIM(J))
1620 PL=PUL(J)+(SL*(TIMS-TIM(J)))
1630 SLAMB=(AMB(J+1)-AMB(J))/(TIM(J+1)-TIM(J))
1640 TA=AMB(J)+(SLAMB*(TIMS-TIM(J)))
1650 TDAO=(TTDO+TBO)/2!
1660 TKW=(TW+TK)/(TWR+TK)
1670 QWGEN=PL*PL*((TKW*PW)+(PE/TKW))*DT
1680 IF TW<TDAO THEN GOTO 1750
1690 ON MA GOTO 1700,1700,1700,1730
1700 T=(TW+TDAO)/2!:VIS=FNV(B,C,T)
1710 QWLOST=((TW-TDAO)/(TWRT-TDAOR))^1.25*((VISR/VIS)^.25)*(PW+PE)*DT
1720 GOTO 1770
1730 QWLOST=((TW-TDAO)/(TWRT-TDAOR))*(PW+PE)*DT
1740 GOTO 1770
1750 QWLOST=0!
1760 IF TW<TBO THEN TW=TBO
1770 TW=(QWGEN-QWLOST+(XMCP*TW))/XMCP
1780 DTDO=(TTDOR-TBOR)*((QWLOST/((PW+PE)*DT))^X)
1790 TTDO=TBO+DTDO:TDAO=(TTDO+TBO)/2!
1800 TWO=TBO+(HHS*DTDO):TKHS=(THS+TK)/(THSR+TK)
1810 IF (TTDO+.1)<TTO THEN TWO=TTO
1820 IF THS<TW THEN THS=TW
1830 IF THS<TWO THEN THS=TWO
1840 QHSGEN=PL*PL*((TKHS*PWH)+(PEHS/TKHS))*DT
1850 ON MA GOTO 1860,1860,1860,1890
1860 T=(THS+TWO)/2!:VISHS=FNV(B,C,T)
1870 QLHS=((THS-TWO)/(THSR-TWOR))^1.25*((VIHSR/VISHS)^.25)*(PWHS+PEHS)*DT
1880 GOTO 1900
1890 QLHS=((THS-TWO)/(THSR-TWOR))*(PWHS+PEHS)*DT
1900 THS=(QHSGEN-QLHS+(XMCP*THS))/XMCP
1910 QS=((PL*PL*PS)/TKW)*DT
1920 QLOSTF=((TFAVE-TA)/(TFATER-TAR))^(1/YN)*PT*DT
1930 IF MCOE<1 THEN GOTO 1960
1940 IF TIMS<TIMCOR THEN GOTO 1960
1950 QC=PCOE*DT: GOTO 1970
1960 QC=PC*DT
1970 TFAVE=(QWLOST+QC+QS-QLOSTF+(SUMMCP*TFAVE))/SUMM CP
1980 DTTB=((QLOSTF/(PT*DT))^Z)*(TTOR-TBOR)
1990 TTO=TFAVE+(DTTB/2!):TBO=TFAVE-(DTTB/2!)
2000 IF TBO<TA THEN TBO=TA
2010 IF TTDO<TBO THEN TTDO=TBO

```

```

2020 AX=(15000!/383!)-(15000!/(THS+273!))
2030 A=EXP(AX):ASUM=ASUM+(A*DT)
2040 IF THS<THSMAX THEN GOTO 2060
2050 THSMAX=THS:TIMHS=TIMSH
2060 IF TTO<TTOMAX THEN GOTO 2080
2070 TTOMAX=TTO:TIMTO=TIMSH
2080 IF TIMS<TIMP(K) THEN GOTO 1560
2090 IF MPR<1 THEN GOTO 2110
2100 PRINT #1, USING C$;TIMSH, PL,TA, THS,TTO,TTDO,TBO
2110 K=K+1:GOTO 1560
2120 NEXT JJJ
2130 TIMS=TIMS-DT:ASUM=ASUM/60!:AEQ=ASUM/TIMSH:PRINT #1,
2140 PRINT #1,"TEMPERATURES DURING LOAD CYCLE:"
2150 PRINT #1,"MAX. HOT SPOT TEMP. = ";THSMAX;"AT ";TIMHS;"HOURS"
2160 PRINT #1,"MAX. TOP FLUID TEMP. = ";TTOMAX;"AT ";TIMTO;"HOURS"
2170 PRINT #1,:PRINT #1, "FINAL HOT SPOT TEMP.      =" ;THS
2180 PRINT #1, "FINAL AVE. WIND. TEMP.      =" ;TW
2190 PRINT #1, "FINAL TOP OIL TEMP.      =" ;TTO
2200 PRINT #1, "FINAL DUCT OIL TEMP.      =" ;TTDO
2210 PRINT #1, "FINAL BOT. OIL TEMP.      =" ;TBO:PRINT #1,
2220 PRINT #1, "EQUIVALENT AGING = ";ASUM;"HOURS"
2230 PRINT #1, "LOAD CYCLE DURATION = ";TIMSH;"HOURS"
2240 PRINT #1, "EQUIVALENT AGING FACTOR = ";AEQ;"PER UNIT"
2250 GOTO 2290
2260 PRINT "WINDING TIME CONSTANT TOO HIGH"
2270 PRINT #1,"CHANGE INPUT TO LOWER VALUE"
2280 PRINT "CHANGE INPUT TO LOWER VALUE IN INPUT FILE";F2$
2290 CLOSE #1
2300 END

```

G.7 Bibliography for annex G

[G1] ASTM D3487-82a, Standard Specification for Mineral Oil in Electrical Apparatus.

[G2] ASTM D4652-87, Standard Specification for Silicone Fluid Used for Electrical Insulation.

[G3] ASTM Committee D-27.01 (to be issued as D5222), Standard Guide for High Fire Point Electrical Insulating Oils of Petroleum Origin, Project Z 1561 Z, July 15, 1991.

[G4] Aubin, J., and Langhame, T., "Effect of Oil Viscosity on Transformer Loading Capability at Low Ambient Temperatures," *IEEE Transactions on Power Delivery*, vol. 7, no. 2, pp. 516–524, April 1992.

[G5] IEEE Std C57.12.90-1993, IEEE Standard Test Code for Liquid-Immersed Distribution, Power, and Regulating Transformers and IEEE Guide for Short Circuit Testing of Distribution and Power Transformers (ANSI), clause 11.2, p. 51.

[G6] IEEE PC57.119 (P838) (D13.1/1-29-96), Draft Recommended Practice for Performing Temperature Rise Tests on Oil-Immersed Power Transformers at Loads Beyond Nameplate Rating.⁵

[G7] Pierce, L. W., "An Investigation of the Thermal Performance of an Oil Filled Transformer Winding," *IEEE Transactions on Power Delivery*, vol. 7, no. 3, pp. 1347–1358, July 1992.

[G8] Pierce, L. W., "Predicting Liquid Filled Transformer Loading Capability," *IEEE Transactions on Industry Applications*, vol. 30, no. 1, pp. 170–178, Jan./Feb. 1994.

Annex H Operation with part or all of the cooling out of service

(Normative)

H.1 General

Where auxiliary equipment, such as pumps or fans, or both, is used to increase the cooling efficiency, the transformer may be required to operate for some time without this equipment functioning. The permissible loading under such conditions is given in the following subclauses.

H.2 OA/FA transformers

Some manufactures use a large number of small fans and others use a small number of large fans. If the number of fans inoperative is a large percentage of the total, use the self-cooled (OA) rating. For some designs only one or two inoperative fans may result in loss of significant cooling capacity.

H.3 OA/FA/FA, OA/FA/FOA, and OA/FOA/FOA transformers

For triple rated forced-air, forced-oil-cooled transformers with all or part of the cooling inoperative use the nameplate rating based on the full stage of cooling remaining in operation, or if less than a full stage of fan and pump cooling is operative, use the self-cooled (OA) rating. For loss of either fans or pumps on a stage of cooling, use the rating which pertains to total loss of that stage of cooling. For large units with a large number of fans the loss of one or two fans will result in minimal temperature increase. For non-directed FOA units the loss of one or more pumps with the fans still in operation results in an increase in tank top oil which gives increased temperatures for bushings, cables, and other ancillary components but the increase in winding hot-spot rise may not be significant.

H.4 FOA and FOW transformers

H.4.1 General

In general, the heat exchangers used to cool FOA and FOW type transformers will dissipate only an insignificant amount of heat when either the forced-oil circulation or the forced cooling medium (air or water) are inoperative. If only part of the coolers are inoperative, then refer to H.5 for load capability. If all of the coolers are inoperative, loading amounts and durations can be calculated as in H.4.2.

The amount of load carried, the duration of the load, the previous loading condition, the ambient temperature, and the physical parameters of the transformer determine its hottest-spot temperature and the loss-of-life experienced during the period of loss of all cooling. The user should calculate in accordance with the method below and refer to other pertinent clauses of this guide to determine the effects of the operating condition. During the period of loss of all cooling, the only significant amount of heat dissipated by the transformer will depend on tank radiation and its convection characteristics which, in turn, are dependent on tank dimensions. Heat dissipation characteristics may be calculated from measurements obtained by measuring the actual unit or from estimations based on the transformer outline drawings.

H.4.2 Calculations

An approximation of the effect of loading and time upon the oil and hottest-spot temperature can be determined as shown in this subclause. More accurate data may be obtained from the manufacturer.

H.4.2.1 List of symbols

S	= sum of surface areas of tank walls and cover neglecting braces, appurtenances, etc., in ³
C	= thermal capacity as defined in equations 13A or 13B
K	= ratio of load to be carried to 100% FOA nameplate rating
q_{TANK}	= losses dissipated by the tank at reference temperature rise $\Delta\Theta_{AO,R}$
m	= exponent given in table 3
t	= time, h
P_T	= total losses in watts, at load to be maintained
Θ_A	= ambient temperature, °C
Θ_H	= hottest-spot temperature, °C
Δ_H	= hottest-spot rise above top-oil rise at load to be maintained, °C
$\Delta\Theta_{H,R}$	= hottest-spot conductor rise over top-oil temperature at rated load
$\Delta\Theta_{TO-AO}$	= difference in top oil temperature and average oil temperature, °C
$\Delta\Theta_{AO}$	= average oil rise over ambient at time t , °C
$\Delta\Theta_{AO,i}$	= average oil rise over ambient of unit at instant of loss of all cooling, °C
$\Delta\Theta_{AO,R}$	= average oil rise over ambient at maximum nameplate rating obtained from factory test data, °C
$\Delta\Theta_{AO,U}$	= ultimate rise of average oil over ambient, °C
$\Delta\Theta_{TO}$	= top-oil temperature rise over ambient, °C
$\Delta\Theta_{W/A}$	= average winding temperature rise over ambient, °C
τ_L	= oil time constant corresponding to loading condition, h

H.4.2.2 Equations

- 1) Estimate the losses in watts that will be dissipated by the tank at the 100% FOA oil rise after loss of all cooling as follows:

$$q_{TANK} = (0.00365)(S)(\Delta\Theta_{AO,R})^{1.4} \quad (H-1)$$

- 2) Estimate the ultimate rise of average oil for the load that is to be maintained as follows:

$$\Delta\Theta_{AO,U} = \left(\frac{P_T}{q_{TANK}} \right)^{0.8} \Delta\Theta_{AO,R} \quad (H-2)$$

- 3) The time constant corresponding to this loading condition should be calculated as follows:

$$\tau_L = \frac{C[\Delta\Theta_{AO,U} - \Delta\Theta_{AO,R}]}{P_T - q_{TANK}} \quad (H-3)$$

- 4) The average oil rise at any time t for the transformer in this operating mode can be estimated from the following formula:

$$\Delta\Theta_{AO} = (\Delta\Theta_{AO,U} - \Delta\Theta_{AO,R}) \left(1 - \exp \frac{-t}{\tau_L} \right) + \Delta\Theta_{AO,R} \quad (H-4)$$

- 5) During the time period of $t/\tau_L = 0$ to 0.15, the difference between top-oil temperature and average oil temperature can be estimated as follows:

$$\Delta\Theta_{TO-AO} = 7t + 6 \quad (H-5)$$

The estimated top-oil rise can then be determined as follows:

$$\Delta\Theta_{TO} = \Delta\Theta_{TO-AO} + \Delta\Theta_{AO} \quad (H-6)$$

It is recommended that $\Delta\Theta_{TO} + \Theta_A$ not exceed 110 °C.

Estimates of top-oil rises at t/τ_L greater than 0.15 will have to be obtained from the manufacturer.

The hottest-spot rise above top-oil temperature, for directed oil flow units, will increase substantially when the forced-oil flow is stopped. An estimate of this rise can be obtained from the manufacturer. On the premise that some reasonable oil circulation will continue by natural convection, a rough estimate can be made as follows:

For nondirected flow, NDFOA:

$$\Delta\Theta_{H,R} = (\Delta\Theta_{W/A} - \Delta\Theta_{AO,R}) + 5 \quad (\text{H-7A})$$

For directed flow, DFOA:

$$\Delta\Theta_{H,R} = 2.0(\Delta\Theta_{W/A} - \Delta\Theta_{AO,R}) + 5 \quad (\text{H-7B})$$

and then,

$$\Delta\Theta_H = \Delta\Theta_{H,R} K^{2m} \quad (\text{H-8})$$

The average winding rise and average oil rise should be obtained from the certified test reports for the maximum nameplate rating.

The hottest-spot temperature at the load to be maintained can be estimated as follows:

$$\Theta_H = \Theta_A + \Delta\Theta_{TO} + \Delta\Theta_H \quad (\text{H-9})$$

It is recommended that Θ_H not exceed 140 °C.

H.4.3 Caution

In using the equations in subclause H.4.2.2, the following factors should be considered during a loss of cooling situation as follows:

- a) Much of the normal overload protection (overcurrent relay, etc.) installed on a transformer will be inadequate for this operating condition.
- b) The hottest-spot relay (for alarm and in many cases trip), using the two input parameters of phase current and top-oil temperature, is calibrated to a hottest-spot rise over oil with forced-oil circulation in the windings. It will indicate a temperature many degrees lower than actual hottest-spot temperature if there is no forced oil flow in the windings.
- c) If the transformer is of directed flow design and pumps have been lost, it may be necessary to hold top-oil temperature well below normal to keep the hottest-spot temperature within its limitation, since, with drastically reduced oil flow, the hottest-spot gradient is greatly increased. Hence, the top-oil temperatures shall be kept lower to stay within the design hottest-spot limitation.

H.5 Forced-oil-cooled transformers with part of coolers in operation

For forced-oil-cooled (FOA or FOW) transformer ratings with part of the coolers in operation, use the reductions in permissible loading to give the losses in table H.1. These permissible loads will give approximately the same temperature rise as full load with all cooling in operation.

Table H.1—Loading capability for FOA transformers

% of total coolers in operation	Permissible total losses in % of total losses at final load
100	100
80	90
60	78
50	70
40	60
33	50

Annex I Transformer insulation life

(Informative)

I.1 Historical perspectives

In past versions of the guides for loading transformers, much space was dedicated to the subject of “loss-of-life.” The background of this term was not always well understood. Many engineers assumed incorrectly that the “life” in “loss-of-life” referred to the transformer's life. From the beginning, the important modifier “insulation” frequently has been omitted from the phrase, “loss-of-life.” Actually, loss-of-life has always meant “loss-of-insulation life.” Because this distinction is so important, the user should review the following discussion of the history of loss-of-insulation life.

In the 1920s, but reported in 1930, Montsinger [I17] placed varnished cambric tape insulation into a series of oil-filled test tubes, heated them, and then measured the insulation's tensile strength. He reported that the life of the varnished cambric was reduced by one half for each 8 °C increase in continuous temperature. The “end-of-life” was defined as the point where the tensile strength of the varnished cambric reached 50% of its initial value. The loss of 50% of initial tensile strength end point was probably chosen because tensile strength was easy to measure. It also varied in about the same manner as other mechanical properties of the early insulations. This is not true of many of the insulating coatings, etc., in common use today. This was an initial signal for engineers to use their slide rules (later calculators and now computers) to make calculations of the expected life of a transformer's insulation at various operating temperatures to many significant figures beyond the accuracy of the input data.

The end-of-life of a transformer is not determined by a 50% reduction in the tensile strength of its insulation. It has been obvious for some time that transformers with residual insulation tensile strengths well below 20% of initial operate in a completely satisfactory manner. Lamentably, the industry gave far too much credence to Montsinger's test tube work. In 1944, Montsinger [I18] stated that one shouldn't use aging data at higher temperatures and that the 8 °C rule was incorrect for lower temperatures. He also said, “There is, of course, some questions whether laboratory aging tests made on isolated strips of paper in sealed tubes can be applied directly in estimating the life of insulation in a transformer.” Unfortunately, the transformer industry apparently has seemed to ignore this statement.

Later, Dakin [I7] postulated that transformer insulation deteriorated following a modification of Arrhenius' chemical reaction rate theory. Dakin was probably correct, and a simple “insulation” life curve was developed to relate the insulation's life at a test temperature to an operating temperature. The industry took Dakin's work and, unfortunately, Montsinger's residual tensile strength end-of-insulation life end point and arrived at loss-of-life percentages (without the insulation modifier) based on time at various temperatures. These percentages were badly flawed due to the poorly selected end point; yet, with some slight modifications, they still appeared in recent loading guides without that all-important “insulation” modifier. This happened in spite of a contemporary 1947 paper by Satterlee and Reed [I19] whose tests showed that insulation, in a sealed tank of oil with no load but exposed to ambient temperatures only, experienced a reduction of tensile strength to 20% of initial in about 2.5 years.

The data on the loss-of-insulation life curves shown in the different guides differed considerably. For example, although both distribution and power transformers use the same insulation, the loss-of-insulation life curves in the guides show a considerable variation for a specific temperature. The insulation life of distribution transformers is listed as being several times greater than the power transformer's guide insulation life.

In summary, loss-of-life data in previous guides was based, in part, on observations made 60–70 years ago, on obsolete materials, test tube data, and an inferior refined oil. In addition, the original investigator repudiated the data in the 1940s.

In the mid-1950s, a task force of the AIEE Transformers Committee composed of the manufacturers and users of distribution and power transformers undertook the most comprehensive examination of transformer life to date. Sample distribution transformers of each manufacture were subjected to a series of carefully selected loading tests at

a number of different manufacturing locations. The data from each of the investigators was coded to preserve the supplier's identity and sent to a neutral data compiler for review by the task force. It was initially planned by the task force to subject the transformer test models to alternate back-to-back loading and cooling cycles at three carefully determined hottest-spot conductor temperatures to determine their straight line life characteristic in accordance with reaction rate theory. The temperatures selected were 220 °C, 180 °C, and 140 °C. The test duration at each temperature was determined by current theory. The temperature was controlled by a monitor of exactly the same design containing thermocouples located throughout the windings and tank. After thermal cycling, each test model received "product" tests; the monitor received no product tests except oil analysis. The test end point was established as failure during any one of the product tests.

The 220 °C models were aged first to obtain a better estimate of the test duration for subsequent temperatures. To the surprise of many task force members, the 220 °C models survived many more cycles than expected. The variability between manufacturers was quite large as expected. The next series at 180 °C hottest-spot temperature was started at lengthened test duration and sure enough, the models continued to pass test cycle after cycle beyond expectation. Using end point times from the very first 180 °C failures to be reported, the task force predicted both an unacceptably long test cycle for the 140 °C models and a projected standard "life" exceeding hundreds of thousands of hours at normal rated temperature. Many manufacturers discontinued the 180 °C cycles. Others continued to run the tests for their own purposes. Although the end point tests included impulse and low-frequency withstands and short-circuit and visual examination, many of the investigators reported short circuits particularly in the end turns as the ultimate failure mode. Investigation showed this to be true long after nearly total dielectric strength reduction of the insulating system.

Since at least three test temperatures were not obtained from which to extrapolate the life characteristics of the tested systems; and as the "end-of-life" points reached at the 220 °C and 180 °C aging temperatures were significantly longer than anticipated, the task force, after much discussion, arbitrarily redefined the life curve for distribution transformers and supported the subsequent recommendation of the even more conservative power transformer life line.

A careful review of this history has been coupled with recent findings based on work done on model power transformers on two extensive EPRI transformer loading research projects [I2], [I3]. Some results of this review have been as follows:

- a) The reviewers have decided that the insulation life curves for distribution and power transformers are similar.
- b) The insulation life curves for distribution and for power transformers, which were found in their respective previous guides, are not appropriate for modern transformer loading guides, but should be included in a future revision of ANSI C57.100 for thermal evaluation comparisons of the new insulation system.
- c) The chemical test measurement of degree of polymerization (DP) is a much better indication of cellulosic insulation mechanical characteristics than loss of tensile strength.

I.2 Thermal aging principles

The principal constituent of most transformer conductor insulation materials is cellulose, an organic compound whose molecule is made up of a long chain of glucose rings or monomers [I8], [I20], [I12], [I5]. Degree of molecular polymerization refers to the average number of glucose rings in the molecule and it typically ranges from 1000-1400 for new material. A single cellulose fiber will contain many of these long chains and the mechanical strength of the fiber, and hence of its parent material, is closely related to the length of the chains. Thus, the degree of polymerization is a good measure of retained strength and functionality of cellulose.

As cellulose ages thermally in an operating transformer, three mechanisms contribute to its degradation, namely hydrolysis, oxidation, and pyrolysis [I20], [I12]. The agents responsible for the respective mechanisms are water, oxygen, and heat. Each of these agents will have an effect on degradation rate so they must be individually controlled. Water and oxygen content of the insulation can be controlled by the transformer oil preservation system, but control of heat is left to transformer operating personnel.

Since the early days of transformer manufacture, the deterioration of mechanical properties as a result of thermal aging has been recognized. Montsinger [I17] published early aging data and made an observation about the aging rate that has been widely used. He noted that the rate of deterioration of mechanical properties doubled for each 5-10 °C increase in temperature. The doubling factor was not a constant, being about 6 °C in the temperature range from 100-110 °C and 8 °C for temperatures above 120 °C. However, people tend to remember the doubling factor as a constant and the present IEC Loading Guide [I11] uses 6 °C.

In 1948, Dakin [I7] made a more significant advance in defining insulation aging rates by recognizing that aging of cellulose is the result of a chemical reaction, so the rate of change of a measured property can be expressed in the form of a reaction rate constant K_O . This can be applied by multiplying the rate constant, a function of temperature, by the time interval over which the aging takes place to find the percentage change in a property. Mathematically, the rate constant can be expressed by

$$K_O = A' \exp \left[\frac{B}{\Theta + 273} \right] \quad (\text{I-1})$$

where

A' and B are empirical constants
 Θ is temperature in °C

Dakin showed that all aging rate data being compared in an AIEE committee, including Montsinger's data, could fit this relationship. The Dakin relationship, sometimes referred to as the Arrhenius reaction rate equation, has found wide acceptance in the world technical community in the ensuing years.

When the approach discussed is to be used for transformer life definition, there are two aspects involved, the first being the aging rate and the second being the life end-point criterion. These may be separated by treating life as a per unit quantity with the following as a life definition:

$$\text{Per unit life} = A \exp \left[\frac{B}{\Theta_H + 273} \right] \quad (\text{I-2})$$

where

A is a modified per unit constant, derived from the selection of 110 °C as the temperature established for “one per unit life”
 B is the same aging rate slope as equation I-1

This equation expresses the dependence of the aging rate on temperature alone, and the absolute definition of “one per unit life” in units of time can encompass the end-point criterion and the other variables that affect the time to reach that end point, namely water and oxygen content of the insulation system. Each of these aspects may be discussed separately.

Many investigators have measured cellulose aging rates under controlled conditions and have presented their results in the above form. Some measured mechanical properties, some measured DP, and some measured gas evolution rates. To use the reaction rate constant for loading guide purposes, it is desirable to select a single rate slope, the constant B , which would be reasonably accurate for all forms of cellulose. Table I.1 represents the results of a search of the published literature to find that slope.

Dakin's and Sumner's data appear to have been shared within an AIEE committee. Head's observations were most interesting in that he found that the B constants for mechanical properties (tensile strength, burst strength, elongation to rupture), DP and gas evolution were all the same within a range of ± 440 . Most of these data appear to be for non-thermally upgraded paper, but Lampe also evaluated thermally upgraded paper. His B constant in the table is one of the lowest, but his constant for thermally upgraded paper was even lower (9820). This could be the result of a limited

temperature range of measurement, 135 °C–155 °C, from which it would be difficult to find an accurate slope. In recent evaluations to qualify thermally upgraded papers in the US the data falls reasonably close to the ANSI C57.92-1981 slope. It should be pointed out that the ASA C57.92-1948 curve was not an Arrhenius curve, so it does not have a single value of B for all temperatures.

Table I.1—Aging rate constant—B

Source	Basis	B
Dakin [I7]	20% tensile strength retention	18 000
Sumner [I21]] 20% tensile strength retention	18 000
Head [I10]	Mechanical/DP/gas evolution	15 250
Lawson [I14]	10% tensile strength retention	15 500
Lawson [I14]	10% DP retention	11 350
Shroff [I20]	250 DP	14 580
Lampe [I13]	200 DP	11 720
Goto [I9]	Gas Evolution	14 300
ASA C57.92-1948	50% tensile strength retention	14 830*
ANSI C57.92-1981	50% tensile strength retention	16 054
ANSI C57.91-1981	DT life tests	14 594

*120 °C to 150 °C temperature range.

From table I.1 it may seem that there is not a single “right” value of B, but it must be remembered that all experimental data is subject to variability and the materials and test conditions for all of the investigators were certainly not identical. Placing the most emphasis on the more modern data [I20], [I9], [I10], it seems that a value of B of 15 000 would be appropriate and is used in the transformer insulation life curve in this loading guide.

For small distribution transformers, it is possible to define an end point for insulation life by means of functional life tests on the actual apparatus, as was done in the 1960s. But this is not economically practical for power transformers. Another option is to make the definition in terms of a measurable physical characteristic, either mechanical, electrical, or chemical. It can involve a percentage retention of the characteristic or an absolute level of the characteristic that is judged to be essential for functionality. Dielectric strength is the characteristic that would relate most closely to functionality, but it has been found that it deteriorates very slowly if the insulation is not disturbed mechanically. Thus, a mechanical characteristic, usually tensile strength, has customarily been chosen, with an end-point criterion of 50% retained tensile strength. However, this has a deficiency in that 50% retained strength for initially weak paper could be a lower absolute strength than 25% retained strength for initially strong paper.

Functional life test evaluations on power transformer models were sponsored by EPRI in the 1978 to 1982 time period [I2], [I3], [I16]. They demonstrated that the ANSI 50 %-retained tensile-strength life criterion is very conservative. In one program [I2], [I16], small disk coils were aged for 6.2 times ANSI life without failure on short circuit and dielectric end-point tests. The aged coils had suffered only a 10% reduction of the initial dielectric strength. In a separate program [I3], disk windings were aged for 8.6, 12.0, and 15.3 ANSI lives (see IEEE Std C57.92-1981) without failure on short-circuit and dielectric end-point tests.

An alternative end-point criterion, an absolute level of DP, has the advantages that only a small sample is required, measurement is simple, and the results tend to have less dispersion than tensile strength measurements. Many investigators [I8], [I10], [I12], [I14], [I22] have shown good correlation between reduction of mechanical properties and reduction of DP. Using DP, an end-point criterion can be selected based on subjective judgment of “loss of useful mechanical properties.” Various investigators [I6], [I8], [I13], [I20], tend to choose different levels of DP for the end

point, ranging from 100 to 250. A value of 200 seems a good compromise for power transformers, but smaller transformers subjected to lower mechanical stress levels in service could possibly accept a lower limit. Some small transformers have continued operation in service with DP below 100 [I4].

Selection of an absolute value for useful life of transformer insulation at the reference temperature of 110 °C is very subjective. The general feeling at present is that the definition of 65 000 h given in IEEE Std C57.92-1981 (and earlier versions) may be excessively conservative. This value was chosen based on time to 50% tensile strength reduction of the insulation in sealed tube aging tests. The functional life tests on power transformer models previously mentioned confirmed that 65 000 was extremely conservative, perhaps by a factor of 2 or 3. At various times during the early deliberations about loading guides, lower levels of residual tensile strength were considered for the end point in sealed tube aging tests, down to a level of 20% residual [I21]. At that level, the life could be considered to be 150 000 h and would be approximately equivalent to an end-point criterion of 200 residual DP. A slightly more conservative end point would be 25% residual tensile strength at a life of 135 000 h.

Functional life testing of distribution transformers was begun in 1957 [I 1] to evaluate the life of 55 °C average winding rise insulation in that product. A factor of safety of 5 was applied to the most pessimistic results to obtain a life definition for distribution transformers of 180 000 h at 95 °C. More recent tests by individual manufacturers on the 65 °C average winding rise insulation system distribution transformers have demonstrated a similar useful life at 110 °C. The normal life of 180 000 h has been used in this standard for many years.

Both the results of functional tests and service experience suggest that a normal life of 15–20 years at a winding hot spot temperature of 110 °C is a reasonable expectation for both distribution and power transformers with well-dried and oxygen-free insulation systems. A 20-year life has long standing in the loading guides for distribution transformers. When an absolute value is placed on time to reach a selected life end point, the effect of all of the significant variables must be considered, namely heat, water, and oxygen. Accelerated material aging tests that formed the basis for the traditional ANSI C57.92-1981 life curves (time to 50% retained tensile strength) were always carried out with very low moisture and oxygen contents in the aging cell. The same can be said for power transformer models and distribution transformers subjected to functional life tests. However, such is not always the case for in-service transformers, particularly those older units with open conservator oil preservation systems. An end of functional life criterion must, therefore, reflect not only a suitable end-point measurement level, but also appropriate moisture and oxygen levels in the insulation system of the operating transformer. For modern, well-sealed systems, these levels are comparable to those in the sealed cell material life evaluation tests.

The effect of the two controllable variables, water and oxygen, on aging rates has been extensively investigated. Fabre and Pichon [I8] stated a very simple rule for the effect of water, namely that the deterioration rate is directly proportional to the water content. Shroff's data [I20] supports that relationship. The reference moisture level typical for material aging tests is 0.2% to 0.3% by weight, so the deterioration rates must be proportionally increased for higher moisture levels in operating transformers. However, the moisture level at the critical location, the hottest spot, is typically only about half of the average moisture level, because of moisture partitioning by temperature. Fabre [I8] also investigated the effect of oxygen, comparing deterioration rates for a sealed low oxygen content system to an open free-breathing system. He found a deterioration acceleration factor of 2.5 for the open system. In a similar study, Lampe [I13] found a factor of 10. All of these data give utilities good incentive to employ an oil preservation system that maintains low moisture and oxygen levels in their transformers.

Water, heat, and oxygen are the catalyst, the accelerator, and the active reagent in the oxidation of the oil in oil-filled transformers. The products of oil oxidation are acids, esters, and metallic soaps that attack the cellulose insulation with vigor and tenacity. The oxidation by-products also attack the oil producing additional oxidation by-products. If failures of the oil preservation system occur (loss of tank seal), then oil oxidation which dramatically accelerates insulation deterioration can be expected.

To summarize, the effect of heat on the useful life of a cellulose insulation material can be estimated on a per unit basis without regard to end-of-life criteria or internal conditions in the insulation system using equation (I-2). Cumulative loss-of-life can be calculated for varying load conditions on this relative basis (See tables I.2 and I.3), with the result

that one real day of operation will produce less or more aging than one day at the reference temperature of 110 °C (for a 65 °C average winding rise insulation system).

I.3 Example calculations

In the first example (see table I.2) with a mild overload, the life consumption was about 107.7% of one day at reference temperature, while for the short-time emergency load in table I.3, with hottest-spot temperature rising to 180 °C for a very brief time, the life consumption was about 18.6 times that of one day at reference temperature. It should be noted that in the development of tables I.2 and I.3 and in the sample calculation, the hot spot temperature that was used was that for the end of each hour, with the assumption made that the temperature was constant for the full hour. In reality, the hot-spot temperature will vary during any one hour of loading. If this variation is small, there is little error in the calculation of aging hours, but if the variation is larger, such as 5 °C–10 °C, or more as around the hour 17:00 in table I.3, the error can be significant. To minimize this error, it is recommended that a computer program be used in which the aging hours are calculated in small increments, such as every 3 min or 5 min.

One example of the use of the aging acceleration factor (FAA) would be for planned overloading. A 24 h variable load cycle would be input, which consists of variable loads and ambient temperature. The ambient and peak load might be high during the day and reduced during the night. Also an equivalent aging factor for a summer load cycle might be averaged with an equivalent aging factor for the winter. If the average was 1.0 for the year, then the KVA purchased was correct. If the average was above 1.0, then a higher KVA should be purchased. Or, economics might be factored in and the best return on the investment would be achieved by loading to, say, a 1.1 equivalent aging factor, which would accelerate slightly the use of the life of the unit and recover the investment more quickly. The user could then buy a newer transformer with more up-to-date technology if the old one failed due to this loading or other reasons.

In order to apply an absolute time scale to the life measurement, an appropriate end-of-life criterion must be selected. Tensile strength retention of 50% would be conservative and a lesser level could be accepted. Alternatively, an absolute level of DP, such as a value of 200, could be chosen as a level at which “useful mechanical properties” of the cellulose are still retained. In the table I.3 example, the absolute percentage of total life lost in this 24 h period is given for the four “normal life” definitions suggested in 4.2.7.2. In making this calculation, the aging acceleration effects of moisture and oxygen must be considered if these parameters are not maintained at low levels.

Table 1 of clause 5 gives aging acceleration factors.

This annex is based largely on a condensation of material presented in [I15].

$$F_{EQA} = \frac{\sum_{n=1}^N F_{AA,n} \Delta t_n}{\sum_{n=1}^N \Delta t_n} = \frac{25.857}{24} = 1.077$$

This is equivalent to aging of 1.077 days or 25.848 hours at 110 °C.

$$\% \text{ Loss of Life} = \frac{F_{EQA} \times 24 \times 100}{\text{Normal Insulation Life}} = \frac{1.077 \times 24 \times 100}{180,000} = 0.014\%$$

Based on normal insulation life of 180 000 h from table 2.

**Table 1.2—24 h load cycle aging calculation
100 MVA transformer (65 °C rise)**

Time	Load (P.U. of N.P.)	Hot-spot temp. °C	Aging accel factor $F_{AA,n}$	Aging hours	Cumulative age hours
1:00	0.599	80.0	0.036	0.036	0.036
2:00	0.577	72.8	0.015	0.015	0.051
3:00	0.555	72.9	0.015	0.015	0.066
4:00	0.544	72.8	0.015	0.015	0.080
5:00	0.544	71.8	0.013	0.013	0.093
6:00	0.566	71.8	0.013	0.013	0.107
7:00	0.655	73.0	0.015	0.015	0.122
8:00	0.844	74.2	0.018	0.018	0.139
9:00	0.955	85.1	0.066	0.066	0.205
10:00	1.021	92.2	0.148	0.148	0.353
11:00	1.054	99.1	0.318	0.318	0.671
12:00	1.077	104.6	0.571	0.571	1.242
13:00	1.088	109.2	0.921	0.921	2.163
14:00	1.099	112.8	1.329	1.329	3.492
15:00	1.099	116.0	1.830	1.830	5.322
16:00	1.110	117.8	2.185	2.185	7.507
17:00	1.200	125.0	4.376	4.376	11.882
18:00	1.077	130.0	6.984	6.984	18.866
19:00	0.977	125.0	4.376	4.376	23.242
20:00	0.910	114.0	1.499	1.499	24.741
21:00	0.877	104.8	0.583	0.583	25.324
22:00	0.866	97.9	0.279	0.279	25.603
23:00	0.832	93.2	0.166	0.166	25.769
24:00	0.788	87.6	0.088	0.088	25.857

**Table 1.3—24 h load cycle aging calculation
100 MVA transformer (65 °C rise)**

Time	Load (P.U. of N.P.)	Hot-spot temp. Deg. °C	Aging accel factor $F_{AA,n}$	Aging hours	Cumulative age hours
1:00	0.599	80.0	0.036	0.036	0.036
2:00	0.577	72.8	0.015	0.015	0.051
3:00	0.555	72.9	0.015	0.015	0.066
4:00	0.544	72.8	0.015	0.015	0.080
5:00	0.544	71.8	0.013	0.013	0.093
6:00	0.566	71.8	0.013	0.013	0.107
7:00	0.655	73.0	0.015	0.015	0.122
8:00	0.844	74.2	0.018	0.018	0.139
9:00	0.955	85.1	0.066	0.066	0.205
10:00	1.021	92.2	0.148	0.148	0.353
11:00	1.054	99.1	0.318	0.318	0.671
12:00	1.077	104.6	0.571	0.571	1.242
13:00	1.088	109.2	0.921	0.921	2.163
14:00	1.099	112.8	1.329	1.329	3.492
15:00	1.099	116.0	1.830	1.830	5.322
16:00	1.110	117.8	2.185	2.185	7.507
17:00	1.690	180.0	424.922	424.922	432.429
18:00	1.077	130.0	6.984	6.984	439.413
19:00	0.977	125.0	4.376	4.376	443.789
20:00	0.910	114.0	1.499	1.499	445.288
21:00	0.877	104.8	0.583	0.583	445.871
22:00	0.866	97.9	0.279	0.279	446.150
23:00	0.832	93.2	0.166	0.166	446.316
24:00	0.788	87.6	0.088	0.088	446.403

$$F_{EQA} = \frac{\sum_{n=1}^N F_{AA,n} \Delta t_n}{\sum_{n=1}^N \Delta t_n} = \frac{446.403}{24} = 18.6$$

$$\% \text{ Loss of Life} = \frac{F_{EQA} \times 24 \times 100}{\text{Normal Insulation Life}} = \frac{18.6 \times 24 \times 100}{180,000} = 0.248\%$$

Using the normal life selections from table 1 gives the following:

- a) 65 000 h = 0.687%
- b) 135 000 h = 0.331%
- c) 150 000 h = 0.298%
- d) 180 000 h = 0.248%

I.4 Bibliography for annex I

[I1] Acker, C. R. "Transformer Insulation and Transformer Life Expectancy—A More Comprehensive Concept," Paper Number A 76 021-6 presented at the IEEE PES Winter Meeting and Tesla Symposium, New York, NY, Jan. 25-30, 1976.

[I2] "Basic Transformer Life Characteristics," EPRI Report EL-2443, Electric Power Research Institute, Palo Alto, CA, June 1982.

[I3] "Basic Research on Transformer Life Characteristics," EPRI Report 2622, Electric Power Research Institute, Palo Alto, CA, Sept. 1982.

[I4] Bassetto, A. and Mak, J. "Analysis of the Degree of Polymerization of Paper Samples from Service-Aged Transformers," minutes of the 1990 Doble Client Conference, Doble Engineering Company, Watertown, MA.

[I5] Beavers, M. F., Rabb, E. L., and J. C. Leslie, "Permalex, A New Insulation System," *IEEE Transactions on Power Apparatus and Systems*, pp. 64-73, April 1960.

[I6] Bozzini, C. A. "Transformer Aging Diagnosis by Means of Measurement of the Degree of Polymerization. Results of New Experiments," CIGRE Paper 12-08, 1968.

[I7] Dakin, T. W. "Electrical Insulation Deterioration Treated as a Chemical Reaction Rate Phenomenon," *AIEE Transactions*, vol. 66, pp. 113-122, 1947.

[I8] Fabre, J. and Pichon, A., "Deterioration Processes and Products of Paper in Oil. Application to Transformers," CIGRE Paper 137, 1960.

[I9] Goto, K., Tsukioka, H., and Mori, E. "Measurement of Winding Temperature of Power Transformers and Diagnosis of Aging Deterioration by Detection of CO₂ and CO," CIGRE Paper 12-102, 1990.

[I10] Head, G., Gale, P.S., and Lawson, W. G. , "Effects of High Temperature and Electric Stress on the Degradation of Oil-Filled Cable Insulation," presented at the 3rd International Conference on Dielectric Materials, Measurements, and Applications, Birmingham, England, Sept. 1979.

[I11] IEC Publication 354 (1991), Loading guide for oil-immersed power transformers.

- [I12] Lampe, W. and Spicar, E., "The Oxygen-Free Transformer, Reduced Aging by Continuous Degassing," *CIGRE* Paper 12-05, 1976.
- [I13] Lampe, W., Spicar, E., and Carranger, K. "Continuous Purification and Supervision of Transformer Insulation Systems in Service," IEEE Paper A 78 111-7, presented at the IEEE Winter Power Meeting, Jan./ Feb. 1978.
- [I14] Lawson, W. G., Simmons, M. A., and Gale, P.S. "Thermal Aging of Cellulose Paper Insulation," *IEEE Transactions on Electrical Insulation*, vol. EI-12, no. 1, Feb. 1977.
- [I15] McNutt, W. J., "Insulation Thermal Life Considerations for Transformer Loading Guides," *IEEE Transactions on Power Delivery*, vol. 7, no. 1, pp. 392–401, Jan. 1992.
- [I16] McNutt, W. J. and Kaufman, G. H., "Evaluation of a Functional Life Model for Power Transformers," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-102, May 1983, pp. 1151–1162.
- [I17] Montsinger, V. M., "Loading Transformers by Temperature," *AIEE Transactions*, vol. 49, 1930, pp. 776–792.
- [I18] Montsinger, V. M. and Ketchum, P.M., "Emergency Overloading of Air-Cooled Oil-Immersed Power Transformers by Hot-Spot Temperatures," *AIEE Transactions*, vol. 61, pp. 906–16, disc. pp. 993–995, 1944.
- [I19] Satterlee, R. D. and Reed, R. D., "Controlled Temperature and Insulation Protection in the Operation of Transformers," *AIEE Transactions*, vol. 61, pp. 753–758, 1944.
- [I20] Shroff, D. H. and Stannet, A. W., "A Review of Paper Aging in Transformers," *IEE Proceedings*, vol. 132, pt. C, no. 6, Nov. 1985.
- [I21] Sumner, W. A., Stein, G. M. and Lockie, A.M., "Life Expectancy of Oil-Immersed Insulation Structures," *AIEE Transactions*, vol. 72, pp. 924–930, 1953.
- [I22] Yoshida, H. et al., "Degradation of Insulating Materials of Transformers," *IEEE Transactions on Electrical Insulation*, vol. EI-22, no. 6, Dec. 1987.

Annex J Hottest-spot temperature indicators and fiber optic detectors

(Informative)

J.1 General

Usually the hottest-spot temperature cannot be directly measured on commercial designs because of the voltage hazard when placing a temperature detector at the proper location. The hottest-spot temperature for commercial designs may be determined by the manufacturers from analytical studies verified by thermal tests on coils with imbedded temperature detectors. Hottest-spot temperature devices are supplied, when specified, and usually indicate a simulated hottest-spot temperature. The simulated devices J8, J1 are calibrated for use with specific transformers and simulate the hottest-spot temperature by taking into account the top-oil temperature and the load. The simulated hottest-spot indicators may be used to control cooling equipment J3 and give alarms at a predetermined hottest-spot temperature in order to limit overloading.

Direct hottest-spot temperature measurement devices using fiber optics have become available; however, long-term experience is not available at the present. Due to the poor reliability, redundant probes must be used. Experience such as that reported by Troisi J10 indicates that even with extreme care in installation about 25%-33% of the probes can be expected to fail: due to damage. Reported data indicates that the location of the hot spot is difficult to determine. A recent CIGRE J11 survey reported that two to eight sensors would be adequate if placed in the winding where the higher temperature is expected but for prototype transformers it was estimated that twenty to thirty sensors would be required.

Due to the high cost and poor reliability of the fiber optic devices, their use appears to be primarily as a research tool to measure winding hottest-spot temperatures during factory thermal tests on transformers and for use on selected units to obtain dynamic loading data under actual field conditions. Poittevin, et. al. J9, reported overload data on a 100 MVA transformer at 1.15 per unit and at 1.5 per unit for 15 min and reported, "It has been noticed that a simple model with two time constants compiled from 1.15 per unit test is not able to simulate the measured temperature during 1.5 per unit test. This difficulty probably comes from the impossibility to consider the oil temperature evolution as a simple exponential law for thermal phenomena, the duration of which is in the same order than (*sic*) the copper time constant. A further study should permit to provide a thermal model able to simulate the transformer behavior for short overload duration." A CIGRE paper by Cosaert J2 relating to thermal issues and fiber optic detectors was presented at the most recent 1992 session. Testing was still in progress at the time of presentation; however, a preliminary conclusion was that the classic thermal model with only one fixed time constant does not reflect the dynamic behavior of the transformer correctly. Further research should lead to improved temperature prediction equations such as those proposed in annex G.

J.2 Bibliography for annex J

[J1] Book, C. E. and Mason, V. V., "The Hot Spot Rise Simulator," *AIEE Transactions*, vol. 70, pt. II, pp. 1524–1530, 1951.

[J2] Cosaert, F., Goossens, J., Platteau, C., Leemans, P., and Moulaert, G. "Dynamic Analysis of Thermal Behavior of Transformers Using Optical Fibre Measurements," CIGRE Paper 12-305, 1992.

[J3] Fohrhaltz, H. A., "Transformer Cooling Equipment has Optimum Operating Conditions," *AIEE Transactions on Power Apparatus and Systems*, no. 6, pp. 424–427, June 1953.

[J4] Lampe, W., Pettersson, L., Ovren, C., and Wahlstrom, B., "Hot Spot Measurements in Power Transformers," CIGRE Paper 12-02, 1984.

- [J5] McNutt, W. J., McIver, J. C., Leibinger, G. E., Fallon, D. J., and Wickersheim, K. A., "Direct Measurement of Transformer Hot Spot Temperature," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-103, no. 6, pp. 1155–1162, June 1984.
- [J6] McNutt, W. J., "Transformer Loading Capability Information Derived from Winding Hot Spot Measurement," Cigre Paper 12-08, 1984 Session.
- [J7] Norton, E. T. and Wickersheim, K. A., "Improved Fiberoptic Temperature Measurement System for Monitoring Winding Temperatures in Medium and Large Transformers," *IEEE Transactions on Power Deliver*, vol. PWRD-2, no. 3, pp. 831–835, July 1987.
- [J8] Montsinger, V. M. and Childs, A. T., "Temperature Indicator for Transformer Windings," *General Electric Review*, vol. XXI, no. 6, pp. 396–401, June 1918.
- [J9] Poittevin, J., Samat, J., Hennebique, I. and Tanguy, A., "Direct Fibre-Optic Temperature Measurement in an Operating Transformer," CIGRE Paper 12-106, 1990.
- [J10] Troisi, J. F., "Experience with Fiber Optic Hot-Spot Sensors in 450 MVA SMIT Autotransformer," Proceedings 1992 Doble Conference.
- [J11] Working Group 09 of Study Committee 12, "Direct Measurement of Hot-Spot Temperature of Transformers," CIGRE Electra no. 129, pp. 48–51, March 1990.
- [J12] Wickersheim, K. A. "Recent Developments in Fiberoptic Monitoring of Winding Temperatures in Power Transformers," EPRI Workshop on Optical Sensing in Utility Applications, San Francisco, May 14, 1991.